

**CITY OF NAPLES  
PURCHASING DIVISION  
CITY HALL, 735 8<sup>TH</sup> STREET SOUTH  
NAPLES, FLORIDA 34102  
PH: 239-213-7100    FX: 239-213-7105**

**ADDENDUM NUMBER 2**

| NOTIFICATION<br>DATE: | BID TITLE:   | BID NUMBER: | BID OPENING DATE & TIME: |
|-----------------------|--|-------------|--------------------------|
| 4/04/12               | City of Naples – Sidewalk Installation<br>River Park | 033/12      | 04/20/12<br>2:00PM       |

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,  
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

**BID OPENING DATE CHANGE: APRIL 20, 2012 AT 2:00 PM**



CLARIFICATION OF THE WALL DESCRIPTION (Item 13, Page 7 of Addendum 1):

The concrete retaining wall denoted on the plans and bid tabulation shall be defined as an interlocking gravity retaining wall system utilizing a minimum block size of 4" high x 8" wide x 8" deep and shall not exceed 8" high x 12" wide x 12" deep. Color samples shall be provided to the Engineer prior to ordering retaining wall for color determination. Installation methods shall be installed per manufacturer's standards. All references to a retaining wall for this project shall meet the requirements as specified.

**IMPORTANT MESSAGE**

**PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.**

HEIGHT: 1.65 FT  
LENGTH: 35 FT  
WIDTH: 2 FT



**CROSS-SECTION  
B-B**

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.