

**CITY OF NAPLES  
PURCHASING DIVISION  
CITY HALL, 735 8<sup>TH</sup> STREET SOUTH  
NAPLES, FLORIDA 34102  
PH: 239-213-7100    FX: 239-213-7105**

**ADDENDUM NUMBER 2**

<small>NOTIFICATION DATE:</small>  <b>01/01/13</b>	<small>BID TITLE:</small>  <b>Wastewater Treatment Plant Filter Rehabilitation</b>	<small>BID NUMBER:</small>  <b>009/13</b>	<small>BID OPENING DATE &amp; TIME:</small>  <b>01/09/13 2:00PM</b>
--	--	---	---

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,  
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

**Below please find Bid clarifications.**

**The following written questions have been submitted:**

Can you specify how the water is to be removed from the existing filters? Will the City drain the tanks allowing the contractor to remove the media and porous plates?

**Answer:** The City will allow the filter to drain. Boards will be put in place to stop the incoming water; there may be some leakage but will do what we can to stop as much as possible.

**IMPORTANT MESSAGE**

**PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.**