

**CITY OF NAPLES
PURCHASING DIVISION
CITY HALL, 735 8TH STREET SOUTH
NAPLES, FLORIDA 34102
PH: 239-213-7100 FX: 239-213-7105**

ADDENDUM NUMBER 1

NOTIFICATION DATE:	BID TITLE:	BID NUMBER:	BID OPENING DATE & TIME:
01/17/13	WELL HEAD IMPROVEMENTS	013-13	01/28/13 2:00PM

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

The below questions are from the Pre-Bid Meeting. The answers are made part of this bid document.

1) Is there an option of leaving the well pumps in-place during the well head replacement?

Answer: Yes, the well heads may remain in place during the project. Regardless of whether or not the Contractor decides to leave the well pump and piping in place during the project, the Contractor will be required to submit to the City for review and approval their plan to prevent all material, debris, water, etc. from entering the well during the project.

2) Is there a time frame for each well, and how many wells can be out of services at one time?

Answer: Per section 01010 of the specifications, "Two wells may be taken out of service at a time. Once two wells have been taken out of service for refurbishment, authorization to start on the next well will not be granted by the City until a well is accepted by the City and has passed all testing required. No more than two wells may be out of service at a time."

3) What is the anticipated start date for the project?

Answer: Per the bid documents, "The work to be performed under this contract shall be commenced within ten (10) calendar days after date of Notice to Proceed and shall be substantially completed within 120 calendar days after the date of this Notice to Proceed, and shall be finally completed within 30 calendar days after the date of substantial completion." The length of the contract is driven by the expected long lead time of material and the need to wait until flow demands decrease, construction start date is estimated to be in May or June.

4) Do the wells have enclosures?

Answer: Yes

5) What is the estimated value of the project?

Answer: \$100,000.00 is budgeted for this project .

Below find the attendance list for the pre-bid meeting as EXHIBIT A.

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.

EXHIBIT A

City of Naples
NON-MANDATORY PRE-BID
Well Head Improvements
#013-13
January 15, 2013 10:00 AM

Page 1

NAME Lou Gauzo

COMPANY Quality Enterprises

TELEPHONE 239-435-7200

E-MAIL LGAUZO@QE-USA.COM

NAME BRANDY BARTOLONS

COMPANY DN HIGGINS INC

TELEPHONE 239-774-3130

E-MAIL brandyb@dnhiggins.com

NAME Rick Schattes

COMPANY AC Schattes of FI

TELEPHONE 813 741 3010

E-MAIL KEVIN.ACSFI@VERIZON.NET

NAME BEN COPELAND

COMPANY CITY OF NAPLES

TELEPHONE 213-4722

E-MAIL bcopeiland@naplesgov.com

City of Naples
NON-MANDATORY PRE-BID
Well Head Improvements
#013-13

January 15, 2013 10:00 AM

Page 2

NAME Harvey Youngquist

COMPANY Youngquist Brothers, Inc.

TELEPHONE 239-489-4444

E-MAIL Harvey@youngquistbrothers.com

NAME Steve Strickler

COMPANY Strickler Bros Inc

TELEPHONE 239-462-3770

E-MAIL sistickler@embargo.com

NAME BRIAN BRANDFASS

COMPANY Andrew Sitework LLC.

TELEPHONE (239) 226-1606

E-MAIL brian@andrewsitework.com

NAME Greg Givens

COMPANY City Of Naples

TELEPHONE 239-7101

E-MAIL ggivens@naplesgov.com