

**CITY OF NAPLES
PURCHASING DIVISION
CITY HALL, 735 8TH STREET SOUTH
NAPLES, FLORIDA 34102
PH: 239-213-7100 FX: 239-213-7105**

ADDENDUM NUMBER 1

NOTIFICATION DATE:	BID TITLE:	BID NUMBER:	BID OPENING DATE & TIME:
05/23/13	WATER TREATMENT DELROYD DV170-S2 GEARBOX REHAB	035-13	05/30/2013 2:00PM

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

The below question was received for clarification of the bid document.

- In regards to the above referenced bid page 13 item # III Labor, requires "load testing" of the rebuilt unit. The only way to load test this gear drive unit is to attach the City's electric motor unit to it, install it on-site at the water plant, and operate it coupled to the clarifier. Is that the intent of this sentence, or are the bidders not expected to load test it, but rather to just functionally test it in their rebuild shop?

Answer: The intent is for the selected vender to functionally test the gear drive at their shop and provide the results of the test to the City for review.

###

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.