

**CITY OF NAPLES
PURCHASING DIVISION
CITY HALL, 735 8TH STREET SOUTH
NAPLES, FLORIDA 34102
PH: 239-213-7100 FX: 239-213-7105**

**ADDENDUM
FWQ 15-019**

NOTIFICATION DATE:	BID TITLE:	BID NUMBER:	BID OPENING DATE & TIME:
1/6/15	Doctors Pass Head Pin Replacement	15-019	1/9/2015 5:00PM

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED QUOTE.**

The following clarifications are issued for the referenced Formal Written Quote solicitation:

- 1) Is there any record of how long the beam must be or at least the water depth at MLW?
ANSWER: Recently installed channel markers were 35'.
- 2) How far into the bottom does the beam need to be driven?
ANSWER: MLW 11'.
- 3) Is the existing platform to be reused?
ANSWER: No. New platform.
- 4) Depth of water at head pin.
ANSWER: Plus/Minus 11' MLW.
- 5) Minimum Embedment of pile
ANSWER: Unknown (recently driven piles for channel markers were 35').
- 6) Coating on H Pile – Brand – application
ANSWER: Each company usually prefers its own choice. We are open to whatever the contractor uses pending approval.
- 7) Sign Dimensions
ANSWER: 4' diameter.
- 8) Light specs – Visibility rating, lumens, ideally a make and model
ANSWER: McDermott Platform Base Top Hat Model plat white 644b-cl Flashing 15 times per minute with bird spike. We will evaluate a substitute model that the bid company recommends.
- 9) Platform and ladder – Hot Dipped Galvanized or Aluminum
ANSWER: Aluminum.

###

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.