



INVITATION TO BID
CITY OF NAPLES
PURCHASING DIVISION
CITY HALL, 735 8TH STREET SOUTH
NAPLES, FL 34102
PH: 239-213-7100 FX: 239-213-7105

NOTIFICATION DATE: 12/31/13	TITLE WRF Aeration Monitor and Control Instrumentation Improvements	NUMBER: 14-016	OPENING DATE & TIME: 01/27/14 2:00 PM
PRE-BID DATE, TIME AND LOCATION: Non-mandatory Pre-Bid Meeting will be held January 10, 2014; 10:00 AM local time; 380 Riverside Circle, Naples FL, 34102			

NAME OF PARTNERSHIP, CORPORATION OR INDIVIDUAL:	
MAILING ADDRESS:	
CITY-STATE-ZIP:	
PH:	EMAIL:
FX:	WEB ADDRESS:

<p>I certify that this bid is made without prior understanding, agreement, or connection with any corporation, firm, or person submitting a bid for the same materials, supplies, or equipment and is in all respects fair and without collusion or fraud. I agree to abide by all conditions of this bid and certify that I am authorized to sign this bid for the bidder. In submitting a bid to the City of Naples the bidder offers and agrees that if the bid is accepted, the bidder will convey, sell, assign or transfer to the City of Naples all rights, title, and interest in and to all causes of action it may now or hereafter acquire under the Anti-trust laws of the United States and the State of FL for price fixing relating to the particular commodities or services purchased or acquired by the City of Naples. At the City's discretion, such assignment shall be made and become effective at the time the City tenders final payment to the bidder.</p> <p style="text-align: center;">FEI/EIN Number _____</p>		
AUTHORIZED SIGNATURE	DATE	PRINTED NAME/TITLE
<small>Please initial by all that apply</small> <small>I acknowledge receipt / review of the following addendum</small> ____Addendum #1 ____Addendum #2 ____Addendum #3 ____Addendum #4		

PLEASE NOTE THE FOLLOWING:

- > **This page must be completed and returned with your bid.**
- > **Bids must be submitted in a sealed envelope, marked with bid number & closing date.**
- > **Bids received after the above closing date and time will not be accepted.**
- > **If you do not have an email address and you want a copy of the Bid Tab, please enclose a stamped, self-addressed envelope with your bid.**

GENERAL CONDITIONS

TO INSURE ACCEPTANCE OF THE BID, PLEASE FOLLOW THESE INSTRUCTIONS. ANY AND ALL SPECIAL CONDITIONS, ATTACHED HERETO, HAVE PRECEDENCE.

- 1. SEALED BID:** All bids must be submitted in a sealed envelope. The face of the envelope shall contain the bid name and bid number. Bids not submitted on attached bid form shall be rejected. All bids are subject to the conditions specified herein. Those which do not comply with these conditions are subject to rejection.
- 2. EXECUTION OF BID:** Bid must contain a manual signature of authorized representative in the proposal section. Bid must be typed or printed in ink. Use of erasable ink is not permitted. All corrections made by bidder to his bid must be initialed.
- 3. NO BID:** If not submitting a bid, respond by returning the Statement of No Bid and explain the reason in the spaces provided. Failure to respond 3 times in succession without justification shall be cause for removal of the supplier's name from the bid mailing list. NOTE: To qualify as a respondent, bidder must submit a "NO BID," and it must be received no later than the stated bid opening date and hour.
- 4. BID OPENING:** Shall be public, on the date and at the time specified on the bid form. It is the bidder's responsibility to assure that his bid is delivered at the proper time and place of the bid opening. Bids which for any reason are not so delivered will not be considered. Offers by telegram, telephone; or fax are not acceptable. Bid files may be examined during normal working hours.
- 5. WITHDRAWAL OF BIDS:** Withdrawal of a bid within sixty (60) days after the opening of bids is subject to suspension or debarment in accordance with Section 2-668 of the City Code for up to three years.
- 6. PRICES, TERMS and PAYMENT:** Firm Prices include all packing, handling, shipping charges and delivery to the destination shown herein. Bidder is encouraged to offer cash discount for prompt invoice payment. Terms of less than 20 days will not be considered.

 - A. TAXES:** The City of Naples does not pay Federal Excise and Sales taxes on direct purchases of tangible personal property. See exemption number on face of purchase order. This exemption does not apply to purchases of tangible personal property made by contractors who use the tangible personal property in the performance of contracts for the improvement of City-owned real property.
 - B. MISTAKES:** Bidders are expected to examine the specifications, delivery schedule, bid prices, extensions, and all instructions pertaining to supplies and services. Failure to do so will be at bidder's risk. In case of mistake in extension, the unit price will govern.
 - C. CONDITION AND PACKAGING:** It is understood and agreed that any item offered or shipped as a result of this bid shall be a new, current standard production model available at the time of this bid. All containers shall be suitable for storage or shipment, and all prices shall include standard commercial packaging.
 - D. SAFETY STANDARDS:** Unless otherwise stipulated in the bid, all manufactured items and fabricated assemblies shall comply with applicable requirements of Occupational Safety and Health Act and any standards there under.
 - E. UNDERWRITERS' LABORATORIES:** Unless otherwise stipulated in the bid, all manufactured items and fabricated assemblies shall carry U.L. approval and re-examination listing where such has been established.
 - F. PAYMENT:** Payment will be made by the buyer after the items awarded to a vendor have been received, inspected, and found to comply with award specifications, free of damage or defect and properly invoiced. All invoices shall bear the purchase order number. Payment for partial shipments shall not be made unless specified in the bid. Failure to follow these instructions may result in delay in processing invoices for payment. In addition, the purchase order number must appear on bills of lading, packages, cases, delivery lists and correspondence.
- 7. DELIVERY:** Unless actual date of delivery is specified (or if specified delivery cannot be met), show number of days required to make delivery after receipt of purchase order in space provided. Delivery time may become a basis for making an award (see Special Conditions). Delivery shall be within the normal working hours of the user, Monday through Friday, unless otherwise specified.

8. MANUFACTURERS' NAMES AND APPROVED EQUIVALENTS: Any manufacturers' names, trade names, brand names, information and/or catalog numbers listed in a specification are for information and not intended to limit competition. The bidder may offer any brand for which he is an authorized representative, which meets or exceeds the specification for any item(s). If bids are based on equivalent products, indicate on the bid form the manufacturer's name and number. Bidder shall submit with his proposal, cuts, sketches, and descriptive literature, and/or complete specifications. Reference to literature submitted with a previous bid will not satisfy this provision. The bidder shall also explain in detail the reason(s) why the proposed equivalent will meet the specifications and not be considered an exception thereto. Bids which do not comply with these requirements are subject to rejection. Bids lacking any written indication of intent to quote an alternate brand will be received and considered in complete compliance with the specifications as listed on the bid form.

9. INTERPRETATIONS: Any questions concerning conditions and specifications shall be directed in writing to this office for receipt no later than ten (10) days prior to the bid opening. Inquiries must reference the date of bid opening and bid number. Failure to comply with this condition will result in bidder waiving his right to dispute the bid.

10. CONFLICT OF INTEREST: All bid awards are subject to Section 2-973 Conflict of Interest, City of Naples Code of Ordinances, which states: *"No public officer or employee shall have or hold any employment or contractual relationship with any business entity or any agency which is subject to the regulation of or is doing business with the city; nor shall an officer or employee have or hold any employment or contractual relationship that will create a continuing or frequently recurring conflict between his private interests and the performance of his public duties or that would impede the full and faithful discharge of his public duties. Any member of the city council or any city officer or employee who willfully violates this section shall be guilty of malfeasance in office or position and shall forfeit his office or position. Violation of this section with the knowledge, express or implied, of the person or corporation contracting with or making a sale to the city shall render the contract or sale voidable by the city manager or the city council."*

11. AWARDS: As the best interest of the City may require, the right is reserved to make award(s) by individual item, group of items, all or none, or a combination thereof; to reject any and all bids or waive any minor irregularity or technicality in bids received.

12. ADDITIONAL QUANTITIES: For a period not exceeding ninety (90) days from the date of acceptance of this offer by the buyer, the right is reserved to acquire additional quantities up to but not exceeding those shown on bid at the prices bid in this invitation. If additional quantities are not acceptable, the bid sheets must be noted "BID IS FOR SPECIFIED QUANTITY ONLY." (THIS PARAGRAPH DOES NOT APPLY FOR A TERM CONTRACT.)

13. SERVICE AND WARRANTY: Unless otherwise specified, the bidder shall define any warranty service and replacements that will be provided during and subsequent to this contract. Bidders must explain on an attached sheet to what extent warranty and service facilities are provided.

14. SAMPLES: Samples of items, when called for, must be furnished free of expense, on or before bid opening time and date, and if not destroyed may, upon request, be returned at the bidder's expense. Each individual sample must be labeled with bidder's name, manufacturer's brand name and number, bid number and item reference. Request for return of samples shall be accompanied by instructions which include shipping authorization and name of carrier and must be received with your bid. If instructions are not received within this time, the commodities shall be disposed of by the City of Naples.

15. BID PROTEST: The city has formal bid protest procedures that are available on request.

16. INSPECTION, ACCEPTANCE AND TITLE: Inspection and acceptance will be at destination unless otherwise provided. Title and risk of loss or damage to all items shall be the responsibility of the contract supplier until accepted by the ordering agency, unless loss or damage results from negligence by the ordering

17. DISPUTES: In case of any doubt or difference of opinion as to the items to be furnished hereunder, the decision of the buyer shall be final and binding on both parties.

18. GOVERNMENTAL RESTRICTIONS: In the event any governmental restrictions may be imposed which would necessitate alteration of the material, quality, workmanship or performance of the items offered on this proposal prior to their delivery, it shall be the responsibility of the successful bidder to notify the buyer at once, indicating in his letter the specific regulation which required an alteration. The City reserves the right to accept any such alteration, including any price adjustments occasioned thereby, or to cancel the contract at no expense to the City.

19. LEGAL REQUIREMENTS: Applicable provision of all Federal, State, county and local laws, and of all ordinances, rules, and regulations shall govern development submittal and evaluation of all bids received in response hereto and shall govern any and all claims and disputes which may arise between person(s) submitting a bid response hereto and the City of Naples by and through its officers, employees and authorized representatives, or any other person, natural or otherwise; and lack of knowledge by any bidder shall not constitute a cognizable defense against the legal effect thereof.

20. PATENTS AND ROYALTIES: The bidder, without exception, shall indemnify and save harmless the City of Naples and its employees from liability of any nature or kind, including cost and expenses for or on account of any copyrighted, patented, or unpatented invention, process, or article manufactured or used in the performance of the contract, including its use by the City of Naples. If the bidder uses any design, device, or materials covered by letters, patent or copyright, it is mutually agreed and understood without exception that the bid prices shall include all royalties or cost arising from the use of such design, device, or materials in any way involved in the work.

21. ADVERTISING: In submitting a bid, bidder agrees not to use the results there from as a part of any commercial advertising.

22. ASSIGNMENT: Any Purchase Order issued pursuant to this bid invitation and the monies which may become due hereunder are not assignable except with the prior written approval of the buyer.

23. LIABILITY: The supplier shall hold and save the City of Naples, its officers, agents, and employees harmless from liability of any kind in the performance of this contract.

24. PUBLIC ENTITY CRIMES: A person or affiliate who has been placed on the convicted vendor list following a conviction for a public entity crime may not submit a bid on a contract to provide any goods or services to a public entity, may not submit a bid on a contract with a public entity for the construction or repair of a public building or public work, may not submit bids on leases of real property to a public entity, may not be awarded or perform work as a contractor, supplier, subcontractor, or consultant under a contract with any public entity, and may not transact business with any public entity in excess of the threshold amount provided in Section 287.017, for CATEGORY TWO for a period of 36 months from the date of being placed on the convicted vendor list.

25. DISCRIMINATION: An entity or affiliate who has been placed on the discriminatory vendor list may not submit a bid on a contract to provide goods or services to a public entity, may not submit a bid on a contract with a public entity for the construction or repair of a public building or public work, may not submit bids on leases of real property to a public entity, may not award or perform work as a contractor, supplier, subcontractor, or consultant under contract with any public entity, and may not transact business with any public entity.

26. COUNTY TAXES: No proposal shall be accepted from and no contract will be awarded to any person, firm or corporation that is in arrears to the government of Collier County, Florida.

27. OFFER EXTENDED TO OTHER GOVERNMENTAL ENTITIES: The City of Naples encourages and agrees to the successful bidder/proposer extending the pricing, terms and conditions of this solicitation or resultant contract to other governmental entities at the discretion of the successful bidder/proposer.

IF THIS BID IS FOR A TERM CONTRACT, THE FOLLOWING CONDITIONS SHALL ALSO APPLY

28. ELIGIBLE USERS: All departments of the City of Naples are eligible to use this term contract. Such purchases shall be exempt from the competitive bid requirements otherwise applying to their purchases.

29. PRICE ADJUSTMENTS: Any price decrease effectuated during the contract period by reason of market change shall be passed on to City of Naples. Price increases are not acceptable.

30. CANCELLATION: All contract obligations shall prevail for at least one hundred eighty (180) days after effective date of contract. After that period, for the protection of both parties, this contract may be cancelled in whole or in part by either party by giving thirty (30) days prior written notice to the other party.

31. RENEWAL: The City of Naples reserves the option to renew the period of this contract, or any portion thereof for up to two (2) additional periods. Renewal of the contract period shall be by mutual agreement in writing.

32. ABNORMAL QUANTITIES: While it is not anticipated, should any unusual or abnormal requirements arise, the City reserves the right to solicit separate bids thereon.

33. FISCAL NON-FUNDING CLAUSE: In the event sufficient funds are not budgeted for a new fiscal period, the City shall notify the contractor of such occurrence and the contract shall terminate on the last day of the current fiscal year without penalty or expense to the City.

IF THIS BID IS FOR PERFORMING A SERVICE, THE FOLLOWING CONDITIONS SHALL ALSO APPLY

34. ALTERNATIVE BIDS: Bidders offering service delivery methods other than those permitted by the scope of work may submit a separate envelope clearly marked "ALTERNATIVE BID". Alternative bids will be deemed non-responsive and will not be considered for award. All such responses will, however, be examined prior to award. Such examination may result in cancellation of all bids received to permit rewriting the scope of work to include the alternative method, or the alternative method may be considered for future requirements of the City of Naples.

35. ANTITRUST: By entering into a contract, the contractor conveys, sells, assigns and transfers to the City of Naples all rights, titles and interest it may now have or hereafter acquire under the antitrust laws of the United States and the State of Florida that relate to the particular goods or services purchased or acquired by the City of Naples under said contract.

36. BIDDER INVESTIGATIONS: Before submitting a bid, each bidder shall make all investigations and examinations necessary to ascertain all site conditions and requirements affecting the full performance of the contract and to verify any representations made by the City of Naples upon which the bidder will rely. If the bidder receives an award as a result of its bid submission, failure to have made such investigations and examinations will in no way relieve the bidder from its obligation to comply in every detail with all provisions and requirements of the contract documents, nor will a plea of ignorance of such conditions and requirements be accepted as a basis for any claim whatsoever by the contractor for additional compensation.

37. CERTIFICATES AND LICENSES: The Contractor, at time of proposal, shall possess the correct occupational licenses, all professional licenses or other authorizations necessary to carry out and perform the work required by the City of Naples and Collier County for this project pursuant to all applicable Federal, State and Local Laws, Statutes, Ordinances, and rules and regulations of any kind.

38. CHANGE IN SCOPE OF WORK: The City of Naples may order changes in the work consisting of additions, deletions or other revisions within the general scope of the contract. No claims may be made by the contractor that the scope of the project or of the contractor's services has been changed, requiring changes to the amount of compensation to the contractor or other adjustments to the contract unless such changes or adjustments have been made by written amendment to the contract signed by the City of Naples and the contractor. If the contractor believes that any particular work is not within the scope of the project, is a material change, or will otherwise require more compensation to the contractor, the contractor must immediately notify the City in writing of this belief. If the City believes that the particular work is within the scope of the contract as written, the contractor will be ordered to and shall continue with the work as changed and at the cost stated for the work within the scope.

39. CONTRACTOR PERSONNEL: The City of Naples shall, throughout the life of the contract, have the right of reasonable rejection and approval of staff or subcontractors assigned to the work by the contractor. If the City

reasonably rejects staff or subcontractors, the contractor must provide replacement staff or subcontractors satisfactory to the City in a timely manner and at no additional cost to the City. The day-to-day supervision and control of the contractor's employees and sub-contractors is the responsibility solely of the contractor.

40. COST REIMBURSEMENT: The contractor agrees that all incidental costs, including allowances for profit and tools of the trade, must be included in the bid proposal rates. If an arrangement is made between the contractor and the City to reimburse the contractor for the cost of materials provided in the performance of the work, the contractor shall be reimbursed in the following manner: The City shall reimburse the contractor on completion and acceptance of each assigned job, only for those materials actually used in the performance of the work that is supported by invoices issued by the suppliers of the contractor describing the quantity and cost of the materials purchased. No surcharge shall be added to the supplier's invoices or included in the contractor's invoice submitted to the City that would increase the dollar amount indicated on the supplier's invoice for the materials purchased for the assigned job.

41. EXCEPTIONS: Bidders taking exception to any part or section of the solicitation shall indicate such exceptions on the bid form. Failure to indicate any exception will be interpreted as the bidder's intent to comply fully with the requirements as written. Conditional or qualified bids, unless specifically allowed, shall be subject to rejection in whole or in part.

42. FAILURE TO DELIVER: In the event of the contractor to fail to deliver services in accordance with the contract terms and conditions, the City, after due oral or written notice, may procure the services from other sources and hold the contractor responsible for any resulting purchase and administrative costs. This remedy shall be in addition to any other remedies that the City may have.

43. FAILURE TO ENFORCE: Failure by the City at any time to enforce the provisions of the contract shall not be construed as a waiver of any such provisions. Such failure to enforce shall not affect the validity of the contract or any part thereof or the right of the City to enforce any provision at any time in accordance with its terms.

44. FORCE MAJEURE: The contractor shall not be held responsible for failure to perform the duties and responsibilities imposed by the contract due to legal strikes, fires, riots, rebellions and acts of God beyond the control of the contractor, unless otherwise specified in the contract.

45. INDEPENDENT CONTRACTOR: The contractor shall be legally considered an independent contractor and neither the contractor nor its employees shall, under any circumstances, be considered servants or agents of the City of Naples and the City of Naples shall be at no time legally responsible for any negligence or any wrongdoing by the contractor, its servants or agents. The City of Naples shall not withhold from the contract payments to the contractor any federal income taxes, Social Security tax, or any other amounts for benefits to the contractor. Further, the City shall not provide to the contractor any insurance coverage or other benefits, including Workers' Compensation normally provided by the City for its employees.

46. ORAL STATEMENTS: No oral statement of any person shall modify or otherwise affect the terms, conditions or specifications stated in this contract. All modifications to the contract must be made in writing by the City of Naples.

47. QUALIFICATIONS OF BIDDERS: The bidder may be required, before the award of any contract, to show to the complete satisfaction of the City of Naples that it has the necessary facilities, ability, and financial resources to provide the service specified therein in a satisfactory manner. The bidder may also be required to give a past history and references in order to satisfy the City in regard to the bidder's qualifications. The City may make reasonable investigations deemed necessary and proper to determine the ability of the bidder to perform the work, and the bidder shall furnish to the City all information for this purpose that may be requested. The City reserves the right to reject any bid if the evidence submitted by, or investigation of, the bidder fails to satisfy the City that the bidder is properly qualified to carry out the obligations of the contract and to complete the work described therein. Evaluation of the bidder's qualifications shall include:

- > The ability, capacity, skill and financial resources to perform the work or service.
- > The ability to perform the work service promptly or within the time specified, without delay.
- > The character, integrity, reputation, judgment, experience, and efficiency of the bidder.

> The quality of performance of previous contracts or services.

48. QUALITY CONTROL: The contractor shall institute and maintain throughout the contract period a properly documented quality control program designed to ensure that the services are provided at all times and in all respects in accordance with the contract. The program shall include providing daily supervision and conducting frequent inspections of the contractor's staff and ensuring that accurate records are maintained describing the disposition of all complaints. The records so created shall be open to inspection by the City.

49. RECOVERY OF MONEY: Whenever, under the contract, any sum of money shall be recoverable from or payable by the contractor to the City, the same amount may be deducted from any sum due to the contractor under the contract or under any other contract between the contractor and the City. The rights of the City are in addition and without prejudice to any other right the City may have to claim the amount of any loss or damage suffered by the City on account of the acts or omissions of the contractor.

50. REQUIREMENTS CONTRACT: During the period of the contract, the contractor shall provide all the services described in the contract. The contractor understands and agrees that this is a requirements contract and that the City shall have no obligation to the contractor if no services are required. Any quantities that are included in the scope of work reflect the current expectations of the City for the period of the contract. The amount is only an estimate and the contractor understands and agrees that the City is under no obligation to the contractor to buy any amount of services as a result of having provided this estimate or of having any typical or measurable requirement in the past. The contractor further understands and agrees that the City may require services in excess of the estimated annual contract amount and that the quantity actually used whether in excess of, or less than, the estimated annual contract amount and that the quantity actually used shall not give rise to any claim for compensation other than the total of the unit prices in the contract for the quantity actually used.

51. TERMINATION FOR CONVENIENCE: The performance of work under the contract may be terminated by the City in whole or in part whenever the City determines that termination is in the City's best interest. Any such termination shall be effected by the delivery to the contractor of a written notice of termination of at least seven (7) days before the date of termination, specifying the extent to which performance of the work under the contract is terminated and the date upon which such termination becomes effective. After receipt of a notice of termination, except as otherwise directed, the contractor shall stop work on the date of the receipt of the notice or other date specified in the notice; place no further orders or subcontracts for materials, services or facilities except as necessary for completion of such portion of the work not terminated; terminate all vendors and subcontracts; and settle all outstanding liabilities and claims.

52. TERMINATION FOR DEFAULT: The City of Naples reserves the right to terminate the contract if the City determines that the contractor has failed to perform satisfactorily the work required, as determined by the City. In the event the City decides to terminate the contract for failure to perform satisfactorily, the City shall give to the contractor at least seven (7) days written notice before the termination takes effect. The seven-day period will begin upon the mailing of notice by the City. If the contractor fails to cure the default within the seven (7) days specified in the notice and the contract is terminated for failure to perform satisfactorily, the contractor shall be entitled to receive compensation for all reasonable, allocable and allowable contract services satisfactorily performed by the contractor up to the date of termination that were accepted by the City prior to the termination. In the event the City terminates the contract because of the default of the contractor, the contractor shall be liable for all excess costs that the City is required to expend to complete the work under contract.

53. STATE AND FEDERAL EMPLOYMENT LAWS: Contractors providing service to the City are required to comply with all state and federal employment laws. This includes, but is not limited to, laws resulting from the Immigration and Reform and Control Act of 1986, wherein all employers are required to verify the identity and employment eligibility of all employees. The Department of Homeland Security, U.S. Citizenship and Immigration Services require employees and employers to complete Form I-9 and the employer must examine evidence of identity and employment eligibility within three business days of the date employment begins. Non compliant contractors will be subject to contract sanctions, up to and including contract termination.

54. CERTIFICATION REGARDING DEBARMENT, SUSPENSION, INELIGIBILITY, AND VOLUNTARY EXCLUSION: The contractor agrees to comply with Executive Order 12549 "Debarment and

Suspension” and 2 CFR 180 “OMB Guidelines to Agencies on Government wide Debarment and Suspension.” These rules require all contractors using federal funds not be debarred or suspended from doing business with the Federal Government. This includes sub-recipients and lower tier participant for covered transactions. Signing and submitting this document certified the organization and its principals are not presently debarred, suspended, proposed for debarment, declared ineligible, or voluntarily excluded from participation in this transaction by any federal department or agency, and further have not within the preceding three-year period been convicted of or had a civil judgment rendered against them for commission of fraud or a criminal offense in connection with obtaining, attempting to obtain, or performing a public (Federal, State or local) transaction .

THE CITY OF NAPLES IS AN EQUAL OPPORTUNITY EMPLOYER

GENERAL INSURANCE REQUIREMENTS

The Contractor shall not commence work until he has obtained all the insurance required under this heading, and until such insurance has been approved by the Owner, nor shall the Contractor allow any subcontractor to commence work until all similar insurance required of the subcontractor has also been obtained and approved by the Owner.

Certificates of insurance must be issued by an authorized representative of the insurance company at the request and direction of the policyholder and must include sufficient information so as to identify the coverage and the contract for Owner's improvements for which they are issued. Certificates of insurance must be issued by a nationally recognized insurance company with a Best's Rating of no less than B+VII, satisfactory to the Owner, and duly licensed to do business in the state of said Contract.

The Contractor shall procure and maintain, during the life of this Contract, Worker's Compensation Insurance for all of his employees to be engaged in work under this Contract, and he shall require any subcontractor similarly to provide Worker's Compensation Insurance for all of the latter's employees to be engaged in such work, unless such employees are covered by the protection afforded by the Contractor's insurance. In case any employees are to be engaged in hazardous work under this Contract, and are not protected under this Worker's Compensation statute, the Contractor shall provide, and shall cause each subcontractor to provide, adequate coverage for the protection of such employees. It is acceptable to use a State-approved Worker's Compensation Self-Insurance fund.

The Contractor shall take out and maintain during the life of this Contract, Public Liability and Property Damage and shall include Contractual Liability, Personal Injury, Libel, Slander, False Arrest, Malicious Prosecution, Wrongful Entry or Eviction, Broad Form Property Damage, Products, Completed Operations and XCU Coverage to be included on an occurrence basis, and to the full extent of the Contract to protect him, the Owner, and any subcontractor performing work covered by this Contract from damages for personal injury, including accidental death, as well as from claims for property damage, which may arise from operations under this contract, whether such operations be by himself or by a subcontractor, or by anyone directly or indirectly employed by either of them. The Contractor shall also maintain automobile liability insurance including "non-owned and hired" coverage. The entire cost of this insurance shall be borne by the Contractor.

The amount of such insurance shall be no less than \$1,000,000 annual aggregate for bodily injury and property damage combined per occurrence.

The City of Naples must be named as Additional Insured on the insurance certificate and the following must also be stated on the certificate. "This coverage is primary to all other coverage the City possesses for this contract only." The City of Naples shall be named as the Certificate Holder. The Certificate Holder shall read as follows:

The City of Naples
735 Eighth Street South
Naples, Florida 34102

No City Division, Department, or individual name should appear on the Certificate.

No other format will be acceptable.

The Certificate must state the proposal number and title.

When using the "Accord"- 25 Certificate of Insurance only the most current version will be accepted.

The City of Naples requires a copy of a cancellation notice in the event the policy is cancelled. The City of Naples shall be expressly endorsed onto the policy as a cancellation notice recipient.

STATEMENT OF NO BID

If you will not be bidding on this product/service, please help us by completing and returning only this page to:

City of Naples, Purchasing Division
City Hall, 735 8th Street South
Naples, FL 34102
Fax 239-213-7105

Bid # _____ and Description: _____

We, the undersigned, decline to proposal on the above project for the following reason(s):

- ___ We are not able to respond to the Invitation to Bid or Request for Proposals by the specified deadline.
- ___ Our Company does not offer this product or service.
- ___ Our current work schedule will not permit us to perform the required services.
- ___ Specifications are incomplete or information is unclear
(Please explain below).

___ Other (Please specify below)

Company Name _____ PH _____

Email _____

Name and Title of individual completing this form:

(Printed Name) (Title)

(Signature) (Date)

REFERENCES

THIS SHEET MUST BE COMPLETED AND RETURNED WITH BID

PROVIDE AT LEAST THREE REFERENCES FOR WHOM YOUR COMPANY HAS PROVIDED SAME OR SIMILAR SERVICES WITHIN THE LAST 2 YEARS.

COMPANY NAME: _____

ADDRESS: _____

TELEPHONE: _____

CONTACT PERSON: _____

CONTACT E-MAIL ADDRESS: _____

COMPANY NAME: _____

ADDRESS: _____

TELEPHONE: _____

CONTACT PERSON: _____

CONTACT E-MAIL ADDRESS: _____

COMPANY NAME: _____

ADDRESS: _____

TELEPHONE: _____

CONTACT PERSON: _____

CONTACT E-MAIL ADDRESS: _____

CONSTRUCTION
SPECIAL CONDITIONS

A. **TERMS OF CONTRACT**

The resulting contract will commence on award and be in effect until completion of the project.

B. **PROHIBITION OF CONTACT**

Under no circumstances should any prospective organization or individual, or anyone acting for or on behalf of a prospective organization or individual, seek to influence or gain the support of any member of the City Council, public official or City staff favorable to the interest of any prospective organization or individual. Likewise, contact with City Council, any public official or city staff against the interests of other prospective organization (s) and or individual(s) is prohibited. Any such activities will result in the exclusion of the prospective organization or individual from consideration by the City.

C. **REFERENCES**

Bidder must submit a minimum of three references on the form provided. Additionally, a signed and dated IRS W-9 form with EIN is required from all vendors.

D. **STATEMENT OF NO BID**

If you will not be bidding on this producer/service, please help us by completing and returning the Statement of No Bid.

E. **BID FORMAT**

The Contract, if awarded, will be awarded on the basis of material and equipment illustrated and described on the Drawings or specified in the Specification. If a substitution or an "or equal" item is proposed, Proposer must submit this information to the City of Naples Purchasing Department ten (10) days prior to the Proposal Date for evaluation as an acceptable substitution or an "or equal" item. If the substitution or the "or equal" item is accepted, the City of Naples will issue an Addendum to all Proposers listing the allowable substitution or the "or equal" item. The cost of changes in related work, additional drawings which may be required to illustrate or define the substitute or "or equal" equipment and its relationship to the other parts or portions of the Work shall be paid by the Contractor. No change will be made in the amount of time in which to complete the Work or in the liquidated damages.

F. **BID SECURITY / BID BOND**

It is the policy of the City of Naples to require a Bid Bond for all construction-related sealed bids estimated to be in excess of \$125,000. A bid bond or equivalent financial security in the amount of five (5) percent of the bid price shall be required and must accompany all bids. The Bid Bond is to be provided by a surety company authorized to do business in the State of Florida or otherwise supplied in a form satisfactory to the City. The bid bond must be submitted with the bid. When the invitation for bids requires a bid bond, noncompliance will result in rejection of the bid.

Note that failure or refusal of the awarded bidder to enter into a contract within twenty (20) calendar days after receipt of said contract will result in damages to the City and bid bond will be forfeited to the City as liquidated damages.

G. **PROPOSAL CONSTRUCTION PERFORMANCE & PAYMENT BONDS**

A Performance and Payment Bond will be required of the Awarded Proposer for any contract that is in excess of \$125,000.00 dollars and will be in an amount equal to 100 (%) percent of the price specified in the Contract.

The bond(s) shall be executed by a surety company authorized to do business in the State of Florida, or otherwise secured in a manner satisfactory to the City for the protection of all persons supplying labor and material to the contractor or its subcontractors for the performance of the work provided for in the contract.

Proof of insurance from the successful proposer is required at the time of issuance and award of a contract.

H. QUESTIONS

Questions regarding this proposer packet must be received in writing in the Purchasing Division, NO LATER THAN TEN CALENDAR DAYS PRIOR TO THE PROPOSAL CLOSING DATE TO ENSURE AN ANSWER IS PROVIDED PRIOR TO CLOSING.

Direct all questions to:
Gerald "Jed" Secory, MBA / CPPO / CPM
Purchasing Manager
City of Naples, Purchasing Division
735 8th Street South
Naples, Florida 34102
PH: (239) 213-7102 FX: (239) 213-7105
Jsecory@naplesgov.com

SUBMISSION CHECKLIST

Bidder should check off each of the following items as completed and submit with bid response:

CHECKLIST ELEMENTS	INCLUDED
<ul style="list-style-type: none"> Submit one (1) original signature and one (1) copy of your original bid proposal / document AND a Windows© compatible PDF of the original document on a CD that is clearly labeled. 	
<ul style="list-style-type: none"> Include any required drawings; descriptive literature; qualifications; schedules; product compliance / exceptions; alternatives; questionnaire; references, forms, tabs, pricing/cost; and any information required of the proposer identified in the text of the bid including information for bid evaluation. 	
<ul style="list-style-type: none"> Include any delivery information. 	
<ul style="list-style-type: none"> Mandatory FORMS from this document to be included are: <u>Cover Sheet</u>, <u>References Sheet</u>, <u>Submission Checklist Sheet</u>, and <u>Cost / Bid Schedule</u>. Also include a current W-9 for your firm. 	
<ul style="list-style-type: none"> Have an authorized individual sign the appropriate pages including the <u>Cover Sheet</u> with any bid addendums initialed. Also, examples of vendor contracts used by the City can be found on the Naples Purchasing web site and should be reviewed by the vendor. 	
<ul style="list-style-type: none"> Bid proposal / document needs to be received by the OPENING DATE & TIME indicated on the Cover Sheet. The mailing envelope must be addressed to: <div style="text-align: center;"> City of Naples Purchasing Division 735 8th Street South Naples, Florida 34102 </div> 	
<p style="text-align: center;">The mailing envelope should be sealed and marked with: BID Number: BID Title: BID Opening Date:</p>	

ALL COURIER DELIVERED PROPOSALS MUST HAVE THE BID NUMBER AND TITLE ON THE OUTSIDE OF THE COURIER PACKET.

At the discretion of the Purchasing Manager, bids or proposals with minor irregularities may be accepted and allowed to be corrected when in the best interest of the City.

DIVISION 1 - GENERAL REQUIREMENTS

01000	Project Requirements
01010	Project Summary
01340	Shop Drawings
01600	Materials and Equipment
01720	Record Documents
01730	Operating and Maintenance Manuals

DIVISION 13 INSTRUMENTATION

13410	Basic Instrumentation Requirements
13413	Optical Fiber Cabling Systems
13421	Flow Measurement
13428	Analytical Instrumentation
13430	Control Panels and Consoles

DIVISION 14 (NOT USED)

DIVISION 15 - MECHANICAL

15000	Mechanical General Requirements
-------	---------------------------------

DIVISION 16 – ELECTRICAL

16050	Basic Electrical Requirements
16060	Grounding
16070	Supporting Devices
16075	Electrical Identification
16120	Wires and Cables
16130	Raceways
16135	Cabinets, Boxes and Fitting
16270	Transformers
16410	Circuit and Motor Disconnects
16440	Panel Boards
16748	Software Services

SECTION 01000

PROJECT REQUIREMENTS

PART 1 - GENERAL

1.01 DESCRIPTION

- A. Scope of Work: The Work to be done consists of the furnishing of all labor, materials, and equipment, and the performance of all Work included in this Contract. The summary of the Work is presented in Section 01010: Summary of Project.

- B. Work Included:
 - 1. The Contractor shall furnish all labor, superintendence, materials, plant power, light, heat, fuel, water, tools, appliances, equipment, supplies, and means of construction necessary for proper performance and completion of the Work. The Contractor shall obtain and pay for all necessary local building permits. The Contractor shall perform and complete the Work in the manner best calculated to promote rapid construction consistent with safety of life and property and to the satisfaction of the Engineer, and in strict accordance with the Contract Documents. The Contractor shall clean up the Work and maintain it during and after construction, until accepted, and shall do all Work and pay all costs incidental thereto. He shall repair or restore all structures and property that may be damaged or disturbed during performance of the Work.

 - 2. The cost of incidental work described in these Project Requirements, for which there are no specific Contract Items, shall be considered as part of the general cost of doing the Work and shall be included in the prices for the various Contract Items. No additional payment will be made therefore.

 - 3. The Contractor shall provide and maintain such modern plant, tools, and equipment as may be necessary, in the opinion of the Engineer, to perform in a satisfactory and acceptable manner all the Work required by this Contract. Only equipment of established reputation and proven efficiency shall be used. The Contractor shall be solely responsible for the adequacy of his workmanship, materials, and equipment, prior approval of the Engineer notwithstanding.

C. Public Utility Installations and Structures:

1. Public utility installations and structures shall be understood to include all poles, tracks, pipes, wires, conduits, vaults, manholes, and all other appurtenances and facilities pertaining thereto whether owned or controlled by the Owner, other governmental bodies, or privately owned by individuals, firms, or corporations, used to serve the public with transportation, traffic control, gas, electricity, telephone, sewerage, drainage, water, or other public or private property which may be affected by the Work shall be deemed included hereunder.
2. The Contract Documents contain data relative to existing public utility installations and structures above and below the ground surface. These data are not guaranteed as to their completeness or accuracy and it is the responsibility of the Contractor to make his own investigations to inform himself fully of the character, condition, and extent of all such installations and structures as may be encountered and as may affect the construction operations.
3. The Contractor shall protect all public utility installations and structures from damage during the Work. Access across any buried public utility installation or structure shall be made to avoid any damage to these facilities. All required protective devices and construction shall be provided by the Contractor at his expense. All existing public utilities damaged by the Contractor shall be repaired by the Contractor, at his expense. No separate payment shall be made for such protection or repairs to public utility installations or structures.
4. Public utility installations or structures owned or controlled by the Owner or other governmental body which are shown on the Drawings to be removed, relocated, replaced, or rebuilt by the Contractor shall be considered as a part of the general cost of doing the Work and shall be included in the prices bid for the various Contract Items. No separate payment shall be made therefor.
5. Where public utility installations or structures owned or controlled by the Owner or other governmental body are encountered during the course of the Work, and are not indicated on the Drawings or in the Specifications, and when, in the opinion of the Engineer, removal, relocation, replacement, or rebuilding is necessary to complete the Work under this Contract, such Work shall be accomplished by the utility having jurisdiction, or such Work may be ordered, in writing by the Engineer, for the Contractor to accomplish. If such work is accomplished by the utility having jurisdiction it will be carried out expeditiously, and the Contractor shall give full cooperation to permit the utility to complete the removal,

relocation, replacement, or rebuilding as required. If such work is accomplished by the Contractor, it will be paid for as extra work as provided in the Agreement.

6. The Contractor shall, at all times in performance of the Work, employ acceptable methods and exercise reasonable care and skill so as to avoid unnecessary delay, injury, damage, or destruction of public utility installations and structures; and shall, at all times in the performance of the Work, avoid unnecessary interference with, or interruption of, public utility services, and shall cooperate fully with the owners thereof to that end.
7. The Contractor shall give written notice to Owner and other governmental utility departments and other owners of public utilities of the location of his proposed construction operations, at least 48-hours in advance of breaking ground in any area or on any unit of the Work.
8. The maintenance, repair, removal, relocation, or rebuilding of public utility installations and structures, when accomplished by the Contractor as herein provided, shall be done by methods approved by the owners of such utilities.

1.02 DRAWINGS AND PROJECT MANUAL

- A. Drawings: When obtaining data and information from the Drawings, figures shall be used in preference to scaled dimensions, and large-scale drawings in preference to small-scale drawings.
- B. Supplementary Drawings:
 1. When, in the opinion of the Engineer, it becomes necessary to explain more fully the Work to be done or to illustrate the Work further or to show any changes which may be required, drawings known as Supplementary Drawings, with specifications pertaining thereto, will be prepared by the Engineer, and the Contractor will be furnished one (1) complete PDF File of the drawings formatted to print 11" by 17" and one (1) complete PDF File of the specifications.
 2. The Supplementary Drawings shall be binding upon the Contractor with the same force as the Contract Drawings. Where such Supplementary Drawings require either less or more than the estimated quantities of Work, credit to the Owner or compensation therefor to the Contractor shall be subject to the terms of the Agreement.

C. Contractor to Check Drawings and Data:

1. The Contractor shall verify all dimensions, quantities, and details shown on the Drawings, Supplementary Drawings, schedules, Specifications, or other data received from the Engineer, and shall notify him of all errors, omissions, conflicts, and discrepancies found therein. Failure to discover or correct errors, conflicts, or discrepancies shall not relieve the Contractor of full responsibility for unsatisfactory work, faulty construction, or improper operation resulting therefrom, nor from rectifying such conditions at his own expense. He will not be allowed to take advantage of any errors or omissions, as full instructions will be furnished by the Engineer, should such errors or omissions be discovered.
2. All schedules are given for the convenience of the Engineer and the Contractor and are not guaranteed to be complete. The Contractor shall assume all responsibility for the making of estimates of the size, kind, and quality of materials and equipment included in work to be done under the Contract.

D. Specifications: The Technical Specifications consist of three (3) parts: General, Products, and Execution. The General part of a Specification contains General Requirements which govern the Work. The Products and Execution parts modify and supplement the General Requirements by detailed requirements for the Work and shall always govern whenever there appears to be a conflict.

E. Intent:

1. All Work called for in the Specifications applicable to this Contract, but not shown on the Drawings in their present form, or vice versa, shall be of like effect as if shown or mentioned in both. Work not specified in either the Drawings or in the Specifications, but involved in carrying out their intent or in the complete and proper execution of the Work, is required and shall be performed by the Contractor as though it were specifically delineated or described.
2. The apparent silence of the Specifications as to any detail, or the apparent omission from them of a detailed description concerning any work to be done and materials to be furnished, shall be regarded as meaning that only the best general practice is to prevail and that only material and workmanship of the best quality is to be used, the interpretation of these Specifications shall be made upon that basis.

1.03 MATERIALS AND EQUIPMENT

A. Manufacturer:

1. All transactions with the manufacturers or subcontractors shall be through the Contractor, unless the Contractor shall request and at the Engineer's option, that the manufacturer or subcontractor deal directly with the Engineer. Any such transactions shall not in any way release the Contractor from his full responsibility under this Contract.
2. Any two (2) or more pieces of material or equipment of the same kind, type, or classification, and being used for identical types of service, shall be made by the same manufacturer.

B. Delivery:

1. The Contractor shall deliver materials in ample quantities to ensure the most speedy and uninterrupted progress of the Work so as to complete the Work within the allotted time.
2. The Contractor shall also coordinate deliveries in order to avoid delay in, or impediment of, the progress of the work of any related Contractor.

C. Tools and Accessories:

1. The Contractor shall, unless otherwise stated in the Contract Documents, furnish with each type, kind, or size of equipment, one (1) complete set of suitably marked high grade special tools and appliances which may be needed to adjust, operate, maintain, or repair the equipment. Such tools and appliances shall be furnished in approved painted steel cases, properly labeled and equipped with good grade cylinder locks and duplicate keys.
2. Spare parts shall be furnished as specified herein and as recommended by the manufacturer necessary for the operation of the equipment, not including materials required for routine maintenance.
3. Each piece of equipment shall be provided with a substantial nameplate, securely fastened in place and clearly inscribed with the manufacturer's name, year of manufacture, serial number, weight, and principal rate data.

D. Service of Manufacturer's Engineer:

1. The Contract Prices for equipment shall include the cost of furnishing a competent and experienced engineer or superintendent who shall represent the manufacturer and shall assist the Contractor, when required, to install,

adjust, test, and place in operation, the equipment in conformity with the Contract Documents.

2. After the equipment is placed in permanent operation by the Owner, such engineer or superintendent shall make all adjustments and tests required by the Engineer to prove that such equipment is in proper and satisfactory operating condition, and shall instruct such personnel as may be designated by the Owner in the proper operation and maintenance of such equipment.

1.04 INSPECTION AND TESTING

A. General:

1. For tests specified to be made by the Contractor, the testing personnel shall make the necessary inspections and tests, and the reports thereof shall be in such form as will facilitate checking to determine compliance with the Contract Documents. Five (5) copies of the reports shall be submitted, and authoritative certification thereof must be furnished to the Engineer as a prerequisite for the acceptance of any material or equipment.
2. If, in the making of any test of any material or equipment, it is ascertained by the Engineer that the material or equipment does not comply with the Contract Documents, the Contractor will be notified thereof, and he will be directed to refrain from delivering said material or equipment, or to remove it promptly from the site or from the Work and replace it with acceptable material, without cost to the Owner.
3. Tests of electrical and mechanical equipment and appliances shall be conducted in accordance with the recognized test codes of the ANSI, ASME, or the IEEE, except as may otherwise be stated herein.
4. The Contractor shall be fully responsible for the proper operation of equipment during testing and instruction periods and shall neither have nor make any claim for damage which may occur to equipment prior to the time when the Owner formally takes over the operation thereof.

B. Costs:

1. All inspection and testing of materials furnished under this Contract will be provided by the Contractor, unless otherwise expressly specified.
2. The cost of shop and field tests of equipment and of certain other tests specifically called for in the Contract Documents shall be borne by the

Contractor, and such costs shall be deemed to be included in the Contract Price.

3. Materials and equipment submitted by the Contractor as the equivalent to those specifically named in the Contract may be tested by the Owner for compliance. The Contractor shall reimburse the Owner for the expenditures incurred in making such tests of materials and equipment which are rejected for non-compliance.

C. Certificate of Manufacture:

1. Contractor shall furnish to Engineer authoritative evidence in the form of a certificate of manufacture that the materials to be used in the Work have been manufactured and tested in conformity with the Contract Documents.
2. These certificates shall be notarized and shall include copies of the results of physical tests and chemical analyses, where necessary, that have been made directly on the product or on similar products of the manufacturer.

D. Shop Tests:

1. Each piece of equipment for which pressure, duty, capacity, rating, efficiency, performance, function, or special requirements are specified shall be tested in the shop of the maker in a manner which shall conclusively prove that its characteristics comply fully with the requirements of the Contract Documents.
2. Five (5) copies of the manufacturer's actual test data and interpreted results thereof, accompanied by a certificate of authenticity sworn to by a responsible official of the manufacturing company and/or independent laboratory, shall be submitted to the Engineer for approval.
3. The cost of shop tests and of furnishing manufacturer's preliminary and shop test data of operating equipment shall be borne by the Contractor.

E. Start-up Tests:

1. As soon as conditions permit, the Contractor shall furnish all labor, materials, and instruments and shall make start-up tests of equipment.
2. If the start-up tests disclose any equipment furnished under this Contract which does not comply with the requirements of the Contract Documents, the Contractor shall, prior to demonstration tests, make all changes, adjustments, and replacements required. The furnishing Contractor shall assist in the start-up tests as applicable.

F. Demonstration Tests:

1. Prior to Contractor's request for a Substantial Completion inspection, all equipment and piping installed under this Contract shall be subjected to demonstration tests as specified or required to prove compliance with the Contract Documents.
2. The Contractor shall furnish labor, fuel, energy, water, and all other materials, equipment, and instruments necessary for all demonstration tests, at no additional cost to the Owner. Contractor shall assist in the demonstration tests as applicable.

1.05 LINES AND GRADES

A. Grade:

1. All work under this Contract shall be constructed in accordance with the lines and grades shown on the Drawings, or as given by the Engineer. The full responsibility for keeping alignment and grade shall rest upon the Contractor.
2. The Engineer will establish bench marks and baseline controlling points. Reference marks for lines and grades as the Work progresses will be located by the Contractor to cause as little inconvenience to the prosecution of the Work as possible. The Contractor shall so place excavation and other materials as to cause no inconvenience in the use of the reference marks provided. He shall remove any obstructions placed by him contrary to this provision.

B. Surveys:

1. The Contractor shall furnish and maintain, at his own expense, stakes and other such materials.
2. The Contractor shall check such reference marks by such means as he may deem necessary and, before using them, shall call the Engineer's attention to any inaccuracies.
3. The Contractor shall, at his own expense, establish all working or construction lines and grades as required from the reference marks set by the Engineer, and shall be solely responsible for the accuracy thereof. He shall, however, be subject to the check and review by the Engineer.

C. Safeguarding Marks:

1. The Contractor shall safeguard all points, stakes, grade marks, monuments, and bench marks made or established on the Work, bear the cost of re-establishing them if disturbed, and bear the entire expense of rectifying work improperly installed due to not maintaining or protecting or to removing without authorization such established points, stakes, and marks.
2. The Contractor shall safeguard all existing and known property corners, monuments, and marks adjacent to but not related to the Work and shall bear the cost of re-establishing them if disturbed or destroyed.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION (NOT USED)

END OF SECTION

SECTION 01010 - SUMMARY OF PROJECT

PART 1 - GENERAL

1.01 WORK COVERED BY CONTRACT DOCUMENTS

- A. This Contract is for the construction of the City of Naples, WRF Aeration Monitor and Control Instrumentation Improvement Project as shown on the Drawings and specified herein. The Work consists of furnishing all labor, equipment, and materials for the construction of the facilities consisting of, but not limited to, the following:

All work for the Project shall be constructed in accordance with the Drawings and Specifications and the proposed improvements will be awarded and constructed, if award is made, under one Contract. Bids shall be submitted for furnishing, delivering and installing all materials, equipment and services, including labor, for the Work, which generally involves:

All Monitoring Devices (DO, SS, Sludge Level, & Thermal Mass Flow), PLC, power, communications, junctions, conduits, conductors, integration, and all related and required hardware, materials, and assemblies necessary for complete and operational systems that will allow real time monitoring, tracking, and control for the Blower systems of the aeration basins and improve treatment throughout various stages of the treatment plant.

1.02 PROJECT SEQUENCE

- A. The Contractor shall establish his work sequence based on the use of crews to facilitate completion of construction and testing within the specified Contract Time(s). The proposed project sequence, including Contractor's plans for provision of temporary facilities, shall be submitted to the Engineer prior to construction.
- B. The Contractor will be required to meet the substantial and final completion dates.
1. All Work included in the Contract Documents will be substantially completed within one hundred twenty (120) days and finally complete one hundred fifty (150) days after the date when Contract Times commence to run.

PART 2 – PRODUCTS (NOT USED)

PART 3 – EXECUTION (NOT USED)

END OF SECTION

SECTION 01340

SHOP DRAWINGS

PART 1 - GENERAL

1.01 DESCRIPTION

A. Scope of Work:

1. The Contractor shall submit to the Engineer for review and approval, such Shop Drawings, Test Reports, and Product Data on materials and equipment (hereinafter in this Section called Data), and material samples (hereinafter in this Section called Samples) as are required for the proper control of work, including but not limited to those Shop Drawings, Data, and Samples for materials and equipment specified elsewhere in the Specifications and in the Drawings.
2. Within fourteen (14) calendar days after the Notice to Proceed, the Contractor shall submit to the Engineer a complete list of preliminary Data on items for which Shop Drawings are to be submitted. Included in this list shall be the names of all proposed manufacturers furnishing specified items. Review of this list by the Engineer shall in no way expressed or implied relieve the Contractor from submitting complete Shop Drawings and providing materials, equipment, etc., fully in accordance with the Contract Documents. This procedure is required in order to expedite final review of Shop Drawings.
3. The Contractor is to maintain an accurate updated submittal log and will bring this log to each scheduled progress meeting with the Owner and the Engineer. This log should include the following items:
 - a. Submittal description and number assigned.
 - b. Date to Engineer.
 - c. Date returned to Contractor (from Engineer).
 - d. Status of submittal (Approved, Approved as Noted, Amend and Resubmit, and Rejected).
 - e. Date of resubmittal and return (as applicable).
 - f. Date material release (for fabrication).

- g. Projected date of fabrication.
- h. Projected date of delivery to site.
- i. Status of O&M manuals submittal.
- j. Specification Section.
- k. Drawings sheet number.

B. Related Requirements Described Elsewhere:

- 1. Material and Equipment: Section 01600.
- 2. Project Record Documents: Section 01720.
- 3. Operating and Maintenance Data: Section 01730.

1.02 CONTRACTOR'S RESPONSIBILITY

- A. It is the responsibility of the Contractor to check all drawings, data and samples prepared before submitting them to the Engineer for review. Each and every copy of the Drawings and data shall bear the Contractor's stamp showing that they have been so checked. Shop drawings submitted to the Engineer without the Contractor's stamp will be returned to the Contractor for conformance with this requirement. Shop drawings shall indicate any deviations in the submittal from requirements of the Contract Documents. If the Contractor takes exception to the specifications, the Contractor shall note the exception in the letter of transmittal to the Engineer.
- B. Determine and verify:
 - 1. Field measurements.
 - 2. Field construction criteria
 - 3. Catalog numbers and similar data.
 - 4. Conformance with Specifications.
- C. The Contractor shall furnish the Engineer a schedule of Shop Drawing submittals fixing the respective dates for the submission of shop and working drawings, the beginning and ending of manufacture, testing, and installation of materials,

supplies, and equipment. This schedule shall indicate those that are critical to the progress schedule.

- D. The Contractor shall not begin any of the work covered by a Shop Drawing, Data, or a Sample returned for correction until a revision or correction thereof has been reviewed and returned to him, by the Engineer, with approval.
- E. The Contractor shall submit to the Engineer all drawings and schedules sufficiently in advance of construction requirements to provide no less than thirty (30) calendar days for checking and appropriate action from the time the Engineer receives them.
- F. All submittals shall be accompanied with a transmittal letter prepared in duplicate containing the following information:
 - 1. Date.
 - 2. Project Title and Number.
 - 3. Contractor's name and address.
 - 4. The number of each Shop Drawings, Project Data, and Sample submitted.
 - 5. Notification of Deviations from Contract Documents.
 - a. The Contractor shall indicate in **bold type** at the top of the cover sheet of submittal of shop drawing if there is a deviation from the Drawings, Specifications, or referenced specifications or codes.
 - b. The Contractor shall also list any deviations from the Drawings, Specifications, or referenced specifications or codes and identify in green ink prominently on the applicable Shop Drawings.
 - 6. Submittal Log Number conforming to Specification Section Number.
- G. The Contractor shall submit four (4) copies of descriptive or product data information and Shop Drawings to the Engineer plus the number of copies which the Contractor requires returned. All blueprint Shop Drawings shall be submitted with one (1) set of mylar reproducibles and the same number of prints as Shop Drawings, plus the number of copies which the Contractor requires returned. The Engineer will review the blueprints and return to the Contractor the set of marked-up mylar reproducibles with appropriate review comments.
- H. The Contractor shall be responsible for and bear all costs of damages which may result from the ordering of any material or from proceeding with any part of Work

prior to the completion of the review by the Engineer of the necessary Shop Drawings.

- I. The Contractor shall be fully responsible for observing the need for and making any changes in the arrangement of piping, connections, wiring, manner of installation, etc., which may be required by the materials/equipment he proposes to supply both as pertains to his own work and any work affected under other parts, headings, or divisions of the Drawings and Specifications.
- J. The Contractor shall not use Shop Drawings as a means of proposing alternate items to demonstrate compliance with the Drawings and Specifications.
- K. Each submittal will bear a stamp indicating that Contractor has satisfied Contractor's obligations under the Contract Documents with respect to Contractor's review and approval of that submittal as illustrated below.

(OWNER'S NAME) (PROJECT NAME) (PROJECT NUMBER)
SHOP DRAWING NO.: _____
SPECIFICATION SECTION: _____ DRAWING NO. _____
WITH RESPECT TO THIS SHOP DRAWING OR SAMPLE, I HAVE DETERMINED AND VERIFIED ALL QUANTITIES, DIMENSIONS, SPECIFIED PERFORMANCE CRITERIA, INSTALLATION REQUIREMENTS, MATERIALS, CATALOG NUMBERS, AND SIMILAR DATA WITH RESPECT THERETO AND REVIEWED OR COORDINATED THIS SHOP DRAWING OR SAMPLE WITH OTHER SHOP DRAWINGS AND SAMPLES AND WITH THE REQUIREMENTS OF THE WORK, THE CONTRACT DOCUMENTS AND EXISTING FIELD CONDITIONS.
_____ NO VARIATION FROM CONTRACT DOCUMENTS
_____ VARIATION FROM CONTRACT DOCUMENTS AS SHOWN
(CONTRACTOR'S NAME) (CONTRACTOR'S ADDRESS)
BY: _____ DATE: _____
AUTHORIZED SIGNATURE

- L. Drawings and schedules shall be checked and coordinated with the work of all trades and sub-contractors involved, before they are submitted for review by the Engineer and shall bear the Contractor's stamp of approval as evidence of such checking and coordination. Drawings or schedules submitted without this stamp of approval shall be returned to the Contractor for resubmission.

1.03 ENGINEER'S REVIEW OF SHOP DRAWINGS

- A. The Engineer's review of Shop Drawings, Data, and Samples as submitted by the Contractor will be to determine if the items(s) generally conforms to the information in the Contract Documents and is compatible with the design concept. The Engineer's review and exceptions, if any, will not constitute an approval of dimensions, connections, quantities, and details of the material, equipment, device, or item shown. Engineer will place Shop Drawings in the mail to the Contractor within 30 days of receipt.
- B. The review of drawings and schedules will be general, and shall not be construed:
 - 1. As permitting any departure from the Contract Documents.
 - 2. As relieving the Contractor of responsibility for any errors, including details, dimensions, and materials.
 - 3. As approving departures from details furnished by the Engineer, except as otherwise provided herein.
- C. If the drawings or schedules as submitted describe variations and show a departure from the Contract Documents which the Engineer finds to be in the interest of the Owner and to be so minor as not to involve a change in Contract Price or contract time, the Engineer may return the reviewed drawings without noting an exception.
- D. "Approved As Noted" - Contractor shall incorporate Engineer's comments into the submittal before release to manufacturer. The Contractor shall send a letter to the Engineer acknowledging the comments and their incorporation into the Shop Drawing.
- E. "Amend And Resubmit" - Contractor shall resubmit the Shop Drawing to the Engineer. The resubmittal shall incorporate the Engineer's comments highlighted on the Shop Drawing.
- F. "Rejected" - Contractor shall correct, revise and resubmit Shop Drawing for review by Engineer.

- G. Resubmittals will be handled in the same manner as first submittals. On resubmittals the Contractor shall direct specific attention, in writing or on resubmitted Shop Drawings, to revisions other than the corrections requested by the Engineer on previous submissions. The Contractor shall make any corrections required by the Engineer.
- H. If the Contractor considers any correction indicated on the drawings to constitute a change to the Drawings or Specifications, the Contractor shall give written notice thereof to the Engineer.
- I. When the Shop Drawings have been completed to the satisfaction of the Engineer, the Contractor shall carry out the construction in accordance therewith and shall make no further changes therein except upon written instructions from the Engineer.
- J. No partial submittals will be reviewed. Submittals not deemed complete will be stamped "Rejected" and returned to the Contractor for resubmittal. Unless otherwise specifically permitted by the Engineer, make all submittals in groups containing all associated items for:

- 1. Systems.
- 2. Processes.
- 3. As indicated in specific Specifications Sections.

All drawings, schematics, manufacturer's product Data, certifications, and other Shop Drawing submittals required by a system specification shall be submitted at one time as a package to facilitate interface review.

- K. Only the Engineer shall utilize the color "red" in marking Shop Drawing submittals.
- L. Shop drawing and submittal data shall be reviewed by the Engineer for each original submittal and first resubmittal; thereafter review time for subsequent resubmittals shall be charged to the Contractor and the Contractor shall reimburse the Owner for services rendered by the Engineer as specified in the Supplementary Conditions.

1.04 SHOP DRAWINGS

- A. When used in the Contract Documents, the term "Shop Drawing" shall be considered to mean Contractor's plans for materials and equipment which become an integral part of the Project. Shop Drawings shall be complete and detailed and shall consist of fabrication, erection, setting and schedule drawings,

manufacturer's scale drawings, and wiring and control diagrams. Catalogs cuts, catalogs, pamphlets, descriptive literature, and performance and test data shall be considered only as supportive information to required Shop Drawings as defined above. As used herein, the term "manufactured" applies to standard units usually mass-produced; and "fabricated" means items specifically assembled or made out of selected materials to meet individual design requirements.

- B. Manufacturer's catalog sheets, brochures, diagrams, illustrations, and other standard descriptive data shall be clearly marked to identify pertinent materials, products, or models. Delete information which is not applicable to the Work by striking or cross-hatching.
- C. Each Shop Drawing shall be submitted with an 8-1/2" by 11" cover sheet which shall include a title block for the submittal. Each Shop Drawing cover sheet shall have a blank area 3-1/2 inches high by 4-1/2 inches wide, located adjacent to the title block. The title block/cover sheet shall display the following:
 - 1. Project Title and Number.
 - 2. Name of project building or structure.
 - 3. Number and title of the Shop Drawing.
 - 4. Date of Shop Drawing or revision.
 - 5. Name of Contractor and subcontractor submitting drawing.
 - 6. Supplier/manufacturer.
 - 7. Separate detailer when pertinent.
 - 8. Specification title and Section number.
 - 9. Applicable Drawing number.
- D. Data on materials and equipment shall include, without limitation, materials and equipment lists, catalog data sheets, catalog cuts, performance curves, diagrams, verification of conformance with applicable standards or codes, materials of construction, and similar descriptive material. Materials and equipment lists shall give, for each item thereon, the name and location of the supplier or manufacturer, trade name, catalog reference, size, finish, and all other pertinent Data.
- E. For all mechanical and electrical equipment furnished, the Contractor shall provide a list including the equipment name, and address, and telephone number

of the manufacturer's representative and service company so that service and/or spare parts can be readily obtained.

- F. If drawings show variations from Contract requirements because of standard shop practice or for other reasons, the Contractor shall describe such variations in his letter of transmittal. If acceptable, proper adjustment in the Contract shall be implemented where appropriate. If the Contractor fails to describe such variations, he shall not be relieved of the responsibility for executing the Work in accordance with the Contract, even though such drawings have been reviewed.
- G. All manufacturers or equipment suppliers who propose to furnish equipment or products shall submit an installation list to the Engineer along with the required shop drawings. The installation list shall include at least five (5) installations where identical equipment has been installed and has been in operation for a period of at least two (2) years unless specified otherwise in the Specification Section applicable.

1.05 WORKING DRAWINGS

- A. When used in the Contract Documents, the term "Working Drawings" shall be considered to mean the Contractor's plan for temporary structures such as temporary bulkheads, support of open cut excavation, support of utilities, ground water control systems, forming and falsework for underpinning, and for such other work as may be required for construction but does not become an integral part of the Project.
- B. Copies of working drawings as noted in paragraph 1.05 A. above, shall be submitted to the Engineer where required by the Contract Documents or requested by the Engineer, and shall be submitted at least thirty (30) calendar days (unless otherwise specified by the Engineer) in advance of their being required for the Work.
- C. Working Drawings shall be signed by a registered Professional Engineer, currently licensed to practice in the State of Florida, and shall convey, or be accompanied by, calculation or other sufficient information to completely explain the structure, machine, or system described and its intended manner of use. Prior to commencing such work, working drawings must have been reviewed without specific exceptions by the Engineer, which review will be for general conformance and will not relieve the Contractor in any way from his responsibility with regard to the fulfillment of the terms of the Contract. All risks to new or existing work are assumed by the Contractor; the Owner and Engineer shall have no responsibility therefor.

1.06 SAMPLES

- A. The Contractor shall furnish, for the approval of the Engineer, samples required by the Contract Documents or requested by the Engineer. Samples shall be delivered to the Engineer as specified or directed. The Contractor shall prepay all shipping charges on samples. Materials or equipment for which samples are required shall not be used in the Work until approved by the Engineer.
- B. Samples shall be of sufficient size and quantity to clearly illustrate:
1. Functional characteristics of the product, with integrally related parts and attachment devices.
 2. Full range of color, texture, and pattern.
 3. A minimum of three (3) samples of each item shall be submitted.
- C. Each sample shall have a label indicating:
1. Name of Project.
 2. Name of Contractor and subcontractor.
 3. Material or equipment represented.
 4. Place of origin.
 5. Name of producer/supplier and brand (if any).
 6. Location in Project.
 7. Submittal and specification numbers.
- (Samples of finished materials shall have additional marking that will identify them under the finished schedules.)
- D. The Contractor shall prepare a transmittal letter and a description sheet for each shipment of samples. The description sheet shall contain the information required in Paragraphs 1.06B and C above. He shall enclose a copy of the letter and description sheet with the shipment and send a copy of the letter and description sheet to the Engineer. Approval of a sample shall be only for the characteristics or use named in such approval and shall not be construed to change or modify any Contract requirements.
- E. Approved samples not destroyed in testing shall be sent to the Engineer or stored at the site of the Work. Approved Samples of the hardware in good condition will be marked for identification and may be used in the Work. Materials and equipment incorporated in the Work shall match the approved Samples. Samples

which failed testing or were not approved will be returned to the Contractor at his expense, if so requested at time of submission.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION (NOT USED)

END OF SECTION

SECTION 01600

MATERIAL AND EQUIPMENT

PART 1 - GENERAL

1.01 DESCRIPTION

- A. Scope of Work: Material and equipment incorporated into the Work:
1. Manufactured and fabricated products:
 - a. Design, fabricate and assemble in accord with the best engineering and shop practices.
 - b. Manufacture like parts of duplicate units to standard sizes and gauges, to be interchangeable.
 - c. Two (2) or more items of the same kind shall be identical, by the same manufacturer.
 - d. Products shall be suitable for service conditions.
 - e. Equipment capacities, sizes and dimensions shown or specified shall be adhered to unless variations are specifically approved in writing.
 2. Do not use material or equipment for any purpose other than that for which it is designed or specified.

1.02 MANUFACTURER'S INSTRUCTIONS FOR INSTALLATION

- A. When Contract Documents require that installation of work shall comply with manufacturer's printed instructions, obtain and distribute copies of such instructions to parties involved in the installation, including five copies of the Engineer.
1. Maintain one (1) set of complete instructions at the job site during installation and until completion.
- B. Handle, install, connect, clean, condition and adjust products in strict accord with such instructions and in conformity with specified requirements.

1. Should job conditions or specified requirements conflict with manufacturer's instructions, consult with Engineer for further instructions.
 2. Do not proceed with work without clear instructions.
- C. Perform work in accordance with manufacturer's instructions. Do not omit any preparatory step or installation procedure unless specifically modified or exempted by Contract Documents.

1.03 TRANSPORTATION AND HANDLING

- A. Arrange deliveries of products in accordance with progress schedules, coordinate to avoid conflict with work and conditions at the site.
1. Deliver products in undamaged condition, in manufacturer's original containers or packaging, with identifying labels intact and legible.
 2. Immediately on delivery, inspect shipments to assure compliance with requirements of Contract Documents and approved submittals, and that products are properly protected and undamaged.
- B. Provide equipment and personnel to handle products by methods to prevent soiling or damage to products or packaging.

1.04 STORAGE AND PROTECTION

- A. The Contractor shall furnish a covered, weather-protected storage structure providing a clean, dry, noncorrosive environment for all mechanical equipment, valves, architectural items, electrical and instrumentation equipment, and special equipment to be incorporated into this Project. Storage of equipment shall be in strict accordance with the "instructions for storage" of each equipment supplier and manufacturer including connection of heaters, placing of storage lubricants in equipment, etc. Corroded, damaged or deteriorated equipment and parts shall be replaced before acceptance of the project. Equipment and materials not properly stored will not be included in a payment estimate.
- B. Store products in accord with manufacturer's instructions, with seals and labels intact and legible.
1. Store products subject to damage by the elements in weather-tight enclosures.
 2. Maintain temperature and humidity within the ranges required by manufacturer's instructions.

3. Store fabricated products above the ground, on blocking or skids, prevent soiling or staining. Cover products which are subject to deterioration with impervious sheet coverings, provide adequate ventilation to avoid condensation.
 4. Store loose granular materials in a well-drained area on solid surfaces to prevent mixing with foreign matter.
- C. All materials and equipment to be incorporated in the work shall be handled and stored by the Contractor before, during and after shipment in a manner to prevent warping, twisting, bending, breaking, chipping, rusting, and any injury, theft or damage of any kind whatsoever to the material or equipment.
- D. Cement, sand and lime shall be stored under a roof and off the ground and shall be kept completely dry at all times. All structural and miscellaneous steel, and reinforcing steel shall be stored off the ground or otherwise to prevent accumulations of dirt or grease, and in a position to prevent accumulations of standing water and to minimize rusting. Beams shall be stored with the webs vertical. Precast concrete beams shall be handled and stored in a manner to prevent accumulations of dirt, standing water, staining, chipping or cracking. Brick, block and similar masonry products shall be handled and stored in a manner to reduce breakage, chipping, cracking and spalling to a minimum.
- E. All materials, which, in the opinion of the Engineer, have become so damaged as to be unfit for the use intended or specified shall be promptly removed from the site of the work, and the Contractor shall receive no compensation for the damaged material or its removal.
- F. Arrange storage in a manner to provide easy access for inspection. Make periodic inspections of stored products to assure that products are maintained under specified conditions, and free from damage or deterioration.
- G. Protection After Installation: Provide substantial coverings as necessary to protect installed products from damage from traffic and subsequent construction operations. Remove covering when no longer needed.
- H. The Contractor shall be responsible for all material, equipment and supplies sold and delivered to the Owner under this Contract until final inspection of the work and acceptance thereof by the Owner. In the event any such material, equipment and supplies are lost, stolen, damaged or destroyed prior to final inspection and acceptance, the Contractor shall replace same without additional cost to the Owner.
- I. Should the Contractor fail to take proper action on storage and handling of equipment supplied under this Contract within seven (7) days after written notice

to do so has been given, the Owner retains the right to correct all deficiencies noted in previously transmitted written notice and deduct the cost associated with these corrections from the Contractor's Contract. These costs may be comprised of expenditures for labor, equipment usage, administrative, clerical, engineering and any other costs associated with making the necessary corrections.

1.05 STORAGE AND HANDLING OF EQUIPMENT ON SITE

- A. Because of the long period allowed for construction, special attention shall be given to the storage and handling of equipment on site. As a minimum, the procedure outlined below shall be followed:
1. Materials shall not be shipped until approved by the Engineer. The intent of this requirement is to avoid unnecessary delivery of unapproved materials and to reduce on-site storage time prior to installation and/or operation. Under no circumstances shall major equipment or finish products be delivered to the site more than one month prior to installation without written authorization from the Engineer. Materials shipped to the site, or temporarily stored off-site in approved locations, shall be stored in accordance with Paragraph 1.04, herein.
 2. All equipment having moving parts such as gears, electric motors, etc. and/or instruments shall be stored in a temperature and humidity controlled building approved by the Engineer, until such time as the equipment is to be installed.
 3. All equipment shall be stored fully lubricated with oil, grease, etc. unless otherwise instructed by the manufacturer.
 4. Manufacturer's storage instructions shall be carefully studied by the Contractor and reviewed with the Engineer by him. These instructions shall be carefully followed and a written record of this kept by the Contractor.
 5. Moving parts shall be rotated a minimum of once weekly to insure proper lubrication and to avoid metal-to-metal "welding". Upon installation of the equipment, the Contractor shall start the equipment, at least half the load, once weekly for an adequate period of time to insure that the equipment does not deteriorate from lack of use.
 6. Lubricants shall be changed upon completion of installation and as frequently as required thereafter during the period between installation and acceptance. Mechanical equipment to be used in the work, if stored for longer than ninety (90) days, shall have the bearings cleaned, flushed and lubricated prior to testing and startup, at no extra cost to the Owner.

7. Prior to acceptance of the equipment, the Contractor shall have the manufacturer inspect the equipment and certify that its condition has not been detrimentally affected by the long storage period. Such certifications by the manufacturer shall be deemed to mean that the equipment is judged by the manufacturer to be in a condition equal to that of equipment that has been shipped, installed, tested and accepted in a minimum time period. As such, the manufacturer will guarantee the equipment equally in both instances. If such a certification is not given, the equipment shall be judged to be defective. It shall be removed and replaced at the Contractor's expense.

1.06 SPARE PARTS

- A. Spare parts for certain equipment provided under Division 13: Special Construction and Division 15: Mechanical have been specified in the pertinent sections of the Specifications. The Contractor shall collect and store all spare parts so required in an area to be designated by the Engineer. In addition, the Contractor shall furnish to the Engineer an inventory listing all spare parts, the equipment they are associated with, the name and address of the supplier, and the delivered cost of each item. Copies of actual invoices for each item shall be furnished with the inventory to substantiate the delivered cost.

1.07 GREASE, OIL AND FUEL

- A. All grease, oil and fuel required for testing of equipment shall be furnished with the respective equipment. The Owner shall be furnished with a year's supply of required lubricants including grease and oil of the type recommended by the manufacturer with each item of equipment supplied.
- B. The Contractor shall be responsible for changing the oil in all drives and intermediate drives of each mechanical equipment after initial break-in of the equipment, which in no event shall be any longer than three (3) weeks of operation.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION (NOT USED)

END OF SECTION

SECTION 01720
RECORD DOCUMENTS

PART 1 - GENERAL

1.01 DESCRIPTION

- A. Scope of Work: Maintain at the site for the Owner one (1) record copy of:
 - 1. Drawings.
 - 2. Specifications.
 - 3. Addenda.
 - 4. Change Orders and other modifications of the Contract.
 - 5. Engineer's Field Orders or written instructions.
 - 6. Approved Shop Drawings, Working Drawings and Samples.
 - 7. Field Test records.
- B. Related Requirements Described Elsewhere:
 - 1. Field Engineering: Section 01050.
 - 2. Shop Drawings, Working Drawings and Samples: Section 01340.

1.02 MAINTENANCE OF DOCUMENTS AND SAMPLES

- A. Store documents and samples in Contractor's field office apart from documents used for construction.
 - 1. Provide files and racks for storage of documents.
 - 2. Provide locked cabinet or secure storage space for storage of samples.
- B. File documents and samples in accordance with CSI format with section numbers as provided herein.
- C. Maintain documents in a clean, dry, legible, condition and in good order. Do not use record documents for construction purposes.

- D. Make documents and samples available at all times for inspection by the Engineer or the Owner.
- E. As a prerequisite for monthly Progress payments, the Contractor is to exhibit the currently updated "Record Documents" for review by the Engineer and Owner. Payment may be withheld if record documents are not satisfactorily maintained.

1.03 MARKING DEVICES

- A. Provide felt tip marking pens for recording information in the color code designated by the Engineer.

1.04 RECORDING

- A. Label each document "PROJECT RECORD" with a rubber stamp having one (1) inch high letters.
- B. Record information concurrently with construction progress.
 - 1. Do not conceal any work until required information is recorded.
- C. Drawings: Legibly and clearly mark, to scale, each drawing to record actual construction:
 - 1. All underground piping with elevations and dimensions. Changes to piping location. Horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements. Actual installed pipe material, class, etc.
 - 2. Location of internal utilities and appurtenances concealed in the construction, referenced to visible and accessible features of the structure.
 - 3. Field changes of dimension and detail.
 - 4. Changes made by Field Order or by Change Order.
 - 5. Details not on original Contract Drawings.
 - 6. Equipment and piping relocations.
- D. Specifications and Addenda: Legibly mark each section to record:
 - 1. Manufacturer, trade name, catalog number of Supplier of each product and item of equipment actually installed.

2. Changes made by Field Order or by Change Order.
- E. Shop Drawings (after final review and approval): Provide four (4) sets of record shop drawings within the Operation and Maintenance Manual, for each process equipment, piping, electrical system and instrumentation system (see Section 01730); and one (1) complete electronic set supplied on CD or DVD.

1.05 SUBMITTAL

- A. At Contract closeout, deliver Record Documents to the Engineer for the Owner.
- B. Accompany submittal with transmittal letter in duplicate, containing:
1. Date.
 2. Project title and number.
 3. Contractor's name and address.
 4. Title and number of each Record Document.
 5. Signature of Contractor or his authorized representative.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION (NOT USED)

END OF SECTION

SECTION 01730

OPERATING AND MAINTENANCE MANUALS

PART 1 - GENERAL

1.01 DESCRIPTION

A. Scope of Work:

1. Compile product data and related information appropriate for Owner's operation and maintenance of products furnished under Contract.
 - a. Prepare operating and maintenance data as specified in this Section and as referenced in other pertinent sections of Specifications.
2. Instruct Owner's personnel in maintenance of products and in operation of equipment and systems.

B. Related Requirements Described Elsewhere:

1. Project Record Documents: Section 01720

1.02 QUALITY ASSURANCE

A. Preparation of data shall be done by personnel:

1. Trained and experienced in maintenance and operation of described products.
2. Familiar with requirements of the Section.
3. Skilled as technical writer to the extent required to communicate essential data.
4. Skilled as draftsman competent to prepare required drawings.

1.03 FORM OF SUBMITTALS

- ###### A. Prepare data in form of an instructional manual for use by Owner's personnel.

B. Format:

1. Size: 8-1/2 inches x 11 inches.
2. Paper: 20 pound minimum, white, for typed pages.
3. Text: Manufacturer's printed data, or neatly typewritten.
4. Drawings:
 - a. Provide reinforced punched binder tab, bind in with text.
 - b. Reduce larger drawings and fold to size of text pages but not larger than 14 inches x 17 inches.
5. Provide fly-leaf for each separate product, or each piece of operating equipment.
 - a. Provide typed description of projects and major component parts of equipment.
 - b. Provide identified tabs.
6. Cover: Identify each volume with typed or printed title "OPERATING AND MAINTENANCE MANUAL". List:
 - a. Title of Project.
 - b. Identity of separate structure as applicable.
 - c. Identity of general subject matter covered in the manual.
 - d. Identity of consulting engineer for the project.
 - e. Identity of general contractor for the project.

C. Binders:

1. Commercial quality , three D-ring type binders with durable and cleanable white plastic covers. Binders shall be presentation type with clear vinyl covers on front, back and spine. Binders shall include two sheet lifters and two, horizontal inside pockets.
2. Maximum D-ring width: 2 inches.

3. When multiple binders are used, correlate the data into related consistent groupings.

1.04 CONTENT OF MANUAL

A. Each volume of the operation and maintenance manual shall include:

1. A neatly typewritten table of contents for each volume, arranged in systematic order by division, as listed within the product specifications.
2. Contractor, name of responsible principal, address and telephone number.
3. A list of each project required to be included, indexed to content of the volume.
4. List, with each project, name, address and telephone number of:
 - a. Subcontractor, manufacturer and installer name, addresses and telephone numbers.
 - b. A list of each product required to be included, indexed to content of the volume.
 - c. Identify area of responsibility of each product.
 - d. Local source of supply for parts and replacement equipment including name, address and telephone number.
5. Identify each product by product name and other identifying symbols as set forth in Contract Documents.

B. Product Design

1. Provide hydraulic and engineering design criteria for each product as it pertains to a particular unit process.
2. Provide a general description of each normal product operation as it pertains to a particular unit process.

C. Product Data:

1. Include only those sheets which are pertinent to the specific product. Hydraulic and engineering design criteria, information and procedures required for normal control, process control and performance evaluations, listing of spare parts required, maintenance and repair instructions, safety

and personnel requirements and a "trouble shooting" problem guide shall be included in the manual. References to related products, manufacturer and equipment histories, product catalogs, etc. shall not be included within the content of the operation and maintenance manual.

2. Annotate each sheet to:
 - a. Clearly identify specific product or part installed.
 - b. Clearly identify data applicable to installation.
 - c. Delete references to inapplicable information.
3. Operation and maintenance information as herein specified.
4. Record shop drawings as submitted and approved with all corrections made for each product.

D. Drawings:

1. Supplement product data with drawings as necessary to clearly illustrate:
 - a. Relations of component parts of equipment and systems.
 - b. Product assembly and disassembly for maintenance and repair procedures.
 - c. Control and flow diagrams.
 - d. Representation of manufacturer's recommended spare parts.
2. Coordinate drawings with information in Project Record Documents to assure correct illustration of completed installation.
3. Do not use Project Record Documents as maintenance drawings.

E. Written test, as required to supplement product data for the particular installation:

1. Organize in consistent format under separate headings for different procedures.
2. Provide logical sequence of instruction of each procedure.

- F. Copy of each warranty, bond and service contract issued.
 - 1. Provide information sheet for Owner's personnel, give:
 - a. Proper step-by-step procedures in the event of product failure.
 - b. Safety instructions for plant personnel in handling of failed equipment.
 - c. Instances which might affect validity of warranties or bonds.

1.05 MANUAL FOR MATERIALS AND FINISHES

- A. Submit six (6) copies of complete manual in final form.
- B. Content: for architectural products, applied materials and finishes:
 - 1. Manufacturer's data, giving full information on products.
 - a. Catalog number, size, composition.
 - b. Color and texture designations.
 - c. Information required for reordering special manufacturing products.
 - 2. Instructions for care and maintenance.
 - a. Manufacturer's recommendation for types of cleaning agents and methods.
 - b. Cautions against cleaning agents and methods which are detrimental to product.
 - c. Recommended schedule for cleaning and maintenance.
- C. Content, for moisture protection and weather-exposed products:
 - 1. Manufacturer's data, giving full information on products.
 - a. Applicable standards.
 - b. Chemical composition.
 - c. Details of installation.

2. Instructions for inspection, maintenance and repair.
- D. Additional requirements for maintenance data: Respective sections of Specifications.

1.06 MANUAL FOR EQUIPMENT AND SYSTEMS

- A. Submit six (6) copies of complete manual in final form.
- B. Provide table of contents for each unit of equipment and system.
1. List in entirety all sections pertinent to equipment operation and maintenance.
 2. Provide fly-leaf for each individual section identified by corresponding section number.
- C. Content, for each unit of equipment and system, as appropriate:
1. Description of unit and component parts.
 - a. Provide general mechanical and process descriptions, normal operating characteristics, and limiting conditions.
 - b. Performance curves, engineering data and tests as pertains to the performance requirements as listed in the respective specifications.
 - c. Complete nomenclature and commercial number of replaceable parts.
 - d. Summary of information listed on equipment and motor data plates.
 2. Operating procedures:
 - a. Start-up, break-in, routine and normal operating instructions.
 - b. Regulation, control, stopping, shut-down and emergency instructions.
 - c. Summer and winter operating instructions.

- d. Special operating instructions in the event of equipment failure or emergency situations to insure uninterrupted plant operation. Provide step-by-step instruction to initiate process alternatives.
3. Maintenance procedures:
 - a. Provide instructions for maintenance procedures during routine operations.
 - b. Provide "trouble-shooting" guide.
 - c. Disassembly, repair and reassembly.
 - d. Alignment, adjusting and checking.
 4. Servicing and lubrication schedules required, to insure maximum product performance.
 5. Manufacturer's printed operating and maintenance instructions.
 6. Description of sequence of operation by control manufacturer.
 7. Original manufacturer's parts list, illustrations, assembly drawings and diagrams required for maintenance.
 - a. Predicted life of parts subject to wear.
 - b. Items recommended to be stocked as spare parts with manufacturers part number.
 8. As-installed control diagrams by controls manufacturer.
 9. Each Contractor's coordination drawings.
 - a. As-installed color coded piping diagrams.
 10. Charts of valve tag numbers, with location and function of each valve.
 11. List of original manufacturer's spare parts, manufacturer's current prices and recommended quantities to be maintained in storage.
 12. Other data as required under respective sections of specifications.

13. Approved record shop drawings with all corrections made, and a copy of the warranty statement, checkout memo, demonstration test procedures and demonstration test certification.

D. Content, for each electric and electronic systems, as appropriate:

1. Description of system and component parts.
 - a. Function, normal operating characteristics, and limiting conditions.
 - b. Performance curves, engineering data and tests.
 - c. Complete nomenclature and commercial number of replaceable parts.
2. Circuit directories and panelboards.
 - a. Electrical service
 - b. Controls
 - c. Communications
3. As installed color coded wiring diagrams.
4. Operating procedures:
 - a. Routine and normal operating instructions.
 - b. Sequences required.
 - c. Special operating instructions.
5. Maintenance procedures:
 - a. Routine operations.
 - b. Guide to "trouble-shooting".
 - c. Disassembly, repair and reassembly.
 - d. Adjustment and checking.
6. Manufacturer's printed operating and maintenance instructions.

7. List of original manufacturer's spare parts, manufacturer's current prices, and recommended quantities to be maintained in storage.
 8. Other data as required under pertinent sections of specifications.
- E. Prepare and include additional data when the need for such data becomes apparent during instruction of Owner's personnel.
 - F. Additional requirements for operating and maintenance data:
 1. Respective sections of Specifications.

1.07 SUBMITTAL SCHEDULE

- A. Submit two copies of preliminary draft of proposed formats and outlines of contents of Operation and Maintenance Manuals within 30 days prior to substantial completion.
- B. Submit two copies of completed data in preliminary form no later than 30 days following Engineer's review of the last shop drawing of a product and/or other submittal specified under Section 01340, but no later than delivery of equipment. One copy will be returned with comments to be incorporated into the final copies and the other copy will be retained on-site for use in any early training.
- C. Submit four (4) copies of approved manual in final form directly to the offices of the City Engineer or designee, within 10 days after the reviewed copy or last item of the reviewed copy is returned.
- D. Provide four (4) copies of addenda to the operation and maintenance manuals as applicable and certificates as specified within 30 days after final inspection.
- E. Provide all data in electronic format on CD or DVD.

1.08 INSTRUCTION OF OWNER'S PERSONNEL

- A. Prior to demonstration test, fully instruct Owner's designated operating and maintenance personnel in operation, adjustment and maintenance of products, equipment and systems.
- B. Operating and maintenance manual shall constitute the basis of instruction. Review contents of manual with Owner's operating and maintenance personnel in full detail to explain all aspects of operations and maintenance.
- C. Instructors shall be fully qualified personnel as outlined within the individual equipment specifications. If no specific training specifications are listed with the

equipment, the Contractor shall provide the instruction with qualified Contractor personnel.

- D. The Contractor shall provide a list to the Owner indicating the date, time and instructors that will be present for all training sessions.
- E. The instructors shall provide for and prepare lesson scopes and handouts for up to five individuals designated by the Owner that outline the items to be covered. Separate sessions for operation and maintenance instruction shall be provided consecutively. Handouts shall be submitted to the Owner with at least one week's notice prior to the training sessions.
- F. All instruction sessions shall be video taped with portable video recording cameras and tapes supplied by the Contractor. Video taping shall be made by the Contractor under the direction of the Owner using DVD compatible video recording equipment.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION (NOT USED)

END OF SECTION

SECTION 13410 - BASIC INSTRUMENTATION REQUIREMENTS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: General administrative and procedural requirements for instrumentation installations. Administrative and procedural requirements are included in this Section to expand on requirements specified in Division 1.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Sections 01340, Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
1. Product data for each product specified.
 2. Wiring diagrams, both elementary and schematic, differentiating between manufacturer installed and field-installed wiring.
 3. Digital Systems: Provide the following:
 - a. Digital equipment layouts of input and output racks showing complete module model number and addressing assignment. Layouts of port pin assignment, connection schematic indicating cable types and port addresses.
 4. Software Programs: One fully annotated printed copy of program prior to factory test. In addition, provide required number of copies of latest revisions of program at time of acceptance by OWNER. Submittal of printouts, listings, and screen images shall be supplied on paper (hard copy). With concurrence of OWNER and ENGINEER, machine readable magnetic copies may be supplied in addition to printed copies as a matter of convenience. Format of magnetic media shall be as mutually agreed with OWNER.
 5. Programmable Logic Controllers: Submits lists of input and output assignments, data file structures used, and internal data points. Show points used to communicate with between PLCs and the operator interface and data collection segments. Include complete, fully annotated ladder logic diagrams complete with cross-reference listings.
 6. Operator Interface and Supervisory Control: Submit "screen dump" images of each proposed operator interface screen. Describe color schema, mouse button use, function key controls and communication protocol with PLCs. Provide a flow diagram showing screen navigation. Show sample event and alarm log outputs.
 7. Data Collection: Submit details of data structures, communications protocols, data exchange formats, sampling intervals, and file storage space management. Provide "screen dump" images of historical trending.
 8. Data Management and Reporting: Includes process data management, laboratory management, and reporting. Submit data definitions, customization of base software, data entry screens, menus, and report formats. Describe data entry, collection, and reporting scenarios. Describe data file storage management including backup and archive operations.
- B. Record Drawings: At Project closeout, submit record drawings of installed products, in accordance with requirements of Section 01720.
1. Where Drawings are drafted by computer equipment, CONTRACTOR shall furnish files on a disk. These Drawings shall include changes made by Field Orders, Change Orders, Addenda, and errors discovered during start-up and acceptance.

2. Drawings shall include terminal numbers at each wiring termination and piping termination. A complete system diagram shall be included.
- C. Operation and Maintenance Manuals: Submit in accordance with requirements of Section 01730, operation and maintenance manuals for items included under this Section.
1. Instructions shall be short, easy-to-understand directions specifically written for this Project describing various possible methods of operating equipment. Instructions shall include procedures for tests required, adjustments to be made, and safety precautions to be taken with equipment. These documents are to be submitted to ENGINEER's office.
 2. Provide 1 complete set of manufacturer's documentation covering programmable equipment supplied. Include hardware manuals and prints as manufacturer normally ships with programmable equipment.
 - a. Include complete software manuals for operating system, as well as manuals for any other software. Written instructions for the operations and maintenance of software shall be provided. The instructions shall be short, easy-to-understand directions specifically written for this Project describing various possible methods of operating software.
 - b. Include program listings, point/address lists, cross-reference listings, images of screens, data entry forms, and sample reports.
 - c. Manuals shall include instructions for program users and instructions for maintenance programmers.
- D. Warranty: Submit in accordance with requirements of Section 01720, warranties covering the items included under this Section.

1.03 QUALITY ASSURANCE

- A. Manufacturer's Qualifications: Firms regularly engaged in manufacture of equipment, of types and sizes required, and whose products have been in satisfactory use in similar service for not less than 5 years.
- B. Codes and Standards:
1. National Electric Code.
 2. Applicable State and local requirements.
 3. UL listing and labeling shall be adhered to.
- C. Items covered by this Section are designated as undelivered specifically manufactured equipment for which associated progress payments will be made in accordance with this Specification.
- D. Equipment that does not have a UL, FM, CSA, or other listed testing laboratory label shall be furnished with a notarized letter signed by the supplier stating that equipment furnished has been manufactured in accordance with National Electric Code and OSHA requirements.
- E. CONTRACTOR shall provide permits and licenses, observe and abide by applicable laws, regulations, ordinances, and rules of State, territory or political subdivision thereof, wherein the Work is done. CONTRACTOR shall pay fees for permits, inspections, licenses, and certifications when such fees are required.
- F. To ensure timely performance and conformance with Specifications, Project meetings shall be held at OWNER's facility once every 3 months during course of Project. Cost of such meetings shall be included.

- G. Calibration Equipment and Testing Apparatus: Equipment supplier shall have available test and calibration equipment for factory panel tests, installation, start-up, service contract, and maintenance or troubleshooting purposes.
 - 1. The equipment required for these tests is as follows:
 - a. One - Digital Multimeter with an accuracy of plus or minus 0.1 percent.
 - b. One - Signal calibrator for analog signals.
 - c. One - Programming terminal with software to configure programmable equipment.
- H. Component Requirements: For the purposes of uniformity and conformance to industry standards, signal transmission modes shall be either electronic 4-20 mA DC or pneumatic 3-15 psi only. No other signal characteristics are acceptable, except for remote temperature detector (RTD) and thermocouple (TC) sensing circuits; 4-20 mA DC signals shall be such that devices may be wired in parallel for 1-5 volt DC as required. 1-5 volt DC mode shall be employed only within control panel enclosures.
- I. Responsibility and Coordination: Drawings and Specifications are intended to include details of a complete equipment installation for purposes specified. CONTRACTOR shall be responsible for details which may be necessary to properly install, adjust, and place in operation complete installation. Any error on Drawings or in Specifications which prevents proper operation of supplied system shall be shown correct at time of Shop Drawing submittal for approval or brought to attention of ENGINEER with or prior to submittal.
- J. CONTRACTOR shall be responsible for costs incurred to correct aforementioned errors brought to ENGINEER's attention. CONTRACTOR shall assume full responsibility for additional costs which may result from unauthorized deviations from Specifications.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. Manufactured material shall be adequately packed to prevent damage during shipping, handling, storage, and erection. Material shipped to Site shall be packed in a container properly marked for identification. Blocks and padding shall be used to prevent movement.
- B. CONTRACTOR shall inspect the material prior to removing it from carrier. If damage is observed, CONTRACTOR shall immediately notify carrier so that a claim can be made. If no such notice is given, material shall be assumed to be in undamaged condition; any subsequent damage that occurs to the equipment shall be the responsibility of CONTRACTOR. Repair and replacement of damaged parts will be done at no expense to OWNER.
- C. CONTRACTOR shall be responsible for any damage charges resulting from handling of materials.

PART 2 - PRODUCTS

2.01 EQUIPMENT SUPPLIERS

- A. References made in these Specifications to specific manufacturer's products are intended to serve as a guide to type, construction, and materials. Listing of a manufacturer does not imply acceptance by ENGINEER of a manufacturer's particular product, product line, or latest product revision if it does not meet Specifications.

- B. Equipment Supplier: Equipment specified under Sections 13413 through 13899 and shown on Drawings shall be designed as a system, fabricated or purchased, shipped to Site, and started up by a qualified and approved equipment supplier. Intent is for unit responsibility.
 - 1. Equipment supplier shall not assign any of its rights or delegate any of its obligations under these Sections without prior written acceptance by ENGINEER.
 - 2. Direct purchase of any items in these Sections by CONTRACTOR is not in compliance with this Specification and will not be permitted.

2.02 EQUIPMENT

- A. Transmitted electronic signals to equipment of other vendors and between control panels shall be a separate isolated-floating output for each item of equipment and shall conform to ISA Standard S50.1.
- B. Enclosures shall be NEMA 12, 4, 4X, or 7 as indicated on Drawings. Intrinsically safe systems, shall be furnished when called for.
- C. No external power connections shall be allowed unless specifically called for in Specification. Where an external power source is called for, unit shall accept 120 VAC, plus or minus 10 percent power.
- D. Current-to-current converters shall be used as power boosters to provide sufficient signal power as required. It is equipment supplier's responsibility to determine under what circumstances and locations power boosters are required, provide them, and integrate them into the instrumentation system to make system function properly.
- E. Separate power supplies shall be totally enclosed with solderless terminals for connections. They shall be short circuit current limiting type that will automatically resume regulation after removal of short circuit. They shall operate from 120 volt AC, plus or minus 10 percent power. Regulated voltage shall be fixed. Units with internal trim potentiometers will be accepted.
 - 1. Instruments shall be panel-mounted or enclosed for wall mounting as shown on Drawings.
- F. Size and style of instruments are defined in Specifications. Pneumatic panel-mounted units shall match in appearance similar electronic components.
- G. Charts and scales are shown on Drawings. Standard scales shall not be accepted without ENGINEER's approval if it differs from those shown. Ratio station scales and other scales shall be graduated such that major graduations fall on whole numbers (i.e., 1, 2, 3, or 5, 10, 15, etc.) and minor graduations fall on 0.1 or 0.2 intervals (i.e., 1.1, 1.2 or 11, 12, etc.). If two scales are called for on ratio stations, each scale shall be indexed to meet Specification. Drawing of each scale for ratio stations shall be submitted with Shop Drawings for approval.
- H. Solid-state output switches, where used, shall be overvoltage transient protected and not be damaged by dI/dT or dv/dt for their design application under this Contract.
- I. Instruments shall be equipped with permanently attached identification tag. Tag shall be included on field- and panel-mounted devices. Tags shall include ENGINEER's tag identification and manufacturer's tag identification if different from ENGINEER's.

1. Tags shall be either stamped metal or laminated phenolic with black letters engraved on a white background. Field-mounted devices shall have tags fastened with screws. Devices mounted in panels will be tagged inside panel on subplates or on device itself where it can be easily read.
- J. Finish on instruments and accessories shall provide protection against corrosion by elements in environment in which they are to be installed. Both the interior and exterior of enclosures shall be finished. Extra paint of each color used on material shall be provided by manufacturer for touch-up purposes.
- K. Provide equipment identification nameplates complying with Section 16075. Nameplates shall contain ENGINEER's item designation and, for indicators and transmitters, design range and units of device shown.

2.03 SOURCE QUALITY CONTROL

- A. Control and monitoring system control panels and computer equipment, if any, shall be tested at the factory and witnessed by ENGINEER prior to shipment to Site. ENGINEER shall be given 4 weeks notice before factory test date. Factory test shall include checking for conformity to Specifications, fabrication, and nomenclature. Control and monitoring system logic and terminals shall be checked line by line and function by function in total for conformity of Drawings.
- B. Conduct preliminary testing prior to factory checkout by executing programs supplied for this Project. Exercise inputs to test logic for correct function and proper response of outputs. Verify correct interface with programs. Verify correct communications.
- C. Factory testing shall be used to validate fieldbus and plant LAN/WAN interconnections. Proper communication between devices and software components shall be demonstrated. Data Collection and Data Management Reporting shall be demonstrated.
- D. Equipment supplier shall have test equipment available at the factory. A full set of annotated logic programs and wiring diagrams with the latest revisions shall be made available to ENGINEER at factory for checking purposes. Drawings shall include wire numbers and terminal numbers.
- E. Control panels and programmable equipment shall not be shipped to Site until logic conforms to Contract requirements, physical changes required by testing are made, and tags conform to factory test corrections. Equipment delivered to Site without factory test or corrections will be returned to factory at CONTRACTOR's expense.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Equipment provided under this Section shall be fabricated, assembled, erected, and placed in proper operating condition in full conformity with detail drawings, specifications, engineering data, instructions, and recommendations of equipment manufacturer as approved by ENGINEER.
- B. Install equipment as indicated, in accordance with manufacturer's written instruction, and in compliance with recognized industry practices to ensure that products fulfill requirements.

- C. Elements that are supported by plumbing or piping, or that have only plumbing or piping connections shall be installed under those Sections.
- D. Plumbing, piping, or pneumatic signal connections to elements requiring such connections shall be made under those Sections. Control panels shall be installed in accordance with Division 16 Sections, with piping connections to control panels installed under Division 15 Sections.
- E. Drawings are not intended to show every detail of construction or location of piping, ductwork, or equipment. Where proper operation or construction makes it necessary or advisable to change location of piping, instrumentation equipment, air ducts, or other equipment, CONTRACTOR shall so inform ENGINEER for his approval and permission.

3.02 FIELD QUALITY CONTROL

- A. Calibrate equipment in accordance with manufacturer's instructions to ranges or set points indicated on Drawings.
- B. Installation and Start-up: Equipment supplier shall have an established service facility from which qualified technical service personnel and parts may be dispatched upon call. Such a service facility shall be no more than 6 hours travel time from Site.
 - 1. Equipment supplier shall provide an experienced, factory-trained, competent, and authorized service representative for a minimum of 3 times at Site, including once during installation and start-up and once during acceptance to inspect, check, and calibrate any part of system. Supplier's service representative shall revisit Site for 8 hours per day as often as necessary after installation until trouble is corrected and equipment has passed acceptance test and is operating satisfactorily to ENGINEER.
 - 2. Third trip is after equipment has been accepted and shall be used to instruct OWNER's personnel in aspects of operation and maintenance, such as fuse locations, use of controls, instruction manuals, etc. Third trip shall be for duration of two, 8-hour days at OWNER's facility.

3.03 DEMONSTRATION

- A. Upon completion of installation and calibration, demonstrate functioning of equipment in accordance with requirements. Where possible, correct malfunctioning units at Site, then retest to demonstrate compliance; otherwise, remove and replace with new or repaired units, and retest to demonstrate compliance.

END OF SECTION

SECTION 13413 - OPTICAL FIBER CABLING SYSTEMS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Product and installation requirements for the following:
 - 1. Fiber-optic (FO) Cables.
 - 2. Fiber-optic Connectors, Couplers, and Patch Panels.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
 - 1. Product data for each type of product specified.
 - 2. Product certificates, signed by the communication system manufacturers, certifying that the cables are suitable for the connected equipment as described in "Quality Assurance" Article below.

1.03 QUALITY ASSURANCE

- A. Manufacturers Qualifications: Firms regularly engaged in manufacture of equipment, of types and sizes required, and whose products have been in satisfactory use in similar service for not less than 5 years.
- B. Connected Equipment Manufacturer Certifications: Where cables specified in this Section are used to provide signal paths for systems specified in other sections of these Specifications, or for systems furnished under other contracts, obtain review of the cable characteristics and certification for use with the connected system equipment by the connected equipment manufacturers.
- C. UL Compliance: For cables that may be run in plenum ceilings or other air-handling spaces, provide cables tested for compliance with applicable requirements of UL Standard 910, "Test Method for Fire and Smoke Characteristics of Electrical and Optical Fiber Cables Used in Air-Handling Spaces." In addition, provide FO cables that have passed the UL VW-1 flame test.
- D. EIA/TIA Compliance: Comply with applicable requirements of EIA Standards, EIA-440, -455, -458, -475, -509, -568-b.3, and 598-a pertaining to optical fiber cable and system component construction and installation. EIA/TIA-455-61, FOTP-61, Measurement of Fiber or Cable Attenuation Using an OTDR.
- E. Fiber Optics Experience: CONTRACTOR must be able to prove to the satisfaction of OWNER that it has significant experience in the installation of fiber-optics cable systems. Installation must include installation of fiber-optics cable, fiber termination, knowledge of interconnect equipment, and a thorough knowledge of testing procedures.
- F. Labeling: Handwritten labels are not acceptable. All labels shall be machine printed on clear or opaque tape, stenciled onto adhesive labels, or type written onto adhesive labels. The font shall be at least 1/8 inch in height, block characters, and legible. The text shall be of a color contrasting with the label such that it may be easily read. If labeling tape is utilized, the font color shall contrast with

the background. Patch panels shall exhibit workstation numbers or some type of location identifier, in sequential order, for all workstations or devices attached. Each fiber-optics cable segment shall be labeled at each end with its respective identifier.

- G. Fiber-Optics Interconnect Equipment (Patch Panels): Interconnect equipment shall be used in all fiber cable installations. Patch panels shall be mounted in the equipment racks or panel mounted. Interconnect equipment mounted in racks shall be affixed to the rack by at least 4 screws. All fiber-optics interconnect devices shall be assembled and installed in accordance with the manufacturer's instructions and recommendations.
- H. Patch Cords: Patch cords shall be provided for each fiber-optic port on the patch panel. Patch cords shall meet or exceed technical specifications of all installed fiber-optic cable. Patch cord connectors shall be matched with patch panel connector type and network fiber module connector type as required.

1.04 COMMISSIONING

- A. Subsequent to hook-ups of FO system to signal sources and destination equipment, operate systems to demonstrate proper functioning. Replace malfunctioning FO cabling system items with new materials, and then retest until satisfactory performance is achieved.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which may be incorporated in Work include:
 - 1. FO Cables:
 - a. Corning Infinicor SX+ Optical Fiber, or Equal, for multi-mode applications.
 - b. Corning NexCor Optical Fiber, or Equal, for single-mode applications.
 - 2. FO Connectors and Couplers:
 - a. AMP Netcon.
 - b. AT&T Network Systems.
 - c. Corning.
 - d. Honeywell, Inc.
 - e. ITT Corp.
 - f. Thomas and Betts Corp.
 - 3. FO Patch Panels:
 - a. Panduit.
 - b. Volition.

2.02 OPTICAL FIBER CABLING SYSTEMS

- A. Fabricate system using manufacturer's standard materials as indicated by published product information and in sizes, types, and performance characteristics as indicated.
- B. FO Cables: Factory fabricated, single channel, all dielectric, low loss glass type, fiber-optic multimode graded-index cables with the following operational and construction features:
 - 1. Multi-mode Fibers:

- a. Cable Type shall be Corning ALTOS One Indoor/Outdoor Tight-Buffered Cable.
 - b. Number of Fibers: 6 minimum or as listed on Drawings.
 - c. Core Diameter: 50 microns or as listed on Drawings.
 - d. Cladding Diameter: 125 microns or as listed on Drawings.
 - e. Fiber Category: style OM2 or OM3.
 - f. Subunit Size: 2.0 mm or as listed on Drawings.
 - g. Maximum Attenuation: Less than 2.5 dB/km at 850 nm and less than 1 dB/km at 1300 nm.
 - h. Minimum Bandwidth: Greater than 1000 MHz-km.
 - i. Minimum Bend Radius (Unloaded): 10 cm (3.1 in).
 - j. Operating Temperature Range: -20 to +70 degrees C.
- C. FO Connectors: Stainless steel, fiber-optic cable connectors, capable of terminating FO glass cables with diameters from 8 through 1,000 microns. Fabricate connectors with optical fiber, self-centering, axial alignment mechanisms. Select ST or SC style connectors as required or shown on Drawings. Connectors shall have an insertion loss of 0.5dB or better.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Examine areas and conditions with the Installer present for compliance with requirements, and other conditions affecting the performance of optical fiber cabling system. Do not proceed with Work until unsatisfactory conditions have been corrected in a manner acceptable to Installer.

3.02 INSTALLATION

- A. Install fiber-optic cables and associated equipment and devices in accordance with industry standards and manufacturer's written instructions.
- B. Install fiber-optic cable without damage to fibers, cladding, or jacket. Ensure that media manufacturer's recommended pulling tensions are not exceeded. Do not, at any time, bend cables to smaller radii than minimums recommended by manufacturer.
- C. Install FO cables simultaneously where more than one cable is being installed in same raceway. Use pulling lubricant where necessary; compound used must not deteriorate cable materials. Do not use soap. Use a pulling means, including fish tape, rope, and basket-weave grips, that will not damage media or raceway.
- D. No splices are allowed, except at indicated splice points.

3.03 GROUNDING

- A. Provide grounding connections for other system components as required by manufacturer's written instructions.

3.04 APPLICATIONS

- A. Install optical fiber cabling for project applications as detailed on drawings.

3.05 FIELD QUALITY CONTROL

- A. Testing: Testing shall be done by CONTRACTOR with at least 5 years of experience in testing fiber-optic cabling systems. CONTRACTOR shall test each fiber strand. **OWNER reserves the right to have representation present during all or a portion of the testing process. CONTRACTOR must notify OWNER 5 days prior to commencement of testing.** If OWNER elects to be present during testing, test results will only be acceptable when conducted in the presence of OWNER. Any fiber-optic cable left non-terminated at the discretion of OWNER, shall be tested using an adequate light source to determine that all installed strands are not damaged.

- B. Fiber-Optics Cable: Each fiber strand shall undergo bi-directional testing for signal attenuation losses using power meter and light source. Testing shall also include Optical Time Domain Reflectometer (OTDR) at both 850 and 1,300 nanometers for all installed fiber strands.
 - 1. Recommended Test Equipment:
 - a. Multimode: Siecorm OM-100F and OS-100D or equivalent power meter and light source.
 - b. Multimode: Siecorm OTDRPlus with appropriate modules for testing.
 - 2. Tests:
 - a. Multi-mode: Bi-directional signal attenuation at 850 and 1,300 nm.
 - 3. Test Criteria: Signal loss of less than 10 dB through entire fiber path, including cable, couplers and jumpers.

- C. Documentation (Fiber Optic): CONTRACTOR shall provide documentation to include test results and as-built Drawings. Fiber Test Results: The results of the fiber testing shall be entered into the form "Fiber Attenuation Tests Results." Handwritten results are acceptable provided the test is neat and legible. Copies of test results are not acceptable. Only original signed copies will be acceptable.
 - 1. Each cable installed shall undergo complete testing in accordance with TIA/EIA TSB-67 to guarantee performance to this standard.
 - 2. All required documentation shall be submitted within 30 days at conclusion of the project to OWNER.
 - 3. Test Criteria: Pass rate to conform to latest TIA/EIA Standards that incorporate link performance testing through entire path, including cable, couplers, and jumpers.

- D. Acceptance: Acceptance of the Data Communications System, by OWNER, shall be based on the results of testing, functionality, and the receipt of documentation.

3.06 CLEANING

- A. Clean optical fiber cabling and components of dirt and construction debris upon completion of installation.

END OF SECTION

SECTION 13421 - FLOW MEASUREMENT

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Thermal Mass transmitter.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Sections 01340 and 13410, Shop Drawings and Basic Instrument Requirements covering the items included under this Section.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which shall be incorporated in Work include:
 - 1. Thermal Mass Transmitter:
 - a. Magnetrol Thermo TA2 (NO OR EQUAL)

2.02 THERMAL MASS

- A. Thermal Mass sensor detects heat dissipation off of a heated surface. The sensor contains two matched RTDs. One sensor monitors the heated surface and the second sensor monitors the process temperature. The power to the heated surface is varied to maintain a constant differential between the process and heated surface temperatures. The power used translates to a mass flow rate per standard calibration curves. The process temperature is monitored to provide temperature compensation for the entire range of the sensor. Converter shall include a repairable circuit board mounted in a cast aluminum explosion-proof housing. Transmitter shall output an isolated 4-20 mA signal proportional to the mass flow measurement. Adjustable electronic damping shall be provided from 0 to 15 seconds.
- B. Sensor shall be calibrated to Air.
- C. Accuracy shall be within plus/minus 0. percent of calibrated span for spans from 1:1 to 100:1 of URL. Repeatability shall be plus/minus 0.5% of reading.
- D. Unit shall be supplied with an IP66 Aluminum enclosure, Ambient temperature -40C to +80C (-40F to +176F), operating temperature: plus/minus 0.04% per C, and Humidity: 99%, non-condensing.

PART 3 - EXECUTION

3.01 GENERAL

A. Examination, Installation, Field Quality Control, Demonstration: In accordance with Section 13410.

END OF SECTION

SECTION 13428 - ANALYTICAL INSTRUMENTS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
1. Dissolved Oxygen Analyzer.
 2. Total Suspended Solids Analyzer.
 3. Sludge Blanket Monitor.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which may be incorporated in Work include:
1. Dissolved Oxygen Analyzer:
 - a. Cerlic O2X (NO OR EQUAL).
 2. Submersion type turbidimeter:
 - a. Cerlic ITX20 (NO OR EQUAL)
 3. Insertion type turbidimeter:
 - a. Cerlic ITX-IL (NO OR EQUAL)
 4. Sludge Blanket Monitor:
 - a. Cerlic CBX Auto Sludge Blanket Monitor & BB1 Controller (NO OR EQUAL)

2.02 COMPONENTS

- A. Dissolved Oxygen Analyzer:
1. Process dissolved oxygen (DO) analyzer shall consist of a field-mounted submersible sensor probe and an analyzer transmitter. Sensor probe shall be self-cleaning type. Clark type sensor shall expose no less than 4 square inches of membrane area to monitored liquid. Unit shall operate from 120 VAC, plus or minus 10 percent power.
 2. Analyzer/transmitter (CERLIC BB2, NO OR EQUAL) shall have direct-reading, multi-scale indicator on analyzer face or behind a window in the "space" enclosure. Enclosure shall be surface-mount or panel-mount in a general-purpose or NEMA 4 rating as shown. Provide cable between probe and analyzer/transmitter in length required. Provide "plug-and-receptacle" type connector. Female receptacle shall be suitable for mounting on junction box and shall have stainless steel shell. Connector shall have gold contacts, shall be hose-down rated, and shall be Brad Harrison Quick-change or equal.
 3. Analyzer output shall be an isolated RS-485 signal for connection to a BB2 analyzer.
 4. Accuracy shall be plus or minus 1% of full scale excluding effects of free Chlorine, Hydrogen Sulfide, and pH.
 5. Probe shall have automatic temperature compensation. Transmitter shall be capable of operating in an ambient of 0 to plus 50 degrees C.

B. Submersion type turbidimeter:

1. Provide submersible turbidimeter utilizing forward light scatter to generate turbidity measurement which is linear to N.T.U. Unit to have 1 LED light source pulsing at 880 nm. Measured value to be N.T.U. independent of liquid color and absorption or scattering at sensor windows. System must be suitable for suspended or direct mounting in open channel or vessel depths to 100 feet. Sensors to be capable of normal operation with 75 percent obscuration of viewing lenses due to absorbed light.
2. Material of construction sensor 316 stainless steel, with neoprene gaskets. Light source shall be a LED. Converter range 0-100 to 0-30,000 ppm, Accuracy: plus or minus 0.5% full scale, repeatability: plus or minus 200ppm.
3. Analyzer/transmitter (CERLIC BB2, NO OR EQUAL) shall have direct-reading, multi-scale indicator on analyzer face or behind a window in the "space" enclosure. Enclosure shall be surface-mount or panel-mount in a general-purpose or NEMA 4 rating as shown. Provide cable between probe and analyzer/transmitter in length required. Provide "plug-and-receptacle" type connector. Female receptacle shall be suitable for mounting on junction box and shall have stainless steel shell. Connector shall have gold contacts, shall be hose-down rated, and shall be Brad Harrison Quick-change or equal.
4. Sensor output shall be an isolated RS-485 signal for connection to a BB2 analyzer.
5. Probe shall have self cleaning capability. Transmitter shall be capable of operating in a process temperature of 0 to plus 60 degrees C.

C. Insertion type turbidimeter:

1. Application: Continuous on-line measurement of suspended solids in the range of 30-30,000 ppm or mg/l range for RAS or WAS in WWTP's and sludge in WTP (depending on type of sludge).
2. Sensor : The measuring principle is based on the transmission of a single NIR (Near Infra-Red) light beam generated by a light emitting diode (LED) and received by a silicon detector. NIR light is not sensitive to color and does not contribute to biological growth as with visible light.
 - a. Sensors to be smart design, so that they are programmed and calibrated from the control box but retain all information internally rather than in the control box. Suspended solid concentrations are measured as a function of the ability of suspended materials to absorb and reflect NIR-light (near infra-red). Sensors based on "reflection" of light by particles are not adequate and therefore not acceptable.
 - b. The sensor housing is to be made of 316SS with glass lenses. Sensor designed for 90 psig (6 bar) working pressure and supplied with integral built-in mechanical stop. Sensor to have integral SS flushing nozzle with check valve. Sensor to be designed to mount in a 1.5" npt female connection on pipe. Gap between lenses is to be to be 15mm. Liquid velocity should to be at least 4 fps in pipe to have turbulent flow. Fluid can flow in either direction. Sensor to be supplied with 33' (10 m) of shielded 4-conductor cable with polyurethane jacket and metallic M12-connector with o-ring seal. The sensor should have a measuring range of 30-30,000 ppm.
3. Analyzer/transmitter (CERLIC BB2, NO OR EQUAL) shall have direct-reading, multi-scale indicator on analyzer face or behind a window in the "space" enclosure. Enclosure shall be surface-mount or panel-mount in a general-purpose or NEMA 4 rating as shown. Provide cable between probe and analyzer/transmitter in length required. Provide "plug-and-receptacle" type connector. Female receptacle shall be suitable for mounting on junction box and shall have stainless steel shell. Connector shall have gold contacts, shall be hose-down rated, and shall be Brad Harrison Quick-change or equal.
4. Sensor output shall be an isolated RS-485 signal for connection to a BB2 analyzer.

5. Probe shall have self cleaning capability. Transmitter shall be capable of operating in a process temperature of 0 to plus 60 degrees C.
6. Self-Diagnostics: The software should be of Multi-task design. It should also contain a watchdog function connected to the microprocessor. The software should inform the “watch-dog” at least once per second that the device is working properly. If it does not, then the “watch-dog” shall restart the processor in order for the unit to resume measuring.
7. Programming Module: All programming and settings are performed from the outside of the control box by using a self-instructing menu, controlled by just three touch pad keys. Special plug-in proms or manually adjustable potentiometers for programming are not acceptable. Tamperproof programming feature is required to keep settings from being changed, except by authorized personnel. In the case of power loss, an EEPROM memory should save programming during power outages.
8. Zero point calibration to be done using clean de-aerated water. The control box should allow for calibration against suspended solids solutions by calibrating to one point or up to five points for wide calibration range. Any of these five points may be entered and the unit shall calculate the correlation between the points. The values for the calibration points which are obtained from laboratory analysis should be able to be entered anytime after calibration since the meter correlates these to light transmission values. Graph scale should be adjustable by changing 4-20 mA output settings. Sample points should not have to be re-entered to change scale. Programming menus to be of a cursor type.
9. Mounting: Sensor to be supplied with 1.5” npt 316 SS isolation valve assembly and male nipple to attach to 1.5” npt boss or saddle in pipe supplied by contractor. 1.5” connection should be at 45 to 90 from bottom of pipe for horizontal pipes and minimum of 10 pipe diameters down stream of elbows and restrictions and 5 pipe diameters for recover after sensor. Sensor can also be mounted in vertical pipes with same downstream requirements. Control box can be mounted inside or outside, but should not be exposed to direct sunlight. The transmitter should have four (4) 3/16” holes for mounting to walls or mounting plates.
10. Flushing System: Sensor to have integral SS flushing nozzle. Control box to be supplied with solenoid flushing valve prewired to control box and mounted on a common aluminum sunshield mounting plate. Flushing cycle to be control box program and should be field adjustable. Output signal must be held constant during flush cycle. Flushing liquid to be 40-60 psig filtered reuse water or compressed air.

D. Sludge Blanket Monitor:

1. Application: Automatic measurement of sludge blanket levels in clarifiers, thickeners, etc. in water and wastewater treatment plants.
2. Sensor: The measuring principle is based on transmission of a single NIR (Near Infra-Red) light beam between two glass prisms and the ability of particles to absorb this light. NIR light is not sensitive to color and does not contribute to biological growth as with visible light. Light source to be 880 nm wavelength NIR light (reflective design sensors are not acceptable). The sensor should be lowered at programmable intervals or pulses from limit switch on rake until the sludge phase is found or blanket level detected. The sensor is then raised and cleaned with a built-in water flushing system after each cycle. The sensor head should be made of 316SS and attached to 33’ (10 m) of 4 conductor cable with Tefsel outer coating, in order to withstand mechanical wear and chemical attack from various fluids.
3. Transmitter - Cerlic BB1Control Box: The transmitter should be microprocessor based with self-instructing menu, digital circuitry, and illuminated LCD screen. Sludge blanket height to be presented in feet on LCD display and as a scalable 0/4-20 mA, 700 ohms, galvanically isolated, output signal, (8 bit resolution). A second screen should be available to show to 240 data logged points as blanket depth versus time or solids concentration versus tank depth. Output signal should be proportional to sludge blanket level. Second output to be RS485

communication to show solids concentration versus depth in tank. Unit to be equipped with alarm relay. The enclosure should be water-tight molded polyurethane, NEMA 4 (IP65).

- a. The power supply must be equipped with filter, fuse and varistors for protection against power surges. The alarm contact is normally open (dry contact), when activated (closed contact) it should have max. resistive load of 250V/2A. The transmitter should have EEPROM memory with battery backup for clock. Following a power failure the sensor should return to home position and then resume operating without requiring recalibration. Power supply is to be 110/1/60. Illuminated LCD display to continuously display current sludge blanket level in feet. Housing to be equipped with built-in thermostat and heater to be activated at temperatures below 40°F.
4. Programming Module: Sounding intervals to be determined by internal timer or externally pulses from a rake. Timer intervals to be adjustable from 4 – 120 minutes. Transmitter to have internal pulse counter that is adjustable from 1–99 pulses. Pulses are generated by external closing relay, which is activated by the rake and powered by 5 VDC supplied by the control box. Limit switch to be normally mounted 90 degrees out of phase with rake on circular clarifiers.
5. All programming and settings are performed from the outside of the transmitter box by using a self-instructing menu controlled by just four touch pad keys. Unit to accept two calibrations points: 1) zero point using clean de-aerated water and 2) sample point using RAS and entering concentration determined by lab. In order to obtain a high accuracy on distance measurement, the unit should allow for calibration against a known distance between the probe's "home position" and a reference point. Unit to have programming offset for dead zone in order to prevent floating sludge or foam from being detected as false sludge blanket. Maximum span or travel distance to be 32' from bottom of control box to bottom of tank.
6. Tamperproof programming feature is required to keep settings from being changed, except by authorized personnel. In the case of power loss an EEPROM memory should save programming during power outages.
7. Self-Diagnostics: The software should be of Multi-task design. It should also contain a watch-dog function connected to the microprocessor. The software should inform the "watch-dog" at least once per second that the device is working properly. If it does not, then the "watch-dog" shall restart the processor in order for the unit to resume measuring.
8. Winch: Winch assembly to consist of motor, 110/1/60, pvc winding drum and pvc weather-proof enclosure. Winch to include flushing mechanism for probe and 1/2" npt (12 mm) hose connection for flushing water. Flushing intervals to be programmable. Max. flush water pressure to be 90 psig (6 bar). Winch to have safety clutch to prevent major damage in case of probe being caught in the rake. Safety clutch to be adjustable from motor to winch drum. Probe speed to 5.7" per second. Sensor to have built-in tilt alarm, so sensor will return to home position, if it contacts the rake or any other item trip down.
9. Mounting: Sludge Blanket Monitor to be equipped with two (2) L shaped stainless steel brackets for 1.5" handrails (2" brackets) which can be hung directly on a handrail. Optional 4" & 6" L brackets should be available for angle handrail.
10. Warranty: The manufacturer shall warrant the equipment to be free of defects from workmanship and material for a period of one (1) year after shipment.

PART 3 - EXECUTION

3.01 GENERAL

- A. Examination, Installation, Field Quality Control, Demonstration: In accordance with Basic Instrumentation Requirements.

3.02 FIELD QUALITY CONTROL

- A. Installation Check: The manufacturer shall provide the services of a factory-trained representative to check the installation of all equipment installed in this Section. The services shall be as noted in Section 01600.
 - 1. Satisfactorily calibrate each analyzer and instruct the plant personnel in the operation and maintenance of each analyzer.

END OF SECTION

SECTION 13430 - CONTROL PANELS AND CONSOLES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
1. Control panels and consoles.
 2. Switches, push-buttons, lights.
 3. Relays.
 4. Control power transformers.
 5. Transient Voltage Surge Suppression

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Sections 01340 and 13410, Shop Drawings and Basic Instrumentation Requirements covering the items included under this Section.

1.03 QUALITY ASSURANCE

- A. Regulatory Requirements:
1. Codes, Ordinances, and Industrial Standards: Design, testing, assembly, and methods of installation for materials, electrical equipment, and accessories proposed under this Section shall conform to National Electric Code and to applicable State and local requirements.
 2. UL listing and labeling of custom-built panels (UL 508) shall be adhered to under this Contract.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which may be incorporated in Work include:
1. Switches, Push-Buttons, Lights:
 - a. Allen-Bradley (Type 800MR).
 2. Relays:
 - a. Potter-Brumfield (Type KUP).
 - b. Schrack North America, Inc. (Type CAD).
 - c. Square D Co. (Type KU).
 - d. Struthers-Dunn (Type A283).
 3. Fusible Terminal Blocks:
 - a. Allen-Bradley (Type 1492-CE6).
 - b. Altech (Type CAFL4U).
 - c. Square D Co. (Class 9080, Type KH-1).
 - d. Thomas & Betts (Series 300 or 0300).
 - e. Weidmueller (SAKS1 or ASK1).
 4. Control Power Transformers:
 - a. Acme.
 - b. Sola.

5. Transient Voltage Surge Suppression:
 - a. Eaton
 - b. Emerson.
 - c. Sola.
 - d. Square D
6. Textured Polyurethane Enamel:
 - a. Sherwin-Williams, Polane T and/or Polane HST.
7. Wire Markers:
 - a. Brady.
 - b. T&B.
 - c. Westline.

2.02 CONTROL PANELS AND CONSOLES

A. Sheet Metal Construction (Interior applications only):

1. Panels and consoles shall be fabricated from sheet steel welded and bolted into a rigid self-supporting structure a maximum of 90 inches high and a minimum of 12 inches deep. Overall length shall be coordinated with space requirements as indicated by Drawings. Changes in length from that shown on Drawings must be brought to attention of ENGINEER within 90 days of Contract Award. Cost to modify floor plan or wall opening shall be at CONTRACTOR's expense after this 90-day period. Panel face layouts shown on Drawings are intended to indicate relative position of all components. Supplier shall fix exact locations and overall dimensions to meet requirements of its equipment.
2. Panel and console bodies shall be 12 gauge minimum steel for panels up to 42 inches in width, and 10 gauge minimum steel for panels exceeding 42 inches in width. Panel subplates shall be same gauge as enclosure. Stiffening members shall be provided for strength and stiffness as required.
3. A minimum of 3 inches shall be provided between edge of panel subplate and outside walls of panel body to ensure adequate wire-way space for external wires entering panel. Panel subplate shall be mounted on collar studs for easy removal. Print pockets shall be provided on each panel. Brackets welded to inside of panel, complete with lights, shall be provided on panels where indicated by Drawings.
4. Identification plates shall be laminated phenolic with black letters engraved on a white background and mounted with screws.
5. All components inside panel shall have identification plates. This includes instruments, relays, switches, circuit boards in plug-in racks, etc. Identification plates shall include engineering symbols (FBQ-1, SW-3, FIC-4, CR-1, etc.). Switches and circuit breakers inside panel shall have names (Horn, Audio Tone, Panel Power, etc.) on identification plates as well as engineering symbol.
6. Identification plates shall be located on or adjacent to device they are identifying and shall be readable without looking around, under, or on top of device to find identification plate.

B. Access:

1. Wall- and/or floor-mounted control panels shall have continuous piano-hinged doors for ease of access. Door openings shall expose a minimum of 80 percent of panel interior. Door openings shall be sealed with a 0.125-inch thick minimum cellular neoprene gasket cemented with oil-resistant adhesive and held in place with a retaining strip. Print pockets shall be provided on each door. Two door enclosures shall have a removable center post. Panel doors less than 40 inches high shall be equipped with a 2-point latching mechanism. Panel doors 40 inches high or more shall be equipped with a 3-point latching mechanism.

2. Components and terminals shall be accessible without removing another component except covers. Swing out sections shall be used if mounting space is required that is not normally accessible.

C. Finish:

1. Panel face openings for mounting equipment shall be smoothly finished cut with counterboring and trim strips provided as required to give a neat finished appearance. Bezels shall be used on all front panel-mounted devices to cover panel cutouts. A chrome-plated or stainless steel bezel shall be used at parting line of panels that have shipping splits or at parting line of panels placed end to end.
2. After fabrication, panel surfaces shall be given a phosphatizing treatment inside and out, and then finished with 2 coats of textured polyurethane enamel. Panel interior shall be painted white, ANSI No. 51. Exterior color will be selected by ENGINEER.
3. Panels shall have identical exterior finishes as selected by ENGINEER. Panel finishes on matching colored panels shall be identical. It is supplier's responsibility to achieve this result, especially for panels fabricated in different shops.

D. Electrical:

1. Internal panel wiring shall be 19 strand No. 16 AWG, 90°C MTW, Class C stranded, or THHN/THWN approved as 90°C MTW. All panel wiring not run in wire ducts shall be bundled and tied. Each wire shall be identified at both ends with same exclusive number. Number shall be same number shown on control schematic. Number shall not be used again for any other purpose. Wires marked differently on each end will not be accepted. Wire markers shall be provided on end of each wire at termination point.
2. Control wiring associated with control circuits de-energized when main disconnect is opened shall be color-coded red. Control wiring associated with control circuits which remains "hot" when main disconnect is opened shall be color-coded yellow. DC control wiring shall be color-coded blue. Ground wires shall be color-coded green. Terminal blocks shall be numbered in numerical order. Yellow wiring leaving panel shall be brought to an isolated set of terminal blocks.
3. Provide an instrument common bus 0.1 by 0.5 by 6-inch minimum in enclosure and isolated from enclosure. A separate instrument common wire shall be run from each common terminal on an instrument to instrument common bus. Instrument common wires looped from one terminal to another and then to instrument common bus will not be accepted.
4. Instrument common bus shall be connected to power supply common with a wire or wire braid strap as short as practical and of sufficient capacity to prevent troublesome voltage drop. Common terminals and common bus for instrument common shall be tagged "Instrument Common." Instrument signal wires of 4-20 mA or 1-5V shall be shielded wire. Telephone wires and telemetry equipment interconnection wires shall be shielded wires.
5. Provide a copper ground bus 0.1 by 0.5 by 6-inch minimum in enclosure to which all instrument grounds and panel enclosure are tied. Separate ground wire shall be run from instrument enclosure ground terminal directly to ground bus. Instrument ground wires looped from one instrument to another will not be accepted. Under no circumstances shall neutral side of power source or any other terminals used for grounding power circuits be used as an instrument common.
6. Wires to internal components shall be connected to inside of terminal strip. Wires to external components shall be connected to outside of terminal strip. No more than 2 wires shall be connected to one terminal point.

7. Panel wire duct shall be provided between each row of components and adjacent to each terminal strip. Wire ducts shall be a minimum of 1-inch wide and 3 inches deep with removable snap-on covers and perforated walls for easy wire entrance. Wire ducts shall be constructed of nonmetallic materials with a voltage insulation in excess of maximum voltage carried therein.
8. Disconnect and transformer shall have enclosed protected terminations to prevent accidental shock.
9. Within each control panel a Transient Voltage Surge Suppression (TVSS) device shall be installed at the main disconnect and shall be sized for the control panel feeder size.
10. Relays, timers, etc., installed on panel subplate shall be provided with a minimum spacing between component and wire duct of 1.5 inches above and 1 inch below. Minimum spacing between adjacent components shall be 0.25 inch. Relays, timers, etc., shown in schematics are intended to show function. Additional relays may be required in conjunction with items shown to provide total number of contacts required. Where limit, pressure, float switches, etc., are used and more than SPDT contacts are indicated by schematics, provide additional contacts required by using auxiliary relays. However, if a DPDT switch is called for, using a SPDT with a relay will not be accepted. All control and pilot devices such as relays, timers, etc., shall be 120V, 3 amp rated except where noted with coil voltage as required. One N.O. spare contact shall be provided on each relay.

E. Panel/Subplate Layout:

1. Panel face-mounted equipment shall consist of pilot lights, push-buttons, selector switches, meters, indicating timer, etc. Spacing between horizontal rows of components shall be 1.5 inches minimum; spacing between vertical columns of components shall be 1.875 inches minimum. Components shall be grouped and/or located as indicated on Drawings. Distance from bottom row of components to floor shall be not less than 36 inches. Top row of recording and indicating instruments shall be centered approximately 60 inches above floor. Maximum height for annunciator windows shall be 85 inches above floor. In general, indicating lights, push-buttons, etc., shall be mounted in accordance with sequence of operation from left to right and top to bottom.
2. A minimum of 2 inches shall be provided between terminal strips and wire ducts or terminal strips and terminal strips. In general, terminal strips shall be mounted on vertical edges of subplate. Where terminal strips are mounted side-by-side, terminals shall be elevated 1.5 inches above subplate to allow wires to pass underneath.
3. Subplates shall have a minimum of 15 percent spare mounting space, and terminal strips shall have a minimum of 20 percent spare terminal blocks.

F. Exterior Enclosures, Panels, and J-Boxes:

1. All Exterior Enclosures, Panels, and J-Boxes shall be NEMA rated and provide as per specified in project drawings.

2.03 SWITCH, PUSH BUTTONS, LIGHTS

- A. Selector switches shall be 120 VAC rated, oil-tight construction with standard operator knob.
- B. Start push buttons shall be 120 VAC rated, oil-tight construction with extended guard and black color insert.
- C. Stop push-buttons shall have a half-guard with red color insert. Contacts shall be rated NEMA B-150 and P-150.

- D. Pilot lights shall be push-to-test oil-tight construction with cap colors and voltages as required. Nameplates for each switch and light shall conform to manufacturer's series and type with engraving as called for on Drawings.

2.04 RELAYS

- A. Control Relays: Switching and output relays shall be plug-in type with contacts rated 120 VAC, 3 amp with 120 VAC or 24 VDC coil, indicating light, manual operator, and plastic transparent cover. Relays shall have a retainer mechanism to prevent loosening from vibration. Relays shall not be used for switching 1-5 VDC or 4-20 mA signals associated with instruments.

2.05 TERMINAL BLOCKS

- A. Terminal blocks shall be 300 or 600 volt rated, channel-mounted box lug with pressure plate type or binding head screw type with pressure plate, and shall have a white marking strip. Terminal blocks shall be color-coded according to the following coloring scheme:
 - Black 120V power circuits de-energized when main disconnect is opened.
 - White 120V neutral conductors.
 - Red 120V control circuits de-energized when main disconnect is opened.
 - Yellow 120V control circuits which remain hot when main disconnect is opened.
 - Blue Terminal blocks for DC wiring.
 - Gray Terminal blocks for shields in DC wiring.
 - Green Ground terminal blocks.
- B. For terminals associated with 120V nonisolated input cards, individually fused terminal blocks shall be used for 120V power to field devices.
- C. Provide a minimum of 20 percent spare terminals for each type and color of terminal used. All terminals of a given color shall be grouped with other terminals of the same color.

2.06 CONTROL POWER TRANSFORMERS

- A. Control power transformers shall be sized to handle in-rush currents and to accommodate continuous load of circuits plus 25 percent future load with 5 percent or less voltage drop. Transformer primary voltage shall be as indicated on Drawings.

2.07 Transient Voltage Surge Suppression (TVSS)

- A. Transient Voltage Surge Suppression (TVSS) device shall be installed at the main disconnect. TVSS shall be sized for the control panel feeder size and shall protect equipment from a peak surge of 45kA per mode and minimum 80kA peak surge per phase. Protection modes shall include phase to phase, and phase to ground for three phase panels, and shall include phase to neutral, phase to ground and neutral to ground for single phase panels. TVSS shall have a status LED indicating that it is operating properly.

PART 3 - EXECUTION

3.01 GENERAL

- A. Examination, Installation, Field Quality Control, Demonstration: In accordance with Section 13410.

END OF SECTION

SECTION 15000

MECHANICAL-GENERAL REQUIREMENTS

PART 1 - GENERAL

1.01 DESCRIPTION

A. Scope of Work:

1. All equipment furnished and installed under this contract shall conform to the general stipulations set forth in this section except as otherwise specified in other sections.
2. Contractor shall coordinate all details of equipment with other related parts of the Work, including verification that all structures, piping, wiring, and equipment components are compatible. Contractor shall be responsible for all structural and other alternations in the Work required to accommodate equipment differing in dimensions or other characteristics from that contemplated in the Contract Drawings or Specifications.

B. Related Work Described Elsewhere:

1. General Requirements: Division 1
2. Electrical: Division 16

C. General Design:

1. Contract Drawings and Specifications: The Contract Drawings and Specifications shall be considered as complementary, one to the other, so that materials and work indicated, called for, or implied by the one and not by the other shall be supplied and installed as though specifically called for by both. The Contract Drawings are to be considered diagrammatic, not necessarily showing in detail or to scale all of the equipment or minor items. In the event of discrepancies between the Contract Drawings and Specifications, or between either of these and any regulations or ordinances governing work of these specifications, the bidder shall notify the Engineer in ample time to permit revisions.

1.02 QUALITY ASSURANCE

- ###### A. Materials and Equipment: Unless otherwise specified, all materials and equipment furnished for permanent installation in the work shall conform to applicable

standards and specifications and shall be new, unused, and undamaged when installed or otherwise incorporated in the work. No such material or equipment shall be used by the Contractor for any purpose other than that intended or specified, unless such use is specifically authorized in writing by the Owner. No material shall be delivered to the work site prior to acceptance of drawings and data by the Engineer.

- B. Where applicable, Manufacturers shall be selected from one of the specified "Manufacturers" in the Orange County Utilities "List of Materials and Approved Manufacturers" as presented in an appendix to these technical specifications or approved equal.
- C. Equivalent Materials and Equipment:
 - 1. Whenever a material or article is specified or described by using the name of a proprietary product or the name of a particular manufacturer or vendor, the specific item mentioned shall be understood as establishing the type, function, and quality desired. Other manufacturers' products will be accepted provided sufficient information is submitted to allow the Engineer to determine that the products proposed are equivalent to those named. Such items shall be submitted for review in accordance with Section 01340: Shop Drawings, Working Drawings, and Samples.
 - 2. Requests for review of equivalency will not be accepted from anyone except the Contractor and such requests will not be considered until after the contract has been awarded.
- D. Governing Standards: Equipment and appurtenances shall be designed in conformity with ANSI, ASME, ASTM, IEEE, NEMA, OSHA, AGMA, and other generally accepted applicable standards. They shall be of rugged construction and of sufficient strength to withstand all stresses which may occur during fabrication, testing, transportation, installation, and all conditions or operations. All bearings and moving parts shall be adequately protected against wear by bushings or other acceptable means. Provisions shall be made for adequate lubrication with readily accessible means.
- E. Tolerances: Machinery parts shall conform to the dimensions indicated on the drawings within allowable tolerances. Protruding members such as joints, corners, and gear covers shall be finished in appearance. All exposed welds shall be ground smooth and the corners of structural shapes shall be rounded or chamfered.
- F. Clearances: Ample clearances shall be provided for inspection and adjustment. All equipment shall fit the allotted space and shall leave reasonable access room for servicing and repairs. Greater space and room required by substituted equipment shall be provided by the Contractor and at his expense.

G. Testing:

1. When the equipment is specified to be factory tested, the results of the tests shall be submitted to the Engineer and approval of the test results shall be obtained before shipment of the equipment.
2. When an item of equipment, including controls and instrumentation, has been completely erected, the Contractor shall notify the Engineer, who will designate a time to make such tests as required, and operate the item to the satisfaction of the Contractor. All testing shall be done in the presence of the Contractor. "Completely erected" shall mean that the installation is erected, all necessary adjustments have been made, all required utility connections have been made, required lubricants and hydraulic fluid have been added and the unit has been cleaned and painted.

H. Pressure Test:

1. After installation, all piping shall be pressure tested. Piping shall be tested in accordance with Section 15044.
2. All tests shall be made in the presence of and to the satisfaction of the Construction Manager and also, to the satisfaction of any local or state inspector having jurisdiction.
 - a. Provide not less than three days notice to the Construction Manager and the authority having jurisdiction when it is proposed to make the tests.
 - b. Any piping or equipment that has been left unprotected and subject to mechanical or other injury in the opinion of the Construction Manager shall be retested in part or in whole as directed by the Construction Manager.
 - c. The piping systems may be tested in sections as the work progresses by no joint or portion of the system shall be left untested.
3. All elements within the system that may be damaged by the testing operation shall be removed or otherwise protected during the operation.
4. All defects and leaks observed during the tests shall be corrected and made tight in an approved manner and the tests repeated until the system is proven tight.

5. Repair all damage done to existing or adjacent work or materials due to or on account of the tests.
6. Provide test pumps, gauges, or other instruments and equipment required for the performance of all tests. Provide all temporary bracing, test plugs, additional restraint, and thrust blocking which may be required for test pressures above normal working pressures.
7. All tests shall be maintained for as long a time as required to detect all defects and leaks but not less than the duration specified for each type of pipe or piping system in this Division.

I. Failure of Test:

1. Defects: Any defects in the equipment, or deviations from the guarantees or requirements of the Specifications, shall be promptly corrected by the Contractor by replacements or otherwise. The decision of the Engineer as to whether or not the Contractor has fulfilled his obligations under the Contract shall be final and conclusive. If the Contractor fails to correct any defects or deviations, or if the replaced equipment when tested shall fail again to meet the guarantees or specified requirements, the Owner, notwithstanding his having made partial payment for work and materials which have entered into the manufacturer for such equipment, may reject that equipment and order the Contractor to remove it from the premises at the Contractor's expense.
2. Rejection of Equipment: In case the Owner rejects a particular item of equipment, then the Contractor hereby agrees to repay to the Owner all sums of money paid to him to deliver to the Contractor a bill of sale of all his rights, title, and interest in and to the rejected equipment provided, however that the equipment shall not be removed from the premises until the Owner obtains from other sources other equipment to take the place of that rejected. The bill of sale shall not abrogate the Owner's right to recover damages for delays, losses or other conditions arising out of the basic Contract. The Owner hereby agrees to obtain the alternate equipment within a reasonable time and the Contractor agrees that the Owner may use the original equipment furnished by him without rental or other charge until the other equipment is obtained.

J. Responsibility During Tests: The Contractor shall be fully responsible for the proper operation of equipment during tests and instruction periods and shall neither have nor make any claim for damage which may occur to equipment prior to the time when the Owner formally takes over the operation thereof.

K. Acceptance of Materials:

1. Only new materials and equipment shall be incorporated in the work. All materials and equipment furnished by the Contractor shall be subject to the inspection and acceptance of the Owner. No material shall be delivered to the work without prior submittal approval of the Engineer.
2. The Contractor shall submit to the Engineer data relating to materials and equipment he proposes to furnish for the work. Such data shall be in sufficient detail to enable the Engineer to identify the particular product and to form an opinion as to its conformity to the specifications.
3. Facilities and labor for handling and inspection of all materials and equipment shall be furnished by the Contractor. If the Engineer requires, either prior to beginning or during the progress of the work, the Contractor shall submit samples of materials for such special test as may be necessary to demonstrate that they conform to the specification. Such sample shall be furnished, stored, packed, and shipped as directed at the Contractor's expense. Except as otherwise noted, the Owner will make arrangements for and pay for tests.
4. The Contractor shall submit data and samples sufficiently early to permit consideration and acceptance before materials are necessary for incorporation in the work.

L. Safety Requirements:

1. In addition to the components shown and specified, all machinery and equipment shall be safeguarded in accordance with the safety features required by the current codes and regulations of ANSI, OSHA, and local industrial codes.
2. The Contractor shall provide for each V-belt drive or rotating shaft a protective guard which shall be securely bolted to the floor or apparatus. The guard shall completely enclose drives and pulleys and be constructed to comply with all safety requirements.
3. For double inlet fans, the belt guard shall be arranged so as not to restrict the air flow into the fan inlet. Guards shall not interfere with lubrication of equipment.

1.03 SUBMITTALS (SEE SECTION 01340: SHOP DRAWINGS, WORKING DRAWINGS AND SAMPLES)

1.04 PRODUCT DELIVERY, STORAGE AND HANDLING

- A. Packaging: All equipment shall be suitably packaged to facilitate handling and protect against damage during transit and storage. All equipment shall be boxed, crated, or otherwise completely enclosed and protected during shipment, handling, and storage. All equipment shall be protected from exposure to the elements and shall be kept thoroughly dry at all times.
- B. Protection: All machined surfaces and shafting shall be cleaned and protected from corrosion by the proper type and amount of coating necessary to assure protection during shipment and prior to installation. Painted surfaces shall be protected against impact, abrasion, discoloration, and other damage as specified in Sections 09900 and 09905. All painted surfaces which are damaged prior to acceptance of equipment shall be repainted to the satisfaction of Engineer.
- C. Lubrication: Grease and lubricating oil shall be applied to all bearings and similar items as necessary to prevent damage during shipment and storage.
- D. Marking: Each item of equipment shall be tagged or marked as identified in the delivery schedule or on the Shop Drawings. Complete packing lists and bills of material shall be included with each shipment.
- E. Fabricated sub-assemblies, if any, shall be shipped in convenient sections as permitted by carrier regulations and shall be properly match-marked for ease of field erection.
- F. Responsibility:
 - 1. The Contractor shall be responsible for all material, equipment, and supplies sold and delivered to the site under this Contract until final inspection of the work and acceptance thereof by the Owner. In the event any such material, equipment, and supplies are lost, stolen, damaged, or destroyed prior to final inspection and acceptance, the Contractor shall replace same without additional cost to the Owner.
 - 2. Should the Contractor fail to take proper action on storage and handling of equipment supplied under this Contract within seven days after written notice to do so has been given, the Owner retains the right to correct all deficiencies noted in previously transmitted written notice and deduct the cost associated with these corrections from the Contractor's Contract. These costs may be comprised of expenditures for labor, equipment usage, administrative, clerical, engineering, and any other costs associated with making the necessary corrections.
- G. Delivery: The Contractor shall arrange deliveries of products in accordance with construction schedules and coordinate to avoid conflict with work and condition at the site.

1. The Contractor shall deliver products in undamaged condition, in manufacturer's original containers or packaging, with identifying labels intact and legible.
2. Immediately on delivery, the Contractor shall inspect shipments to assure compliance with requirements of Contract Documents and accepted submittals, and that products are properly protected and undamaged.
3. Under no circumstances shall the Contractor deliver equipment to the site more than one month prior to installation without written authorization from the Construction Manager. Operation and maintenance data shall be submitted to the Engineer for review prior to shipment of equipment as described in Section 01730: Operating and Maintenance Data.

H. Storage and Protection of Products:

1. The Contractor shall furnish a covered, weather-protected storage structure providing a clean, dry noncorrosive environment for all mechanical equipment, valves, architectural items, electrical and instrumentation equipment, and special equipment to be incorporated into this project. Storage of equipment shall be in strict accordance with the "Instructions for Storage" of each equipment supplier and manufacturer including connection of space heaters, and placing of storage lubricants in equipment. Corroded, damaged, or deteriorated equipment and parts shall be replaced before acceptance of the project. Equipment and materials not properly stored will not be included in a payment estimate.
 - a. The Contractor shall store products subject to damage by the elements in weathertight enclosures.
 - b. The Contractor shall maintain temperature and humidity within the ranges required by manufacturer's instructions.
 - c. The Contractor shall store fabricated products above the ground, on blocking or skids, to prevent soiling or staining. The Contractor shall cover products which are subject to deterioration with impervious sheet coverings and provide adequate ventilation to avoid condensation.
 - d. The Contractor shall store loose granular materials in a well drained area on solid surfaces to prevent mixing with foreign matter.

2. All materials and equipment to be incorporated in the work shall be handled and stored by the Contractor before, during, and after shipment in a manner to prevent warping, twisting, bending, breaking, chipping, rusting, and any injury, theft, or damage of any kind whatsoever to the material or equipment.
 3. Cement, sand, lime shall be stored under a roof and off the ground, and shall be kept completely dry at all times. All structural and miscellaneous steel and reinforcing steel shall be stored off the ground or otherwise to prevent accumulations of dirt, or grease, and in a position to prevent accumulations of standing water, staining, chipping, or cracking. Brick, block, and similar masonry products shall be handled and stored in a manner to reduce breakage, chipping, cracking and peeling to a minimum.
 4. All materials which, in the opinion of the Construction Manager, have become damaged and are unfit for the use intended or specified, shall be promptly removed from the site of the work, and the Contractor shall receive no compensation for the damaged material or its removal.
 5. The Contractor shall arrange storage in a manner to provide easy access for inspection. The Contractor shall make periodic inspections of stored products to assure products are maintained under specified conditions, and free from damage or deterioration.
 6. Protection After Installation: The Contractor shall provide substantial coverings as necessary to protect installed products from damage from traffic and subsequent construction operations. The Contractor shall remove covering when no longer needed.
- I. Extended Storage Requirements For Equipment: Because of the long period allowed for construction, special attention shall be given to extended storage and handling of equipment onsite. As a minimum, the procedure specified herein shall be followed:
1. If equipment will be stored onsite for more than one month prior to incorporation into the Work, the Contractor shall submit a written request to the Construction Manager outlining any special provision to be made to protect and maintain the equipment while it is being stored. All such provisions shall be acceptable to the Construction Manager. No equipment shall be stored onsite for more than one month without prior written authorization from the Construction Manager.
 2. All equipment having moving parts including gears, electric motors, and/or instruments shall be stored in a temperature and humidity

controlled building accepted by the Construction Manager, until such time as the equipment is to be installed.

3. All equipment shall be stored fully lubricated with oil and grease unless otherwise instructed by the manufacturer.
4. Manufacturer's storage instructions shall be carefully studied by the Contractor and reviewed by him with the Construction Manager. These instructions shall be carefully followed and a written record of this review kept by the Contractor.
5. Moving parts shall be rotated a minimum of once weekly to ensure proper lubrication and to avoid metal-to-metal "welding". Upon installation of the equipment, the Contractor shall start the equipment, and operate loaded when possible, weekly for an adequate period of time to ensure that the equipment does not deteriorate from lack of use.
6. Lubricants shall be changed upon completion of installation and as frequently as required thereafter during the period between installation and acceptance. Mechanical equipment to be used in the work, if stored for longer than ninety days, shall have the bearings cleaned, flushed, and lubricated prior to testing and startup, at no extra cost to the Owner.
7. Prior to acceptance of the equipment, the Contractor shall have the manufacturer inspect the equipment and certify that its condition has not been detrimentally affected by the long storage period. Such certifications by the manufacturer shall be deemed to mean that the equipment is judged by the manufacturer to be in a condition equal to that of equipment that has been shipped, installed, tested, and accepted in a minimum time period. As such, the manufacturer will guarantee the equipment equally in both instances. If such a certification is not given, the equipment shall be judged to be defective, and it shall be removed and replaced at the Contractor's expense.
8. A maintenance log shall be maintained by the Contractor outlining the schedule of maintenance required for each piece of equipment as well as the date on which the maintenance was actually performed and the initials of the individual performing the work. Submit a copy of the maintenance log monthly with the progress pay application.

1.05 WARRANTY AND GUARANTEES

- A. The manufacturer's written warranty shall be submitted for all major pieces of equipment, as specified in Section 01740: Warranties and Bonds. The

manufacturer's warranty period shall be concurrent with the Contractor's correction period for one year after the time of completion and acceptance.

PART 2 - PRODUCTS

2.01 GENERAL

- A. All materials that come into contact with the water being treated or the finished water shall be on either the EPA or NSF lists of products approved for use in contact with potable water. Manufacturers shall submit an affidavit with the shop drawings indicating approval by the EPA or NSF for the materials used in products that come into contact with the water, in accordance with Rule 62-555.320(3) Florida Administrative Code.

2.02 MATERIALS AND EQUIPMENT

A. Fabrication and Manufacture:

1. Workmanship and Materials:

- a. Contractor shall guarantee all equipment against faulty or inadequate design, improper assembly or erection, defective workmanship or materials, and leakage, breakage or other failure. Materials shall be suitable for service conditions.
- b. All equipment shall be designed, fabricated, and assembled in accordance with recognized and acceptable engineering and shop practice. Individual parts shall be manufactured to standard sizes and gages so that repair parts, furnished at any time, can be installed in the field. Like parts of duplicate units shall be interchangeable. Equipment shall not have been in service at any time prior to delivery, except as required by tests.
- c. Except where otherwise specified, structural and miscellaneous fabricated steel used in equipment shall conform to AISC standards. All structural members shall be designed for shock or vibratory loads. Unless otherwise specified, all steel which will be submerged, all or in part, during normal operation of the equipment shall be at least 1/4 inch thick.

2. Lubrication:

- a. Equipment shall be adequately lubricated by systems which require attention no more frequently than weekly during continuous

operation. Lubrication systems shall not require attention during startup or shutdown and shall not waste lubricants.

- b. Lubricants of the type recommended by the equipment manufacturer shall be furnished by the Contractor in sufficient quantity to fill all lubricant reservoirs and to replace all consumption during testing, startup, and operation prior to acceptance of equipment by Owner. Unless otherwise specified or permitted, the use of synthetic lubricants will not be acceptable.
 - c. Lubrication facilities shall be convenient and accessible. Oil drains and fill openings shall be easily accessible from the normal operating area or platform. Drains shall allow for convenient collection of waste oil in containers from the normal operating area or platform without removing the unit from its normal installed position.
3. Safety Guards: All belt or chain drives, fan blades, couplings, and other moving or rotating parts shall be covered on all sides by a safety guard. Safety guards shall be fabricated from 16 USS gage or heavier galvanized or aluminum-clad sheet steel or 1/2 inch mesh galvanized expanded metal. Each guard shall be designed for easy installation and removal. All necessary supports and accessories shall be provided for each guard. Supports and accessories, including bolts, shall be galvanized. All safety guards in outdoor locations shall be designed to prevent the entrance of rain and dripping water.
4. Equipment Foundation Supports:
 - a. All foundations, platforms and hangers required for the proper installation of equipment shall be furnished and installed by the Contractor.
 - b. Unless otherwise indicated or specified, all equipment shall be installed on reinforced concrete bases at least 6 inches high and shall conform to Section 03300. Cast iron or welded steel baseplates shall be provided for pumps, compressors, and other equipment. Each unit and its drive assembly shall be supported on a single baseplate of neat design. Baseplates shall have pads for anchoring all components and adequate grout holes. Baseplates for pumps shall have a means for collecting leakage and a threaded drain connection. Baseplates shall be anchored to the concrete base with suitable anchor bolts and the space beneath filled with grout as specified in Section 03600: Grout. All open equipment bases

shall be filled with nonshrinking grout sloped to drain to the perimeter of the base.

- c. The Contractor shall furnish, install and protect all necessary guides, bearing plates, anchor and attachment bolts, and all other appurtenances required for the installation of equipment. These shall be of ample size and strength for the purpose intended.
- d. Equipment suppliers shall furnish suitable anchor bolts for each item of equipment. Anchor bolts, together with templates or setting drawings, shall be delivered sufficiently early to permit setting the anchor bolts when the structural concrete is placed. Anchor bolts shall comply with Section 05500: Miscellaneous Metals and, unless otherwise specified, shall have a minimum diameter of 3/4 inch. Unless otherwise indicated or specified, anchor bolts for items of equipment mounted on baseplates shall be long enough to permit 1-1/2 inches of grout beneath the baseplate and to provide adequate anchorage into structural concrete.
- e. Structural steel supports and miscellaneous steel required for supporting and/or hanging equipment and piping furnished under this Division shall be provided and installed by Contractor.
- f. All foundations, anchor pads, piers, thrust blocks, inertia blocks and structural steel supports shall be built to template and reinforced as required for loads imposed on them.
- g. The Contractor shall assume all responsibility for sizes, locations and design of all foundations, anchor pads, pier, thrust blocks, inertia blocks, curbs and structural steel supports.

5. Shop Painting:

- a. All steel and iron surfaces shall be protected by suitable paint or coatings applied in the shop. Surfaces which will be inaccessible after assembly shall be protected for the life of the equipment. Exposed surfaces shall be finished smooth, thoroughly cleaned, and filled as necessary to provide a smooth uniform base for painting. Electric motors, speed reducers, starters, and other self-contained or enclosed components shall be shop primed or finished with a high-grade oil resistant enamel suitable for coating in the field with an alkyd enamel. Coatings shall be suitable for the environment where the equipment is installed.

- b. Surfaces to be painted after installation shall be prepared for painting as recommended by the paint manufacturer for the intended service, and then shop painted with one or more coats of the specified primer. Unless otherwise specified, the shop primer for steel and iron surfaces shall be Cook "391-N-167 Barrier Coat", Koppers "No. 10 Inhibitive Primer", or equal.
 - c. Machined, polished, and nonferrous surfaces which are not to be painted shall be coated with rust-preventive compound, Houghton "Rust Veto 344", Rust-Oleum "R-9", or equal.
 - 6. Nameplates: Contractor shall provide equipment identification nameplates for each item of equipment. Nameplates shall be 1/8-inch Type 304 stainless steel and shall be permanently fastened. Plates shall be fastened using round head metallic drive screws, or where metallic drive screws are impractical, with stainless steel pop rivets. Metallic drive screws shall be brass or stainless steel, Type V and No. 8 by 3/8-inch long. Names and/or equipment designations shall be engraved on the plates and the engraving painted with a primer and black paint system compatible with stainless steel. Contractor shall submit a list of proposed names and designations for review prior to fabrication of nameplates. At a minimum, each nameplate shall include equipment manufacturers name, year of manufacture, serial number and principal rating data.
- 7. Pipe Identification:
 - a. All pipe (except underground) shall have code letters and flow arrows painted as per specification Section 09905. The contractor shall ensure that the pipes are properly marked.
 - b. Underground pipe and tube: Pipe and tube shall be located by laying 2-inch wide plastic tape continuously along the run of pipe or tube. Where possible, color of tape shall be consistent with the color of bands on interior pipe and as approved by the Engineer, or shall bear an imprinted identification of the line.
 - i. Location: Tape shall be laid approximately 12 inches below ground surface and directly over pipe location.
 - ii. Manufacturer: Tape shall be as specified in Section 09905.
- 8. Valve Identification: On all valves, except shut-off valves located at a fixture or piece of equipment, the Contractor shall provide a coded and numbered tag attached with brass chain and/or brass "S" hooks.

- a. Tag Types:
 - i. Tags for valves on pipe and tube lines conducting hot medium (steam, condensate, hot water, etc.) shall be brass or anodized aluminum.
 - ii. Tags for all other valves shall be Type 304 stainless steel.
 - iii. Square tags shall be used to indicate normally closed valves and round tags shall indicate normally open valves.
- b. Coding: In addition to the color coding, each tag shall be stamped or engraved with wording or abbreviations to indicate the line service. All color and letter coding shall be approved by the Engineer.
- c. Valve Schedule: The Contractor shall provide a typewritten list of all tagged valves giving tag shape, letter code and number, the valve size, type, use and general location within building.

9. Fire Hazard Rating:

- a. All piping, duct work, and equipment insulation, fastener, and jacketing materials shall have a fire hazard rating not to exceed 25 for flame spread, 50 for fuel contributed, and 50 for smoke developed. Rating shall be determined by ASTM Designation E84, "Surface Burning Characteristics of Building Materials". Corresponding ratings determined by Underwriters' Laboratories, Inc., UL-723, "Test Method for Fire Hazard Classification of Building Materials", will also be acceptable.
- b. Flameproofing treatments will not be acceptable.

10. Heating, Ventilation and Domestic Plumbing Equipment:

- a. Interchangeability: In all design and purchasing, interchangeability of items of equipment, subassemblies, parts, motors, starters, relays, and other items is essential. All similar items shall be of the same manufacturer, type, model, and dimensions.

2.03 ACCESSORIES

- A. Special Tools and Accessories: Equipment requiring periodic repair and adjustment shall be furnished complete with all special tools, instruments, and

accessories required for proper maintenance. Equipment requiring special devices for lifting or handling shall be furnished complete with those devices.

2.04 SPARE PARTS

- A. Spare parts for certain equipment provided under Divisions 11, 13, 14, 15, and 16 have been specified in the pertinent sections of the specifications. The Contractor shall collect and store all spare parts in an area to be designated by the Engineer. In addition, the Contractor shall furnish to the Engineer an inventory listing of all spare part, the equipment they are associated with, and the name and address of the supplier.
- B. Maintenance Materials:
 - 1. All grease, oil, and fuel required for testing of equipment shall be furnished with the respective equipment. The Owner shall be furnished with a year's supply of required lubricants including grease and oil of the type recommended by the manufacturer with each item of equipment supplied.
 - 2.. The Contractor shall be responsible for changing the oil in all drives and intermediate drives of each mechanical equipment after initial break-in of the equipment, which in no event shall be any longer than three weeks of operation.

2.05 QUALITY CONTROL

- A. Contractor shall follow Manufacturer's and Supplier's recommended product quality control specifics as required for project.

PART 3 - EXECUTION

3.01 PREPARATION (Not Applicable)

3.02 INSTALLATION

- A. Installation: Equipment shall not be installed or operated except by, or with the guidance of, qualified personnel having the knowledge and experience necessary for proper results. When so specified, or when employees of Contractor or his subcontractors are not qualified, such personnel shall be field representatives of the manufacturer of the equipment or materials being installed.
 - 1. The Contractor shall have on site sufficient proper construction equipment and machinery of ample capacity to facilitate the work and to handle all

emergencies normally encountered in work of this character. To minimize field erection problems, mechanical units shall be factory assembled when practical.

2. Equipment shall be erected in a neat and workmanlike manner on the foundations and supports at the locations and elevations shown on the Drawings, unless otherwise directed by the Engineer during installation.
 3. All equipment shall be installed in such a manner as to provide access for routine maintenance including lubrication.
 4. For equipment such as pumping units, which require field alignment and connections, the Contractor shall provide the services of the equipment manufacturer's qualified mechanic, millwright, machinist, or authorized representative, to align the pump and motor prior to making piping connections or anchoring the pump base.
 5. Equipment of a portable nature which require no installation shall be delivered to a location designated by the Owner.
- B. Tolerances: Precision gauges and levels shall be used in setting all equipment. All piping and equipment shall be perfectly aligned, horizontally and vertically. Tolerances for piping and equipment installation shall be 1/2 inch to 30 ft horizontal and vertically. All valves and operators shall be installed in the position shown on the Contract Drawings or as directed by the Engineer, if not shown.
- C. Alignment and Level: The equipment shall be brought to proper level by shims (1/4 inch maximum). After the machine has been leveled and aligned, the nuts on the anchor bolts shall be tightened to bind the machine firmly into place against the wedges or shims. Grouting shall be as specified in Section 03600: Grout.
- D. Grouting: The grout shall be tamped into position with a board, steel bar, or other tool. Tamping should not be so hard as to raise or otherwise displace the plate.
- E. Contact of Dissimilar Metals: Where the contact of dissimilar metal may cause electrolysis and where aluminum will contact concrete, mortar, or plaster, the contact surface of the metals shall be separated using not less than one coat of zinc chromate primer and one heavy coat of aluminum pigmented asphalt paint on each surface.
- F. Cutting and Patching: All cutting and patching necessary for the work shall be performed by the Contractor.
- G. Operation: All equipment installed under this Contract, including that furnished by Owner or others under separate contract, shall be placed into successful

operation according to the written instructions of the manufacturer or the instructions of the manufacturer's field representative. All required adjustments, tests, operation checks, and other startup activity shall be provided.

3.03 INSPECTION AND TESTING

- A. Where the specifications require observation of performance tests by the Construction Manager, such tests shall comply with the quality assurance paragraph in this section.

3.04 START-UP AND INSTRUCTION

- A. Services Furnished Under This Contract:

1. An experienced, competent, and authorized representative of the manufacturer of each item of equipment shall visit the site of the Work and inspect, check, adjust if necessary, and approve the equipment installation. In each case, the manufacturer's representative shall be present when the equipment is placed in operation. The manufacturer's representative shall revisit the jobsite as often as necessary until all trouble is corrected and the equipment installation and operation are satisfactory in the opinion of Construction Manager.
2. Each manufacturer's representative shall furnish to Owner, Construction Manager, a letter of certification stating that the equipment has been properly installed and lubricated; is in accurate alignment; is free from any undue stress imposed by connecting piping or anchor bolts; and has been operated under full load conditions and that it operated satisfactorily.
3. All costs for field services shall be included in the contract amount.

END OF SECTION

SECTION 16050 - BASIC ELECTRICAL REQUIREMENTS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: General administrative, procedural requirements, and installation methods for electrical installations specified in Division 16.
- B. The Drawings are schematic and are not intended to show every detail of construction.
 - 1. In general, conduits/raceways, transitions and offsets shown on Drawings indicate approximate locations in plan and elevation where the systems are intended to be run.
 - 2. CONTRACTOR shall fully coordinate electrical Work with other trades to avoid interferences.
 - 3. In the event of interferences, CONTRACTOR shall request clarification from ENGINEER in writing.
- B. Related Documents: Drawings and general provisions of Contract, including General and Supplementary Conditions and Division 1 Sections, apply to Work of this Section.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with requirements of Section 01340, Shop Drawings covering the items included under this Section of Work. Shop Drawing submittals shall include:
 - 1. Submit product data covering the items included under this Section of Work.
- B. Conforming to Construction Drawings: Submit a complete set of Drawings showing the locations of the piping, ductwork, etc., as actually installed. Such Drawings shall be submitted to ENGINEER in PDF format.
- C. Operation and Maintenance Manuals: Submit in accordance with requirements of Section 01730, Operation and Maintenance Manuals for items included under this Section. Include following information for equipment items:
 - 1. Description of function, normal operating characteristics and limitations, performance curves, engineering data and tests, and complete nomenclature and commercial numbers of replacement parts.
 - 2. Manufacturer's printed operating procedures to include start-up, break-in, and routine and normal operating instructions; regulation, control, stopping, shutdown, and emergency instructions; and summer and winter operating instructions.
 - 3. Maintenance procedures for routine preventative maintenance and troubleshooting; disassembly, repair, and reassembly; aligning and adjusting instructions.
 - 4. Servicing instructions and lubrication charts and schedules.

1.03 RECORD DOCUMENTS

- A. Prepare Record Documents in accordance with requirements in Section 01720. In addition, CONTRACTOR shall submit, prior to final payment, Drawings conforming to construction records of systems it has installed. Vendor drawings shall be sized as manufacturers' standard.

1.04 QUALITY ASSURANCE

- A. National Electrical Code: Comply with NFPA 70, National Electrical Code.
- B. UL Compliance and Labeling: Use products and components labeled by UL.

1.05 PERMITS, INSPECTIONS, AND LICENSES

- A. CONTRACTOR shall procure all necessary permits and licenses, observe and abide by all applicable laws, codes, regulations, ordinances, and rules of the State, territory, or political subdivision thereof, wherein Work is done, or any other duly constituted public authority, and further agrees to hold OWNER harmless from liability or penalty which might be imposed by reason of an asserted violation of such laws, codes, regulations, ordinances, or other rules.
 - 1. Upon completion of Work, CONTRACTOR shall secure certificates of inspection from the inspector having jurisdiction and shall submit 3 copies of the certificates to OWNER. CONTRACTOR shall pay the fees for the permits, inspections, licenses, and certifications when such fees are required.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to Project properly identified with names, model numbers, types, grades, compliance labels, and other information needed for identification. Equipment shall be packaged to prevent damage during shipment, storage, and handling. Do not install damaged units; replace, and remove damaged units from Site.

PART 2 - PRODUCTS

2.01 AMMETER

NOT USED

PART 3 - EXECUTION

3.01 GENERAL ELECTRICAL INSTALLATION

- A. Provide electrical materials and equipment enclosures appropriate for areas in which they are installed. Each area will be designated on Drawings with a type of construction such as NEMA 4, 4X, 7 or 9 if it is other than NEMA 12. An area designated by a name and elevation includes space bounded by floor, ceiling, and enclosing walls.
 - 1. Exception: Provide manufacturer's standard construction for indoor or outdoor application where equipment is not manufactured to NEMA specifications (e.g., switchgear, transformers, high voltage capacitors, bus duct, and light fixtures; materials and equipment used in finished areas such as offices, laboratories, etc.).

- B. Provide nonmetallic electrical materials and equipment enclosures in NEMA 4X areas; watertight NEMA 4 and equipment enclosures for outdoor applications and indoor applications below grade; explosion-proof NEC Class I, Division 1, Group D equipment for NEMA 7 areas; explosion-proof NEC Class II, Division 2, Group F equipment for NEMA 9 areas.

- C. Where mounting heights are not detailed or dimensioned, install systems, materials, and equipment to provide maximum headroom possible.

- D. Install systems, materials, and equipment to conform with approved submittal data, including coordination Drawings, to greatest extent possible. Conform to arrangements indicated by Drawings recognizing that portions of Work are shown only in diagrammatic form. Where coordination requirements conflict with individual system requirements, refer conflict to ENGINEER.

- E. Install systems, materials, and equipment level and plumb, parallel and perpendicular to other building systems and components where installed exposed in finished spaces.

- F. As much as practical, connect equipment for ease of disconnecting with minimum of interference with other installations.

- G. Install systems, materials, and equipment giving right-of-way priority to systems required to be installed at a specified slope.

3.02 RACEWAY INSTALLATION

- A. Outdoors, use the following materials:
 1. Exposed Conduit: Rigid Schedule 40 PVC conduit.
 2. Underground Direct Buried Conduit: Rigid Schedule 40 PVC conduit.
 3. Conduit Used to Connect to Vibrating Equipment including transformers and hydraulic, pneumatic or electric solenoid or motor-driven equipment: Liquidtight flexible metal conduit.

- B. Indoors, use the following wiring materials:
 1. Connection to Vibrating Equipment, including transformers and hydraulic, pneumatic or electric solenoid or motor-operated equipment: Liquidtight flexible metal conduit.
 2. Exposed Conduit: Rigid Schedule 40 PVC conduit..
 3. Concealed Conduit: Rigid Schedule 40 PVC conduit.

- C. Minimum size conduit shall be 3/4 inch unless shown otherwise.

- D. Instrument Signal Conduit Requirements: Shielded signal wires for 4-20 mA type instruments or thermocouple wires assigned to the same control panel may be run in the same conduit. Shielded instrument signal wires, thermocouple wires, and shielded 2-wire intercom wires may be run in the same conduit. No other wires will be permitted in an instrument signal/2-wire intercom conduit. Conduit shall be PVC.

- E. Install expansion fittings in all exposed rigid nonmetallic conduit runs of 20 feet or more.
- F. Install expansion/deflection fittings where conduit passes a building expansion joint or where conduits are attached to two structures joined by a concrete expansion joint.
- G. Exposed or Concealed Construction: Install conduit exposed inside buildings except for areas with finished walls (e.g., offices, laboratories, lavatories, locker rooms, etc.) unless otherwise indicated.
- H. Exposed Raceways: Install parallel and perpendicular to nearby surfaces or structural members and follow the surface contours as much as practical. Make bends and offsets so the inside diameter is not effectively reduced. Keep the legs of a bend in the same plane and the straight legs of offsets parallel. Conduits shall slope away from loads to keep moisture from entering the load. Run parallel or banked raceways together. Make bends in parallel or banked runs from the same centerline so that the bends are parallel. Factory elbows may be used in banked runs only where they can be installed parallel. This requires that there be a change in the plane of the run, such as from wall to ceiling and that the raceways be of the same size. In other cases, provide field bends for parallel raceways. Keep raceways at least 6 inches away from parallel runs of flues and steam or hot water pipes. Install horizontal raceway runs above water and steam piping.
- I. Space raceways, fittings, and boxes 0.25 inch from mounting surface in NEMA 4 and NEMA 7 areas. Spacers shall be one-piece construction of stainless steel, galvanized steel, PVC, ABS, or other noncorrosive material.
- J. Sleeves: Install in concrete floor slabs except where conduit passes through a housekeeping pad. Install in exterior walls below grade.
- K. Flexible Connections: Use short length (maximum 3 feet for all other equipment) of flexible conduit for equipment subject to vibration, noise transmission, or movement, and all motors. Use liquidtight flexible conduit in wet locations and rated flexible connections for hazardous locations. Install separate ground conductor across flexible connections.
- L. Join raceways with fittings designed and approved for the purpose and make joints tight. Where joints cannot be made tight, use bonding jumpers to provide electrical continuity of the raceway system. Where terminations are subject to vibration, use bonding bushings or wedges to assure electrical continuity. Where subject to vibration or dampness, use insulating bushings to protect conductors.
- M. Use raceway fittings that are of types compatible with the associated raceway and suitable for the use and location.
- N. Install raceway sealing fittings in accordance with the manufacturer's written instructions. Locate fittings at suitable, approved, accessible locations and fill them with UL listed sealing compound. For concealed raceways, install each fitting in a flush metal box with a blank cover plate having a finish similar to that of adjacent plates or surfaces. Install raceway sealing fittings at the following points and elsewhere as indicated:
 1. Where conduits enter or leave hazardous locations.
 2. Where conduits enter or leave NEMA 4X areas.

3. Where conduits pass from warm locations to cold locations, such as the boundaries of refrigerated spaces and air-conditioned spaces.
 4. Where required by the NEC.
- O. Install electrical boxes in those locations which ensure ready accessibility to enclosed electrical wiring. Provide knockout closures to cap unused knockout holes where blanks have been removed.
- P. Provide fire-retardant barriers in all pull and junction boxes containing circuits that are otherwise continuously separated in conduit. Securely fasten these barriers within box. Size barriers so that space between barrier and box wall does not exceed 0.125 inch anywhere around the perimeter of barrier.
- Q. Support exposed raceway within 1 foot of an unsupported box and access fittings. In horizontal runs, support at box and access fittings may be omitted where box or access fittings are independently supported and raceway terminals are not made with chase nipples or threadless box connectors.
- R. In open overhead spaces, cast boxes threaded to raceways need not be supported separately except where used for fixture support; support sheet metal boxes directly from building structure.
- S. Terminations: Where raceways are terminated with locknuts and bushings, align the raceway to enter squarely and install the locknuts with dished part against the box. Where terminating in threaded hubs, screw the raceway or fitting tight into the hub so the end bears against the wire protection shoulder. Where chase nipples are used, align the raceway so the coupling is square to the box and tighten the chase nipples so no threads are exposed.
- T. Complete installation of electrical raceways before starting installation of conductors within raceways and prevent foreign matter from entering raceways by using temporary closure protection. Cap spare conduit.
- U. Install pull wires in empty raceways: Use No. 14 AWG zinc-coated steel or monofilament plastic line having not less than 200-pound tensile strength. Leave not less than 12 inches of slack at each end of the pull wire.

3.03 WIRE AND CABLE INSTALLATION

- A. Use pulling means including fish tape, cable, rope, and basket weave wire/cable grips which will not damage cables or raceways. Pull conductors simultaneously where more than one is being installed in same raceway. Use UL listed pulling compound or lubricant where necessary.
- B. Keep branch circuit conductor splices to minimum. Splice feeders only where indicated. Use a standard kit. No splices are allowed for instrument and telephone cables except at indicated splice points.
- C. Install splice and tap connectors which possess equivalent or better mechanical strength and insulation rating than conductors being spliced. Use splice and tap connectors which are compatible with conductor material and are UL listed as pressure type connectors.

- D. Provide adequate length of conductors within electrical enclosures and train conductors to terminal points with no excess. Bundle multiple conductors, with conductors larger than No. 10 AWG cabled in individual circuits. Make terminations so there is no bare conductor at terminal.
- E. Terminate power conductors at equipment using pressure-type terminals specifically designed for type of terminations to be made. Terminate no more than 2 conductors No. 8 AWG and smaller within the same pressure-type terminal. These 2 conductors shall be no more than 4 wire gauge sizes apart. Terminate no more than 1 conductor larger than No. 8 AWG within any pressure-type terminal.
- F. Seal wire and cable ends until ready to splice or terminate.

3.04 CUTTING AND PATCHING

- A. Perform cutting and patching in accordance with requirements in Section 02220. In addition, the following requirements apply.
 - 1. Perform cutting, fitting, and patching of electrical equipment and materials required to uncover Work to provide for installation of ill-timed Work, remove and replace Work that is either defective or does not conform to requirements of Drawings.
 - 2. Cut, remove, and legally dispose of selected electrical equipment, components, and materials as indicated including, but not limited to, removal of electrical items indicated to be removed and items made obsolete by new Work. Protect structure, furnishings, finishes, and adjacent materials not indicated or scheduled to be removed. Provide and maintain temporary partitions or dust barriers adequate to prevent spread of dust and dirt to adjacent areas.
 - 3. Patch existing finished surfaces and building components using new materials matching existing materials.

3.05 EQUIPMENT CHECKOUT AND TESTING

- A. In addition to testing recommended by equipment or material supplier and called for in equipment or material specification, perform the following.
- B. Equipment Testing: The following tests which are applicable for a particular item of equipment shall be performed:
 - 1. Megger power circuit breakers and circuits supplied phase-to-phase and phase-to-ground (100 megohms minimum).
 - 2. After Work has been completed, demonstrate to OWNER's Representative that entire electrical installation is in proper working order and will perform functions for which it was designed by functional testing.
 - 3. Make any specific tests required by the manufacturer's installation instructions.
- C. Check-out Procedures. In general, check-out procedures (as listed below) which are applicable for a particular item of equipment shall be performed:
 - 1. Vacuum interior of electrical equipment and remove foreign material.
 - 2. Wipe clean with a lint-free cloth insulators, bushings, bus supports, etc.

3. Check and adjust time delay, under-voltage devices, phase relay, over-current relays, etc., as required by coordination study or ENGINEER.
4. Check exposed bolted power connections for tightness.
5. Check operation of breakers, contactors, etc., and control and safety interlocks.
6. Check tightness of bolted structural connections.
7. Check leveling and alignment of enclosures.
8. Check tightness and correctness of control connections at terminal blocks, relays, meters, switches, etc.
9. Clean auxiliary contacts and exposed relay contacts after vacuuming.

END OF SECTION

SECTION 16060 - GROUNDING

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Electrical grounding and bonding Work as follows:
 - 1. Solidly grounded.

- B. Applications of electrical grounding and bonding Work in this Section:
 - 1. Metal building frames.
 - 2. Electrical power systems.
 - 3. Grounding electrodes.
 - 4. Separately derived systems.
 - 5. Raceways.
 - 6. Service equipment.
 - 7. Enclosures.
 - 8. Equipment.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
 - 1. Product Data: Submit manufacturer's data on grounding and bonding products and associated accessories.

1.03 QUALITY ASSURANCE

- A. Codes and Standards:
 - 1. UL Compliance: Comply with applicable requirements of UL Standards No. 467, "Electrical Grounding and Bonding Equipment," and No. 869, "Electrical Service Equipment," pertaining to grounding and bonding of systems, circuits, and equipment. In addition, comply with UL Standard 486A, "Wire Connectors and Soldering Lugs for Use with Copper Conductors." Provide grounding and bonding products which are UL listed and labeled for their intended usage.
 - 2. IEEE Compliance: Comply with applicable requirements and recommended installation practices of IEEE Standards 80, 81, 141, and 142 pertaining to grounding and bonding of systems, circuits, and equipment.

PART 2 - PRODUCTS

2.01 GROUNDING AND BONDING

- A. Materials and Components:
 - 1. Except as otherwise indicated, provide electrical grounding and bonding systems indicated; with assembly of materials including, but not limited to, cables/wires, connectors, solderless lug terminals, grounding electrodes and plate electrodes, bonding jumper braid, surge arresters, and additional accessories needed for complete installation. Where more than one type

component product meets indicated requirements, selection is Installer's option. Where materials or components are not indicated, provide products which comply with NEC, UL, and IEEE requirements and with established industry standards for those applications indicated.

2. Conductors: Electrical copper grounding conductors for grounding system connections that match power supply wiring materials and are sized according to NEC.
3. Grounding Electrodes: Steel with copper welded exterior, 3/4-inch diameter by 10 feet.
4. Electrical Grounding Connection Accessories: Provide electrical insulating tape, heat-shrinkable insulating tubing, welding materials, bonding straps, as recommended by accessories manufacturers for type services indicated.

PART 3 - EXECUTION

3.01 INSTALLATION OF ELECTRICAL GROUNDING AND BONDING SYSTEMS

- A. Connect grounding conductors to underground grounding electrodes using exothermic weld process or mechanical compression type connectors.
- B. Ground each separately derived system neutral to effectively grounded metallic water pipe, effectively grounded structural steel member, and separate grounding electrode.
- C. Connect together system neutral, service equipment enclosures, exposed noncurrent carrying metal parts of electrical equipment, metal raceway systems, grounding conductor in raceways and cables, receptacle ground connectors, and plumbing systems.
- D. Terminate feeder and branch circuit insulated equipment grounding conductors with grounding lug, bus, or bushing.
- E. Connect tank reinforcing steel, tank steel beam, tank steel roof and walls and duct bank and vault reinforcing steel to ground mat using No. 4/0 AWG bare copper grounding cable.
- F. Bond bare No. 4/0 AWG grounding cable in duct banks to grounding cable in vaults and to power equipment ground bus at ends of each duct bank.
- G. Bond strut and other metal inside of electrical manholes and vaults to bare No. 4/0 AWG grounding cable carried in duct bank.
- H. Bond grounding cables to both ends of metal conduit or sleeves through which such cables pass.
- I. Tighten grounding and bonding connectors and terminals, including screws and bolts, in accordance with manufacturer's published torque-tightening values for connectors and bolts. Where manufacturer's torquing requirements are not indicated, tighten connections to comply with tightening torque values specified in UL 486A to assure permanent and effective grounding.
- J. Install braided type bonding jumpers with code-sized ground clamps on water meter piping to electrically bypass water meters.
- K. Route grounding connections and conductors to ground and protective devices in shortest and straightest paths as possible while following building lines to minimize transient voltage rises. Protect exposed cables and straps where subject to mechanical damage.

- L. Apply corrosion-resistant finish to field connections, buried metallic grounding and bonding products, and places where factory applied protective coatings have been destroyed and are subjected to corrosive action.

3.02 FIELD QUALITY CONTROL

- A. Test ground paths for continuity by applying a low DC voltage source of current, capable of furnishing up to 100 amps, between electrical equipment grounds and ground grid. Grounding path must conduct a 100-amp current at a resistance of 0.010 ohms or less as calculated from circuit voltage.

END OF SECTION

SECTION 16070 - SUPPORTING DEVICES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Secure support from the building structure for electrical items by means of hangers, supports, anchors, sleeves, inserts, seals, and associated fastenings.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
 - 1. Product data for each type of product specified.

1.03 QUALITY ASSURANCE

- A. Electrical components shall be listed and labeled by UL, ETL, CSA, or other approved, nationally recognized testing and listing agency that provides third-party certification follow-up services.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which may be incorporated in Work include:
 - 1. Slotted Metal Angle and U-Channel Systems:
 - a. Allied Tube & Conduit.
 - b. American Electric.
 - c. B-Line Systems, Inc.
 - d. Cinch Clamp Co., Inc.
 - e. GS Metals Corp.
 - f. Haydon Corp.
 - g. Kin-Line, Inc.
 - h. Unistrut Diversified Products.
 - 2. Conduit Sealing Bushings:
 - a. Bridgeport Fittings, Inc.
 - b. Cooper Industries, Inc.
 - c. Elliott Electric Mfg. Corp.
 - d. GS Metals Corp.
 - e. Killark Electric Mfg. Co.
 - f. Madison Equipment Co.
 - g. L.E. Mason Co.
 - h. O-Z/Gedney.
 - i. Producto Electric Corp.
 - j. Raco, Inc.
 - k. Red Seal Electric Corp.
 - l. Spring City Electrical Mfg. Co.
 - m. Thomas & Betts Corp.

2.02 COATINGS

- A. Coating: Supports, support hardware, and fasteners shall be stainless steel.. Products for use embedded in concrete shall be hot-dip galvanized.

2.03 MANUFACTURED SUPPORTING DEVICES

- A. Raceway Supports: Clevis hangers, riser clamps, conduit straps, threaded C-clamps with retainers, ceiling trapeze hangers, wall brackets, and spring steel clamps.
- B. Fasteners. Types, materials, and construction features as follows:
 - 1. Expansion Anchors: Carbon steel wedge or sleeve type.
 - 2. Toggle Bolts: Steel springhead type.
 - 3. Hanger Rods: 0.375-inch diameter minimum, aluminum.
- C. Conduit Sealing Bushings: Factory fabricated, watertight conduit sealing bushing assemblies suitable for sealing around conduit or tubing passing through concrete floors and walls. Construct seals with steel sleeve, malleable iron body, neoprene sealing grommets or rings, metal pressure rings, pressure clamps, and cap screws.
- D. Cable Supports for Vertical Conduit: Factory fabricated assembly consisting of threaded body and insulating wedging plug for nonarmored electrical cables in riser conduits. Provide plugs with number and size of conductor gripping holes as required to suit individual risers. Construct body of aluminum.
- E. U-Channel Systems: 12 gauge or 0.105-inch-thick aluminum channels, with 9/16-inch-diameter holes, at a minimum of 8 inches on center in top surface. Provide fittings and accessories that mate and match with U-channel and are of same manufacturer.

2.04 FABRICATED SUPPORTING DEVICES

- A. Shop- or field-fabricated supports or manufactured supports assembled from U-channel components.
- B. Aluminum Brackets: Fabricated of angles, channels, and other standard structural shapes. Connect with welds and machine bolts to form rigid supports.
- C. Pipe Sleeves: Provide a waterstop on pipe sleeves. Provide pipe sleeves of 2 standard sizes larger than conduit/pipe passing through it .

PART 3 - EXECUTION

NOT USED

END OF SECTION

SECTION 16075

ELECTRICAL IDENTIFICATION

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Identification of electrical materials, equipment, and installations. It includes requirements for electrical identification components including, but not limited to, the following:
1. Buried Electrical Line Warnings.
 2. Identification Labeling for Cables and Conductors.
 3. Operational Instruction Signs.
 4. Warning and Caution Signs.
 5. Equipment Labels and Signs.

1.02 SUBMITTALS

- A. Shop Drawings: Submit Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
1. Product Data for each type of product specified.

PART 2 - PRODUCTS

2.01 ELECTRICAL IDENTIFICATION PRODUCTS

- A. Colored Adhesive Marking Tape for Wires and Cables: Self-adhesive vinyl tape not less than 3 mils thick by 1 inch to 2 inches in width.
- B. Pre-tensioned Flexible Wraparound Colored Plastic Sleeves for Cable Identification: Flexible acrylic bands sized to suit raceway diameter and arranged to stay in place by pre-tensioned gripping action when coiled around the cable.
- C. Underground Line Marking Tape: Permanent, bright-colored, continuous-printed, plastic tape compounded for direct-burial service not less than 6 inches wide by 4 mils thick. Printed legend indicative of general type of underground line below.

- D. Wire/Cable Designation Tape Markers: Vinyl or vinyl-cloth, self-adhesive, wraparound, cable/conductor markers with preprinted numbers and letter.
- E. Aluminum, Wraparound, Cable Marker Bands: Bands cut from 0.014-inch thick, aluminum sheet, fitted with slots or ears for securing permanently around wire or cable jacket or around groups of conductors. Provide for legend application with stamped letters or numbers.
- F. Engraved, Plastic-Laminated Labels, Signs, and Instruction Plates: Engraving stock melamine plastic laminate, 1/16-inch minimum thick for signs up to 20 square inches, or 8 inches in length; 1/8-inch thick for larger sizes. Engraved legend in white letters on black face and punched for mechanical fasteners.
- G. Baked-Enamel Warning and Caution Signs for Interior Use: Pre-printed aluminum signs, punched for fasteners, with colors, legend, and size appropriate to the location.
- H. Exterior Metal-Backed Butyrate Warning and Caution Signs: Weather-resistant, nonfading, pre-printed cellulose acetate butyrate signs with 20-gauge, galvanized steel backing, with colors, legend, and size appropriate to location. Provide 1/4-inch grommets in corners for mounting.
- I. Fasteners for Plastic-Laminated and Metal Signs: Self-tapping stainless steel screws or Number 10/32 stainless steel machine screws with nuts and flat and lock washers.
- J. Cable Ties: Fungus-inert, self-extinguishing, one-piece, self-locking nylon cable ties, 0.18-inch minimum width, 50-pound minimum tensile strength, and suitable for a temperature range from minus 50 degrees F to 350 degrees F. Provide ties in specified colors when used for color-coding.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Lettering and Graphics: Coordinate names, abbreviations, colors, and other designations used in electrical identification work with corresponding designations specified or indicated. Install numbers, lettering, and colors as approved in submittals and as required by code.
- B. Underground Electrical Line Identification: During trench backfilling, for exterior non-concrete encased underground power, signal, and communications lines, install continuous underground plastic line marker, located directly above line at 6 to 8 inches below finished grade. Where multiple lines installed in a common trench do not exceed an overall width of 16 inches; install a single line marker.
- C. Install line marker for underground wiring, both direct buried and in raceway.

- D. Conductor Color Coding: Provide color coding for secondary service, feeder, and branch circuit conductors throughout the Project secondary electrical system following OWNER's method of phase identification or as follows:

<u>Phase</u>	<u>480/277 Volts</u>
A	Yellow
B	Brown
C	Orange
Neutral	White
Ground	Green

- E. Use conductors with color factory-applied entire length of conductors except as follows:
1. Following field-applied color-coding methods may be used in lieu of factory-coded wire for sizes larger than No. 10 AWG.
 - a. Apply colored, pressure-sensitive plastic tape in half-lapped turns for a distance of 6 inches from terminal points and in boxes where splices or taps are made. Apply last two laps of tape with no tension to prevent possible unwinding. Use 1-inch-wide tape in colors as specified. Do not obliterate cable identification markings by taping. Tape locations may be adjusted slightly to prevent such obliteration.
 - b. In lieu of pressure-sensitive tape, colored cable ties may be used for color identification. Apply three ties of specified color to each wire at each terminal or splice point starting 3 inches from the terminal spaced 3 inches apart. Apply with a special tool or pliers, tighten for snug fit, and cut off excess length.
- F. Power Circuit Identification: Securely fasten identifying metal tags of aluminum wraparound marker bands to cables, feeders, and power circuits in vaults, pull boxes, junction boxes, manholes, and switchboard rooms with 1/4-inch steel letter and number stamps with legend to correspond with designations on Drawings. If metal tags are provided, attach them with approximately 55-pound test monofilament line or one-piece self-locking nylon cable ties.
- G. Install wire/cable designation tape markers at termination points, splices or junctions in each circuit. Circuit designations shall be as indicated on Drawings.

END OF SECTION

SECTION 16120 - WIRES AND CABLES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section includes the following:
 - 1. Low-Voltage Wire and Cable.
 - 2. Instrument Cable.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section. Include Shop Drawings of wires, cables, connectors, splice kits, and termination assemblies.
- B. Reports of field tests prepared as noted in Section 01600.

1.03 QUALITY ASSURANCE

- A. UL Compliance: Provide components which are listed and labeled by UL. For cables intended for use in air handling space comply with applicable requirements of UL Standard 710, "Test Method for Fire and Smoke characteristics of cables used in Air Handling Spaces."
- B. NEMA/ICEA Compliance: Provide components which comply with following standards:
 - 1. NEMA WC 70-1999/ICEA S-95-658-1999, Nonshielded Power Cables Rated 2,000 Volts or Less for the Distribution of Electrical Energy.
- C. IEEE Compliance: Provide components which comply with the following standard.
 - 1. Standard 82, Test procedures for Impulse Voltage Tests on Insulated Conductors.
- D. Labeling: Handwritten labels are not acceptable. All labels shall be machine printed on clear or opaque tape, stenciled onto adhesive labels, or typewritten onto adhesive labels. The font shall be at least 1/8 inch in height, block characters, and legible. The text shall be of a color contrasting with the label such that is may be easily read. If labeling tape is utilized, the font color shall contrast with the background.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which may be incorporated in Work include:
 - 1. Low-Voltage Wire and Cable:
 - a. American Insulated Wire Corp.
 - b. General Cable.
 - c. The Okonite Co.
 - d. Southwire Co.
 - 2. Connectors for Low-Voltage Wires and Cable Conductors:

- a. AMP.
 - b. O-Z/Gedney Co.
 - c. Square D Company.
 - d. 3M Company.
3. Instrument Cable:
- a. Belden (Trade Nos. 1120A and 1118A).

2.02 LOW-VOLTAGE WIRES AND CABLES

- A. Conductors: Provide stranded conductors conforming to ASTM Standards for concentric stranding, Class B. Construction of wire and cable shall be single conductor (1/c) unless multiconductor cable is shown by notation in form (x/c) where x indicates the number of separate insulated conductors per cable.
- B. Conductor Material: Copper. Minimum size power wire shall be No. 12 AWG.
- C. Insulation: Provide THHN/THWN insulation for power conductors used in single- and 3-phase circuits.
 - 1. Provide THHN/THWN insulation for grounding conductors installed in raceways.
 - 2. Provide THHN/THWN insulation for control conductors.

2.03 CONNECTORS FOR LOW-VOLTAGE WIRES AND CABLES

- A. Provide UL listed factory fabricated, solderless metal connectors of sizes, ampacity ratings, materials, types, and classes for applications and services indicated. Use connectors with temperature ratings equal to or greater than those of the wires upon which used.

2.04 INSTRUMENT CABLE

- A. Instrument Cable: 600 volt minimum insulated shielded cable with two or more twisted No. 16 or No. 18AWG stranded copper conductors; PVC, nylon, or polyethylene outer jacket; and 100 percent foil shielding.

PART 3 - EXECUTION

3.01 FIELD QUALITY CONTROL

NOT USED

END OF SECTION

SECTION 16130 - RACEWAYS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Raceways for electrical wiring. Types of raceways in this Section include the following:
1. Flexible metal conduit.
 2. Liquidtight flexible conduit.
 3. Underground plastic utilities duct.
 4. Rigid nonmetallic conduit.
 5. Electrical nonmetallic tubing.
 6. Conduit bodies.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
1. Product data for the following products:
 - a. Surface raceway and fittings.
 - b. Conduit.
 - c. Conduit bodies.

1.03 QUALITY ASSURANCE

- A. Codes and Standards:
1. NEMA Compliance: Comply with applicable requirements of NEMA standards pertaining to raceways.
 2. UL Compliance and Labeling: Comply with applicable requirements of UL standards pertaining to electrical raceway systems. Provide raceway products and components listed and labeled by UL, ETL, or CSA.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with requirements, manufacturers offering products which may be incorporated in Work include:
1. Conduit:
 - a. Allied Tube.
 - b. Carlon.
 - c. General Electric Co.
 - d. Johns Manville.
 - e. Occidental Coatings.
 - f. Orangeburg.
 - g. Perma-Cote Industries.
 - h. Republic Steel.

- i. Robroy Industries.
- j. Steelduct Co.
- k. Triangle Conduit.
- l. Wheatland Tube.
- m. Youngstown Sheet and Tube.
- 2. Liquidtight Conduit:
 - a. Anamet, Inc.
 - b. Carlon.
 - c. Electric-Flex.
 - d. Thomas and Betts.
- 3. Conduit Bodies:
 - a. Adalet-PLM.
 - b. American Electric.
 - c. Appleton Electric Co.
 - d. Carlon.
 - e. Crouse-Hinds Division, Cooper Industries, Inc.
 - f. Delta Industrial Products.
 - g. Killark Electric Mfg. Co.
 - h. Kraloy Products Co.
 - i. O-Z/Gedney Co.
 - j. Perma-Cote Industries.
 - k. Robroy Industries.
 - l. Spring City Electrical Mfg. Co.
- 4. Conduit Thread Paint:
 - a. CRC Chemicals, USA.
 - b. Sherwin Williams.
 - c. ZRC Chemical Products Co.

2.02 METAL CONDUIT AND TUBING

- A. Liquidtight Flexible Metal Conduit and Fittings: UL 360. Fittings shall be specifically approved for use with this raceway.

2.03 NONMETALLIC CONDUIT AND DUCTS

- A. Rigid Nonmetallic Conduit (RNC): NEMA TC 2 and UL 651, Schedule 40 or 80 PVC.
- B. PVC Conduit and Tubing Fittings: NEMA TC 3; match to conduit or conduit/tubing type and material.
- C. Underground PVC: NEMA TC 6, Type I for encased burial in concrete, Type II for direct burial.
- D. Liquidtight Flexible Nonmetallic Conduit and Fittings: UL 1660. Fittings shall be specifically approved for use with this raceway.

2.04 CONDUIT BODIES

- A. Provide matching gasketed covers secured with corrosion-resistant screws. Use cast covers in NEMA 4 areas and stamped steel covers in NEMA 1 and 12 areas. Use nonmetallic covers in NEMA 4X areas and threaded, ground joint covers in NEMA 7 and NEMA 9 areas.
- B. Metallic Conduit and Tubing: Use metallic conduit bodies as follows:
 - 1. Nonmetallic Conduit and Tubing: Use nonmetallic conduit bodies conforming to UL 514 B.
 - 2. NEMA 7 and NEMA 9 Areas: Use materials conforming to UL standards for the area.

PART 3 - EXECUTION

NOT USED

END OF SECTION

SECTION 16135 - CABINETS, BOXES, AND FITTINGS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Cabinets, boxes, and fittings for electrical installations and certain types of electrical fittings not covered in other Sections. Types of products specified in this Section include:
1. Pull and junction boxes.
 2. Bushings.
 3. Locknuts.
 4. Conduit hubs.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
1. Shop Drawings for floor boxes and boxes, enclosures, and cabinets that are to be shop-fabricated, (nonstock items). For shop-fabricated junction and pull boxes, show accurately scaled views and spatial relationships to adjacent equipment. Show box types, dimensions, and finishes.
 2. Product data for boxes, fittings, cabinets, and enclosures.

1.03 QUALITY ASSURANCE

- A. Codes and Standards:
1. UL Listing and Labeling: Items provided under this section shall be listed and labeled by UL.
 2. NEMA Compliance: Comply with NEMA Standard 250, "Enclosures for Electrical Equipment (1,000 Volts Maximum)."

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which may be incorporated in Work include:
1. Junction and Pull Boxes, Concealed System:
 - a. Adalet-PLM Div., Scott Fetzer Co.
 - b. Appleton Electric, Emerson Electric Co.
 - c. Arrow-Hart Div., Crouse-Hinds Co.
 - d. Bell Electric, Square D Company.
 - e. GTE Corporation.
 - f. Keystone Columbia, Inc.
 - g. OZ/Gedney Co.; General Signal Co.
 - h. Spring City Electrical Mfg. Co.
 2. Junction and Pull Boxes, Exposed Conduit System:
 - a. Appleton Electric, Type FS/FD.

- b. Crouse-Hinds, Type FS/FD.
- 3. Bushings, Knockout Closures, Locknuts, and Connectors:
 - a. Adalet-PLM Div., Scott Fetzer Co.
 - b. AMP, Inc.
 - c. Arrow-Hart Div., Crouse-Hinds Co.
 - d. Appleton Electric Co., Emerson Electric Co.
 - e. Bell Electric; Square D Co.
 - f. Midland-Ross Corp.
 - g. Midwest Electric, Cooper Industries, Inc.
 - h. OZ/Gedney Co., General Signal Co.
 - i. RACO Div., Harvey Hubbell, Inc.
 - j. Thomas & Betts Co., Inc.

2.02 CABINETS, BOXES, AND FITTINGS - GENERAL

- A. Junction and Pull Boxes: Suitable for the conduit system installation as follows:
 - 1. Exposed Conduit: For pull and junction boxes 50 cubic inches and smaller, provide cast or malleable iron, zinc electroplated boxes finished with aluminum lacquer or enamel. Provide exterior mounting lugs and cast covers with neoprene gaskets. For pull and junction boxes larger than 50 cubic inches provide watertight sheet metal boxes. Grind exposed edges smooth or roll edges to prevent scuffing of wire during installation. Provide code-gauge sheet steel construction for boxes smaller than 1,000 cubic inches. Provide 0.10-inch steel construction, hot-dip galvanized after fabrication for boxes larger than 1,000 cubic inches. Secure box covers using No. 8 or larger machine screws spaced at intervals not exceeding 6 inches. Provide a continuous neoprene or rubber gasket cemented to the box cover where it contacts the box body.
 - a. Exceptions: Provide nonmetallic pull and junction boxes in NEMA 4X areas. Provide appropriate explosion-proof construction for boxes located in NEMA 7 and NEMA 9 areas. Provide factory PVC-coated boxes for areas where PVC conduit is used.
 - 2. Concealed Conduit: Provide galvanized code-gauge sheet steel junction and pull boxes, with screw-on covers; of types, shapes and sizes, to suit each respective location and installation; with welded seams and equipped with stainless steel nuts, bolts, screws, and washers.
- B. Bushings, Knockout Closures, and Locknuts: Provide corrosion-resistant box knockout closures, conduit locknuts and malleable iron conduit bushings, offset connectors, of types and sizes, to suit respective installation requirements and applications. Provide watertight hubs on conduits terminated at sheet steel enclosures in NEMA 4 areas.

PART 3 - EXECUTION

NOT USED

END OF SECTION

SECTION 16270 - TRANSFORMERS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Types of transformers specified, and include the following:
1. Dry-type transformers (lighting transformers).

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
1. Product Data: Submit manufacturer's technical product data, including rated kVA, frequency, primary and secondary voltages, percent taps, polarity, impedance and average temperature rise above 40 degrees C ambient temperature, sound level in decibels, and standard published data.
 2. Submit manufacturer's Drawings indicating dimensions and weight loadings for transformer installations.
 3. Wiring Diagrams: Submit wiring diagrams for power distribution transformers.

1.03 QUALITY ASSURANCE

- A. Codes and Standards:
1. NEMA Compliance: Comply with NEMA Standard Pub/Nos. ST 20, "Dry-Type Transformers for General Applications," TR 1, and TR 27.
 2. UL Compliance: Comply with applicable portions of ANSI/UL 506, "Safety Standard for Specialty Transformers. Provide power/distribution transformers and components which are UL listed and labeled.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which may be incorporated in Work include:
1. Acme Electric Corporation.
 2. Cutler-Hammer.
 3. General Electric Company.
 4. Hevi-Duty Electric Div., General Signal Corp.
 5. Square D Company.

2.02 POWER/DISTRIBUTION TRANSFORMERS

- A. Except as otherwise indicated, provide manufacturer's standard materials and components as indicated by published product information, designed and constructed as recommended by manufacturer, and as required for complete installation.

- B. Dry-Type Distribution Transformers (45 kVA or less): Provide factory assembled, general purpose, air cooled, dry-type distribution transformers where shown; of sizes, characteristics, and rated capacities indicated, single phase, 60 hertz, 10 kV BIL, 4.0 percent impedance, with 480 volts primary and 240/120 volts secondary; or K-rated 13 three-phase, 60 hertz, 10 kV BIL, 4.0 percent impedance with 480-volts delta connection primary and 208/120 volts secondary wye connected. Provide primary winding with 4 taps; 2 to 2-1/2 percent increments above and below full-rated voltage for de-energized tap-changing operation. Insulate with Class 150 or 220 degree C insulation and rate for continuous operation at kVA, and limit transformer temperature rise to maximum of 115 or 150 degrees C, respectively. Provide terminal enclosure, with cover, to accommodate primary and secondary coil wiring connections and electrical supply raceway terminal connector. Equip terminal leads with connectors installed. Limit terminal compartment temperature to 75 degrees C when transformer is operating continuously at rated load with ambient temperature of 40 degrees C. Provide wiring connectors suitable for copper or aluminum wiring. Cushion-mount transformers with external vibration isolation supports; sound-level ratings not to exceed 45 db as determined in accordance with ANSI/NEMA standards. Electrically ground core and coils to transformer enclosure by means of flexible metal grounding strap. Provide transformers with fully enclosed sheet steel enclosures. Apply manufacturer's standard light gray indoor enamel over cleaned and phosphatized steel enclosure. Provide transformers suitable for wall mounting.
- C. Finishes: Coat interior and exterior surfaces of transformer, including bolted joints, with manufacturer's standard color baked-on enamel.

PART 3 - EXECUTION

NOT USED

END OF SECTION

SECTION 16410 - CIRCUIT AND MOTOR DISCONNECTS

PART 1 - GENERAL

1.01 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
 - 1. Product data for each type of product specified.
- B. Operation and Maintenance Manuals: Submit in accordance with requirements of Sections 01600 and 13410, operation and maintenance manuals for items included under this Section, including circuits and motor disconnects.

1.02 QUALITY ASSURANCE

- A. Codes and Standards:
 - 1. Electrical Component Standards: Provide components which are listed and labeled by UL. Comply with UL Standard 98 and NEMA Standard KS 1.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which may be incorporated in Work include:
 - 1. Allen-Bradley.
 - 2. Appleton.
 - 3. Crouse-Hinds Co.
 - 4. EATON.
 - 5. Furnas Electric Co.
 - 6. General Electric Co.
 - 7. Siemens, Inc.
 - 8. Square D Company.

2.02 CIRCUIT AND MOTOR DISCONNECT SWITCHES

- A. Provide NEMA 4, 4X, 7, 9, or 12 enclosure to match the rating of the area in which switch is installed. For motor and motor starter disconnects through 100 horsepower, provide units with horsepower ratings suitable to loads. For motor and motor starter disconnects above 100 horsepower, clearly label switch, "DO NOT OPEN UNDER LOAD."
- B. Non-fusible Disconnects: (Heavy-duty) switches of classes and current ratings as indicated.

2.03 ACCESSORIES

- A. Special Enclosure Material: Provide special enclosure material as follows for switches indicated:
 - 1. Stainless Steel for NEMA 4 or outdoor switches.

PART 3 - EXECUTION

NOT USED

END OF SECTION

SECTION 16440 - PANELBOARDS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section includes the following:
1. Lighting panelboards.

1.02 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Section 01340, Shop Drawings covering the items included under this Section. Shop Drawing submittals shall include:
1. Manufacturer's product data on panelboards and enclosures.

1.03 QUALITY ASSURANCE

- A. Codes and Standards:
1. UL Compliance: Comply with applicable requirements of UL 67, "Electric Panelboards," and UL's 50, 869, 486A, 486B, and 1053 pertaining to panelboards, accessories, and enclosures. Provide panelboard units which are UL listed and labeled.
 2. NEMA Compliance: Comply with NEMA Standards Pub/No. 250, "Enclosures for Electrical Equipment (1,000 Volts Maximum)," Pub/No. PB 1, "Panelboards," and Pub/No. PB 1.1, "Instructions for Safe Installation, Operation and Maintenance of Panelboards Rated 600 Volts or Less."
 3. Federal Specification Compliance: Comply with FS W-P-115, "Power Distribution Panel," pertaining to panelboards and accessories.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with specified requirements, manufacturers offering products which may be incorporated in Work include:
1. EATON Products.
 2. General Electric Company.
 3. Siemens, Inc.
 4. Square D Company.

2.02 PANELBOARDS

- A. Except as otherwise indicated, provide panelboards, enclosures, and ancillary components, of types, sizes, and ratings indicated, which comply with manufacturer's standard materials; with design and construction in accordance with published product information. Equip with proper number of unit panelboard devices as required for complete installation. Where types, sizes, or ratings are not indicated, comply with NEC, UL, and established industry standards for those applications indicated.

- B. Lighting Panelboards: Provide dead-front safety type lighting and appliance panelboards as indicated, with switching and protective devices in quantities, ratings, and types shown; with anti-turn solderless pressure type lug connectors approved for use with copper conductors. Construct unit for connecting feeders at top of panel; equip with copper bus bars, full-sized neutral bar with bolt-in type heavy-duty, quick-make quick-break, single pole circuit breakers, and toggle handles that indicate when tripped. Provide suitable lugs on neutral bus for each outgoing feeder required and provide bare uninsulated grounding bars suitable for bolting to enclosures. Select enclosures fabricated by same manufacturer as panelboards, which mate and match properly with panelboards. Panelboards and circuit breakers shall be braced for 10,000 rms symmetrical amperes fault current unless otherwise indicated.
- C. Panelboard Enclosures: Provide galvanized sheet steel cabinet type enclosures, in sizes and NEMA types as indicated, code gauge, minimum 16-gauge thickness. Construct with multiple knockouts and wiring gutters. Provide fronts with adjustable trim clamps and doors with flush locks and keys, all panelboard enclosures keyed alike, with concealed piano door hinges and door swings as indicated. Equip with interior circuit directory frame and card with clear plastic covering. Provide baked gray enamel finish over a rust-inhibitor coating. Design enclosures for surface mounting as indicated. Provide enclosures which are fabricated by same manufacturer as panelboards, which mate and match properly with panelboards to be enclosed. Panelboard enclosure shall be installed inside an aluminum enclosure for adverse conditions.
- D. Molded-Case Circuit Breakers: Provide factory assembled, molded-case circuit breakers of frame sizes, characteristics, and ratings, including rms symmetrical interrupting ratings indicated. Select breakers with permanent thermal and instantaneous magnetic trip, and with fault-current limiting protection, ampere ratings as indicated. Construct with overcenter, trip-free, toggle type operating mechanisms with quick-make quick-break action and positive handle trip indication. Construct breakers for mounting and operating in any physical position, and operating in an ambient temperature of 40 degrees C. Provide breakers with mechanical screw type removable connector lugs, AL/CU rated.
- E. Ground Fault Protected Breakers: Provide UL Class A protected GFI breakers with 6 mA for personnel protection, and for general-purpose receptacles. For breakers dedicated to equipment (sump pumps, heat trace, etc.), provide breaker with 30 mA equipment protection.
- F. Accessories: Provide panelboard accessories and devices including, but not necessarily limited to, ground-fault protection units or circuit breaker locking hardware as indicated.
- G. Spares: In each panelboard provide 8 installed, single pole, 20A spare circuit breakers unless otherwise indicated.

PART 3 - EXECUTION

3.01 INSTALLATION OF PANELBOARDS

- A. Type out panelboard's circuit directory card upon completion of installation Work.

END OF SECTION

SECTION 16748 - SOFTWARE SERVICES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Labor, materials, equipment, and services necessary for furnishing fabrication, production, and installation of items specified in this Section or as shown on Drawings.
- B. Work includes programming, testing, and installation of software required for a complete and fully operational control system. Principal segments of Work include, but are not limited to, programmable logic controller ladder logic, data collection, supervisory control, operator process control interfaces, process data management, laboratory management, and plant administrative/management reports.

1.02 SYSTEM DESCRIPTION

- A. Design Requirements. System consists of PLC panel designed to accept input of several analog instruments and retransmit to the existing SCADA system. The SCADA HMI shall be updated to display, alarm, and trend the data from these signals. The information shall be displayed in a pictorial representation of the actual basin layout.
- B. Performance Requirements: Programmable logic controllers (PLCs) shall complete execution of all rungs with a cycle time not to exceed 250 mS. Operator interface functions shall have a 2-second response time or better. Adjust timing and operating system parameters of PLCs and computers as necessary.

1.03 SUBMITTALS

- A. Shop Drawings: Submit in accordance with Sections 01340 and 13410, Shop Drawings and Basic Instrumentation Requirements; and product data for products provided under this Section.

1.04 QUALITY ASSURANCE

- A. Software Progress Meetings: Allow in Bid for 2 meetings per month via teleconference, for review of PLC logic and graphic operator screens. Meeting to commence at time of Contract Award and continue up to panel checkout.

PART 2 - PRODUCTS

2.01 SERVICE SUPPLIER

- A. Software services shall be fulfilled by the organization selected as "Equipment Supplier" under Section 13410.

2.02 SOFTWARE SERVICES

- A. Software services include program development, testing, documentation, and Work necessary to implement a complete and fully operating system as shown on Drawings and/or as specified. Provide programming to implement required functions and features.
- B. Work requires coordination with concurrent program development for PLCs, Operator Interfaces, Management Reports, and Data Collection. Include PLC error detection logic for communications failures, data highway faults, internal faults, and time outs. Communicate PLC error conditions to Operator Interface for logging and reporting.
- C. Communication between PLCs, Operator Interface, and Data Collection shall be on an exception basis. When reportable changes in process state occur, such as alarm assertion, return to normal, or analog value out of dead band, report event to PLC that communicates with Operator Interface and Data Collection. This PLC shall maintain data tables current with all process inputs and outputs. Organize data to be transferred into contiguous blocks of information using bit-mapped and integer tables. Employ a "watchdog" timer for each remote PLC and poll that PLC if no message has been received in a reasonable amount of time. Accept Operator Interface directives for setpoint changes and hand switches.

2.03 PROGRAMMABLE CONTROLLER LOGIC

- A. Develop programs for execution on PLC using development software supplied under that Section. Logic shall perform functions required to control processes and equipment as shown on Drawings and/or as specified. Develop complete cross-references for ladder logic and complete input/output listings.

2.04 OPERATOR INTERFACE (LOCAL OPERATOR COMPUTER)

- A. Operator Interface programs for Local Operator Computers (LOCs) provide graphic representation of local processes and control over machinery. Provide following screens:
 - 1. Process Tanks overview.
 - 2. Individual Clarifiers (update ex. screen)
 - 3. Trends (update ex. screens)
 - 4. Alarming (update ex. screen/database)
- B. Screens shall include indicating lamps and hand switches shown. Include analog instruments such as indicators, manual loading stations, controllers, etc., as shown. Programming shall be done using panel viewing software as manufactured by the PLC vendor.

2.05 OPERATOR INTERFACE AND DATA COLLECTION (DATA MANAGEMENT COMPUTER)

- A. Operator Interface programs provide graphic representation of plant processes and control over machinery. Data collection activities provide historical trend analysis and process data readings for use in management reporting.
- B. Provide following screens:
 - 1. Process Tanks overview.
 - 2. Individual Clarifiers (update ex. screen)

3. Trends (update ex. screens)
 4. Alarming (update ex. screen/database)
- C. Operator Displays: Develop programs to provide following elements and as required for a complete fully functional Operator Interface and data collection system:
1. Video displays shall be color at highest resolution supported by hardware. Install operating system drivers as necessary. They shall be fully windowed and shall use a mouse for control. Use colors, function keys, and navigational controls consistently.
 2. Alarm Management: For each process or system event classed as an alarm provide facilities for displaying and logging on system alarm printer, acknowledgment, and purging of stale messages. Alarm events are derived from discrete inputs, analog trip values, logic combinations and computations as needed. Print and display both alarm events and returns to normal. Provide date/time stamps for events, descriptive message, and event type code. Use color combinations to distinguish following alarm states: Alarm-Unacknowledged, Alarm-Acknowledged, Normal-Unacknowledged, and Normal-Acknowledged.
 3. Graphic Displays: Provide process-oriented displays showing current process status and accepting operator input for setpoint and status changes. Submit for approval color schema and screen-to-screen navigation strategies. For each display, show process elements such as pumps, valves, tanks, pipe lines, etc., with their current operational status. Provide analog displays for board instruments shown including indicators, controllers, manual loading stations, etc. Indicators shall use an appropriate number of significant digits and dead band to produce steady values and color to show operational status.
 4. Print Screen function shall direct an image of the currently displayed screen to any system printer as the user directs. When directed to a color printer, a color screen image shall be produced.
 5. Trending: Provide on-screen trending displays that are user definable that operate from either previously collected historical trend groups (named file) or from a group of real-time variables. Provide facilities for user selection of colors, time (horizontal), and measurement (vertical) scales. Accommodate real-time sampling intervals as short as 1 second. Real-time trends shall show alarm setpoints. Historical trend displays shall have time-scale panning controls.
 6. Security: Using operator interface and operating system software, implement a security system to restrict access to parts of system. Provide following as a minimum:
 - a. Programmer - Access to all facilities including changing displays and logic.
 - b. Supervisor - Access to all displays, change master set points and purge stale alarm messages.
 - c. Operator - Access to all displays, change normal operational sequences and acknowledge alarms.
 - d. Observer - Access to displays only.
- D. Provide following data management functions:
1. Collection files are closed at 00:05 of first day of each calendar month and a new file started. Establish a file naming convention based on file type (analog, historical, or motor), month, and year. Provide operator screens for managing file space:
 - a. Backing up to archive medium.
 - b. Restoration from archive.
 - c. Deleting archive files.
 - d. Display/print of archive catalog.
 - e. Forcing early closure of collection file.
 - f. Create export file.

2. Analog Points: Scan each analog point every minute. Every hour, store minimum, maximum, and average values in a journal file. Do not store values that are out of range, out of service, or not valid for any other reason.
3. Historical Trend Data Collection: Establish data collection tables for up to 20 groups of up to 6 process points each with a collection interval of 1 minute. Provide facilities for defining and changing trend groups. Removal and archiving of closed trend files shall be accomplished using operating system's standard backup/restore programs. Do not store values that are out of range, out of service, or not valid for any other reason.
4. Motor Run Times: For each monitored motor, store daily values for running time. Run times may be developed either by scanning points every minute or by providing PLC timer logic. Daily accumulated run times are to be stored at 00:01 of each day and then reset. Close running time data collection file at 00:05 on first day of each month.
5. Data Export: Provide collected data file export facilities for use by management reporting programs and third-party data analysis programs such as dBase IV and spreadsheets. Export files shall be ASCII encoded, fixed record (and field) length with carriage control. Export files shall be made from closed collection files on user demand.

PART 3 - EXECUTION

3.01 SOURCE QUALITY CONTROL

- A. Conduct preliminary testing prior to factory checkout by executing programs supplied for this Project. Use simulated input and output devices as necessary to verify correct interpretation. Exercise inputs to test logic for correct function and proper response of outputs. Verify correct interface of PLC logic with programs used for Operator Interface and Data Collection Activities. Verify correct PLC to PLC communications.
- B. Examination, Installation, Field Quality Control, Demonstration: In accordance with Section 13410.

END OF SECTION

**CITY OF NAPLES
WRF AERATION MONITOR & CONTROL
INSTRUMENTATION IMPROVEMENTS
BID SCHEDULE**

ITEM	DESCRIPTION	UNIT	QUANT	TOTAL
1	PHASE 1 – DO & SS MONITORING			
1A	Aeration Basin Dissolved Oxygen Monitoring	LS	1	\$
1B	Aeration Basin & RAS Suspended Solids Monitoring	LS	1	\$
1C	Chlorine Contact Chamber & Final Effluent Station Dissolved Oxygen Monitoring	LS	1	\$
2	PHASE 2 OPTION – SLUDGE BLANKET MONITORING	LS	1	\$
3	PHASE 3 OPTION – THERMAL MASS FLOW MONITORING	LS	1	\$
TOTAL PRICE:				\$

PHASE 1 – DO & SS MONITORING

- 1A. Price for Aeration Basin Dissolved Oxygen (DO) Monitoring shall include all cost for labor, material, and equipment, preparatory work, mobilizing and demobilizing, insurance, permitting, field engineering, construction schedule, shop drawings, demolition, disposal, plugging, capping, welding, storing material and equipment, PLC, power, enclosures, programming/integration, screen development, terminal boxes, breaker panel, fiber converters, junction boxes, DO probes, conduit, wire, connectors, concrete work, brackets, flushing system piping, fittings, and valves; coating, testing, and all other related items as required per the Drawings and Specification, and City of Naples requirements.

Aeration Basin DO Monitoring shall include the furnishing and installation of all items necessary to provide a complete and operating DO monitoring system for the aeration basins and the PLC/Terminals/Power Facilities backbone necessary to provide for: All components shown in the Drawings & Specifications, including Suspended Solids Monitoring in the aeration basins & RAS Pipe, DO monitoring of the Chlorine Contact Chamber & Final Effluent Station, and future monitoring of Sludge Blanket Levels in the clarifiers as required per the Drawings and Specification. Additionally, Aeration Basin DO Monitoring shall include all shared conduit for the SS probes.

- 1B. Price for Aeration Basin & RAS Pipe Suspended Solids (SS) Monitoring shall include all cost for preparatory work, mobilizing and demobilizing, insurance, permitting, field engineering, construction schedule, shop drawings, demolition, disposal, plugging, capping, welding, storing material and equipment, programming/integration, screen development, SS probes, PLC Modules, breakers, conduit (not shared with the DO probes, item #1 above), wire, connectors, concrete work, brackets, flushing system piping, fittings, and valves; coating, testing, and all other related items as required per the Drawings and Specification, and City of Naples requirements.

- 1C. Price for Chlorine Contact Chamber (CCC) & Final Effluent Dissolved Oxygen (DO) Monitoring shall include all cost for preparatory work, mobilizing and demobilizing, insurance, permitting, field engineering, construction schedule, shop drawings, demolition, disposal, plugging, capping, welding, storing material and equipment, programming/integration, screen development, SS probes, PLC Modules, breakers, conduit, (not shared with the DO probes, item #1 above), wire, connectors, concrete work, brackets, flushing system piping, fittings, and valves; coating, testing, and all other related items as required per the Drawings and Specification, and City of Naples requirements.

PHASE 2 OPTION – SLUDGE BLANKET MONITORING

Price for Sludge Blanket Monitoring in Clarifiers #1 - #6 shall include all cost for preparatory work, mobilizing and demobilizing, insurance, permitting, field engineering, construction schedule, shop drawings, demolition, disposal, plugging, capping, welding, storing material and equipment, programming/integration, screen development, SS probes, PLC Modules, breakers, conduit, (not shared with the DO probes, item #1 above), wire, connectors, concrete work, brackets, flushing system piping, fittings, and valves; coating, testing, and all other related items as required per the Drawings and Specification, and City of Naples requirements.

PHASE 3 OPTION – THERMAL MASS FLOW MONITORING

Price for Thermal Mass Flow Monitoring in Aeration Basins shall include all cost for preparatory work, mobilizing and demobilizing, insurance, permitting, field engineering, construction schedule, shop drawings, demolition, disposal, plugging, capping, welding, storing material and equipment, programming/integration, screen development, SS probes, PLC Modules, breakers, conduit, (not shared with the DO probes, item #1 above), wire, connectors, concrete work, brackets, flushing system piping, fittings, and valves; coating, testing, and all other related items as required per the Drawings and Specification, and City of Naples requirements.

NOTE: The City reserves the right to award all, none, or any portion of the project.

Bid Schedule Signature

Company Name _____ PH _____

Name and Title of individual completing this schedule:

(Printed Name)

(Title)

(Signature)

(Date)

CONTACT INFORMATION

Company Representative Signatures: _____

Printed Name and Title: _____

Company Name: _____

Address: _____

Telephone: _____

Email: _____

EIN: _____