

**CITY OF NAPLES
PURCHASING DIVISION
CITY HALL, 735 8TH STREET SOUTH
NAPLES, FLORIDA 34102
PH: 239-213-7100 FX: 239-213-7105**

ADDENDUM NUMBER 2

NOTIFICATION DATE:	BID TITLE:	BID NUMBER:	BID OPENING DATE & TIME:
03/18/14	WWTP Reuse Pump Replacement	14-028	03/20/14 2:00PM

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

The following clarifications are issued as an addendum for the referenced solicitation.

The engineer of record would like the following two clarifications:

1. On the check valve, (15050-9, Item 2.07, the check valve needs to be rate for 150 psi, which matches the existing valves
2. On the dashpot for the check valve, the dashpot shall be located on the top of the valve.

###

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.