

**CITY OF NAPLES
PURCHASING DIVISION
CITY HALL, 735 8TH STREET SOUTH
NAPLES, FLORIDA 34102
PH: 239-213-7100 FX: 239-213-7105**

ADDENDUM NUMBER 1

NOTIFICATION DATE:	BID TITLE:	BID NUMBER:	BID OPENING DATE & TIME:
03/12/14	WWTP Reuse Pump Replacement	14-028	03/20/14 2:00PM

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

The following clarifications are issued as an addendum for the referenced solicitation.

Revised Bid Form is attached as Exhibit B. Please use this revised form in you bid response. This form replaces the below referenced page (bid document page 18) in its entirety.

DMN/specs/BID FORM

Tt #200-08516-13002
City of Naples

00300-1
ITB 14-028

012014
18

Note there was a typographic error on the project title which should have been Waste Water Treatment Plant (WWPT).

Below are answers to written submitted questions.

- What is the engineer's estimated value for the contract?

ANSWER: The Engineer's estimate is: \$325,000.

- What is the amount for liquidated damages?

ANSWER: \$250/day

- Note 11 on G-001 states that Tetra Tech will program the new VFD's. Will they also program the existing PLC for the new I/O module and inputs?

ANSWER: Yes, Tetra Tech will program in the new I/O module and the control of the drives. Note that Tetra Tech will only be programming the existing PLC, the actual configuration/setup/programming/commissioning/etc. of the new VFD's shall be the responsibility of the contractor.

- Is there a permit allowance for the project? If not, will permit fees be waived?

ANSWER: A permit allowance of \$500.00 has been added to the bid schedule to cover the costs associated with City of Naples permits. All costs associated with permitting needs from other agencies shall be the responsibility of the Contractor. Please see the modified bid schedule.

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.

- Do you have the Street Address for the Site?

ANSWER: The address of the facility is: 1400 3rd Avenue North, Naples FL 34102

- What is the weight of the new pump assembly?

ANSWER: The Pump has a weight of 4,500 lbs according to the data sheet.

- What is the weight of the new motor?

ANSWER: The 600 HP Motor has a weight of 6,900 lbs according to the data sheet.

- When will the City supplied pump and motor be onsite ready for installation by the Contractor?

ANSWER: The City anticipates that the 600 HP pump and motor will be onsite, ready for installation by May 15, 2014.

Exhibit A – Pre-Bid Attendees List

Exhibit B – REVISED Bid Form (Please use this form in your bid response.)

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.

EXHIBIT A

**City of Naples
NON-MANDATORY PRE-BID
14-028 WTP Reuse Pump Replacement BID #14-028
March 10, 2014 10:00 AM Local Time**

Page 1 of 3

NAME TODD Doederlein

COMPANY Mitchell f STARK

TELEPHONE 239-332-1632

E-MAIL tdoederlein@mitchellstark.com

NAME BOB HODGES

COMPANY CARDINAL CONTRACTORS

TELEPHONE 239 931 3550

E-MAIL RHODGES@CARDINALCO.COM

NAME Gregory Sullivan

COMPANY CSN

TELEPHONE 239-213-7101

E-MAIL gsullivan@naplesgov.com

City of Naples
NON-MANDATORY PRE-BID
14-028 WTP Reuse Pump Replacement BID #14-028
March 10, 2014 10:00 AM Local Time

Page 2 of 3

NAME Kevin Smith

COMPANY QUALITY ENTERPRISES USA, Inc

TELEPHONE (239) 435-7200

E-MAIL ksmith@qe-usa.com

NAME BRANDY BARTOLONE

COMPANY DM HIGGINS

TELEPHONE 239-274-3130

E-MAIL brandybedahiggins.com

NAME Dan Speas

COMPANY Mader Electric Inc

TELEPHONE 941 315 1825

E-MAIL dspeas@maderelectricinc.com

City of Naples
NON-MANDATORY PRE-BID
14-028 WTP Reuse Pump Replacement BID #14-028
March 10, 2014 10:00 AM Local Time

Page 3 of 3

NAME JUSTIN FREDERIKSEN

COMPANY CITY OF NAPLES

TELEPHONE 213-4762

E-MAIL jfrederiksen@naples.gov.com

NAME Linda Moore

COMPANY TLC Diversified, Inc.

TELEPHONE 941-722-0621

E-MAIL lmoore@tlcdiversified.com
mheath@tlcdiversified.com

NAME JEFFREY HOLST

COMPANY FLORIDA DESIGN DRILLING GRP.

TELEPHONE 561-818-3228

E-MAIL JEFF@FLDRILLING.COM

EXHIBIT B

**CITY OF NAPLES
WASTEWATER TREATMENT PLANT
REUSE PUMP UPGRADES**

BID FORM

<u>Item No.</u>	<u>Description</u>	<u>Estimated Quantity</u>	<u>Units</u>	<u>Unit Price</u>	<u>Price</u>
Schedule 1: General					
1.1	Mobilization/Demobilization	1	LS	\$ _____	\$ _____
1.2	General Requirements	1	LS	\$ _____	\$ _____
1.3	Indemnification	1	LS	\$ <u>100.00</u>	\$ <u>100.00</u>
Subtotal for Schedule 1:					\$ _____
Schedule 2: Reuse Pump Upgrades					
2.1	350 Hp Pump Replacement	1	LS	\$ _____	\$ _____
2.2	Pipe/Appurtenance Replacement	1	LS	\$ _____	\$ _____
Subtotal for Schedule 2:					\$ _____
Schedule 3: Electrical/Mechanical Upgrades					
3.1	Remove/Replace Controls	1	LS	\$ _____	\$ _____
3.2	Remove/Replace HVAC	1	LS	\$ _____	\$ _____
3.3	Programming Allowance	1	LS	\$ <u>25,000</u>	\$ <u>25,000</u>
3.4	I/O Module Allowance	1	LS	\$ <u>5,000</u>	\$ <u>5,000</u>
3.5	City of Naples Permitting Allowance	1	LS	\$ <u>500</u>	\$ <u>500</u>
Subtotal for Schedule 3:					\$ _____
Total Base Bid Price for the Contract (Sum of Schedules 1 through 3):					
_____					\$ _____
_____					\$ _____
(In Words)					(in Figures)

All Bid items shall include all materials, equipment, labor, permit fees, taxes, tests, miscellaneous costs of all types, overhead, and profit for the item to be complete, in place, and ready for operation in the manner contemplated by the Contract Documents.