

**CITY OF NAPLES  
PURCHASING DIVISION  
CITY HALL, 735 8<sup>TH</sup> STREET SOUTH  
NAPLES, FLORIDA 34102  
PH: 239-213-7100 FX: 239-213-7105**

**ADDENDUM NUMBER 3**

NOTIFICATION DATE:  <b>06/17/14</b>	BID TITLE:  <b>Wastewater Treatment Bar Screens Replacement</b>	BID NUMBER:  <b>14-046</b>	BID OPENING DATE & TIME: <b>New Date</b> <b>07/01/14</b> <b>2:00PM</b>
--	---	----------------------------------	---

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,  
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

The following clarifications are issued for the referenced solicitation:

The following changes (word deletions) are made to the section 1.02 A of 11331 specifications:

**1.02 QUALITY ASSURANCE**

- A. **Qualifications:** All of the equipment specified herein shall be furnished by a single manufacturer who regularly engages in the production of this type of equipment ~~in the United States~~ and who is fully experienced, reputable and qualified in the manufacture of the equipment to be furnished. Each component and ancillary equipment item furnished under this Specification shall be new and unused, of the type, size, design, and efficiency installed on previous projects and the product of a manufacturer having a successful record of manufacturing and servicing the equipment for a minimum of ten (10) years ~~in the United States~~ prior to bid date. Manufacturer shall have a minimum of ten (10) year experience producing equipment substantially similar to that required and shall submit documentation of at least fifteen (15) independent installations ~~in the United States~~ using the same size or larger equipment as detailed in the below. Each installation must have been in satisfactory operation for at least five (5) years.

###

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.