



City of Naples Building Department

Naples Process for Assisting FPL Power Activation

Buildings where electrical equipment was flooded or damaged by Hurricane Ian, or that have been notified by FPL that a city inspection is required to obtain power, are required to follow the below steps for the city to notify FPL that power may be restored:

- A. All Commercial, Multi-Family, and Single-Family homes with an electrical service greater than 600 amps:
 - Florida Building Code requires a licensed Florida engineer to provide an inspection and approval of the existing electrical equipment.
 - If undamaged, please provide the approved for power engineers report to the city at the following email addresses.
 - If damaged a licensed electrical contractor must make the required repairs and then have their engineer reinspect and provide the approved for power engineers report to the city at the following email addresses.
 - Once the approved for power report is received, the city will notify FPL that the power may be restored.
- B. All Commercial, Multi-Family, and Single-Family homes with an electrical service less than 600 amps:
 - A licensed electrical contractor is required to provide an inspection and approval of the existing electrical equipment.
 - If undamaged, please provide the contractors approved for power report to the city at the following email addresses.
 - If damaged a licensed electrical contractor must make the required repairs and then contact the city at the following email addresses to schedule an inspection.
 - Once the inspection passes the city will notify FPL that power may be restored.

Questions may be directed to the City of Naples Building Department:

Building Official: Stephen Beckman	Phone: 239-213-5008	Email: sbeckman@naplesgov.com
Deputy Building Official: Tom Tucker	Phone: 239-213-5047	Email: ttucker@naplesgov.com