

**CITY OF NAPLES
PURCHASING DIVISION
CITY HALL, 735 8TH STREET SOUTH
NAPLES, FLORIDA 34102
PH: 239-213-7100 FX: 239-213-7105**

ADDENDUM NUMBER 2

NOTIFICATION DATE:	SOLICITATION TITLE:	SOLICITATION NUMBER:	BID OPENING DATE & TIME:
2/13/2023	Seagate Linear Boardwalk Restoration FWQ	23-013	2/16/2023 4:00PM

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

1. Since there will not be any engineered drawings, what is the required embedment depth for the 8"x8" posts, and do you have, or can you provide a proposed or existing deck elevation above grade? ***The deck elevation is to remain the same and is approximately 4' above ground. The 8x8 posts need be set a minimum of 4' in-ground. (No footer/concrete etc. is required)***

#

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.