

**CITY OF NAPLES  
PURCHASING DIVISION  
CITY HALL, 735 8<sup>TH</sup> STREET SOUTH  
NAPLES, FLORIDA 34102  
PH: 239-213-7100 FX: 239-213-7105**

**ADDENDUM NUMBER 1**

NOTIFICATION DATE:	SOLICITATION TITLE:	SOLICITATION NUMBER:	BID OPENING DATE & TIME:
<b>2/6/2023</b>	<b>Seagate Linear Boardwalk Restoration FWQ</b>	<b>23-013</b>	<b>2/16/2023 4:00PM</b>

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,  
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

1. Has a staging and storage area been identified on the project site? **Contractor will be able to stage materials on site. Area will be identified at project kickoff with awarded contractor.**
2. Will the city be providing an engineered set of drawings, or is that the contractor's responsibility? **This is a replacement of existing with in kind materials. There will be no city provided drawings.**
3. Is this project a 100% complete replacement or is the intent to leave the existing support posts in place? **100% replacement**
4. The bid package states .60 CCA treated lumber for all including the decking. CCA is not approved for skin contact due to the arsenic. ACQ or MCA would be the appropriate marine grade decking treatment. **Decking should be either .40 ACQ or .15 MCA- Framing materials are to be .60CCA**

**###**

**IMPORTANT MESSAGE**

**PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.**