

**CITY OF NAPLES
PURCHASING DIVISION
CITY HALL, 735 8TH STREET SOUTH
NAPLES, FLORIDA 34102
PH: 239-213-7100 FX: 239-213-7105**

ADDENDUM NUMBER 2

NOTIFICATION DATE:	SOLICITATION TITLE:	SOLICITATION NUMBER:	BID OPENING DATE & TIME:
8/1/2023	Riprap Installation under Harbour Bridge - ITB	23-033	8/23/2023 2:00PM

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

The following answers to written, submitted questions:

1. Will the riprap be certified by an engineer?

ANSWER: The contractor is responsible for sourcing high quality limerock riprap. Certification is not required.

2. Also, what is meant by installing 1-3 ft of riprap? Will the limerock be installed on top of the existing riprap?

ANSWER: This project will supplement the existing sub-tidal riprap that is already present. New riprap, ideally 1'-2' in size, should extend up to Mean High Water and slope towards the first set of the westernmost vertical bridge supports.

3. I have reviewed the Harbour Bridge RFP. I note the pay item has 90FT. Normally, RIPRAP is quoted in TONS or CUBIC FEET. Sometimes ditch linings are required, etc.

ANSWER: There is some subtidal riprap that already exists along the seawall. The contractor will need to determine additional tons needed to bring the riprap up to Mean High Water. A site visit is recommended.

4. There is no line item for Traffic Control or Mobilization?

ANSWER: All materials should be transported to and deployed at the site from the water. Separate mobilization costs can be provided as a part of the bid response.

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.

The following clarification is issued as an addendum identifying the following change for the referenced solicitation.

REVISED SCHEDULE OF VALUES FORM:

Attached Exhibit A is a REVISED SCHEDULE OF VALUES FORM - 8/01/23. The Form replaced in its entirety the published Schedule of Values Form

THE REVISED SCHEDULE OF VALUES FORM - 8/01/23 (EXHIBIT A) MUST BE USED BY VENDORS OR THE BID WILL BE REJECTED.

Exhibit A - REVISED SCHEDULE OF VALUES – 8/01/23

#

IMPORTANT MESSAGE

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET .

EXHIBIT A - REVISED SCHEDULE OF VALUES - 8/1/23

23-033 Riprap Installation under Harbour Bridge - Schedule of Values - 8/01/23

Description	Qty	Unit of Measure	Unit Cost	Line-Item Cost
Install supplemental riprap, 1-2 ft in size, around existing riprap to Mean High Water	90	LINEAR FT (by approx. 15' into the water)	\$	\$
Mobilization				\$
Permitting (local, state, federal)				\$
Total			\$0.00	

THE REMAINDER OF THIS PAGE INTENTIONALLY LEFT BLANK