

**CITY OF NAPLES  
PURCHASING DIVISION  
CITY HALL, 735 8<sup>TH</sup> STREET SOUTH  
NAPLES, FLORIDA 34102  
PH: 239-213-7100 FX: 239-213-7105**

**ADDENDUM NUMBER 1**

NOTIFICATION DATE:	SOLICITATION TITLE:	SOLICITATION NUMBER:	BID OPENING DATE & TIME:
<b>11/9/2023</b>	<b>Lowdermilk Park Facility Improvements - ITB</b>	<b>24-007</b>	<b>12/29/2023 2:00PM</b>

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,  
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

The following answers to written, submitted questions:

1. Please provide the Specs for the Mop Sink, Mop Sink Faucet or Hose Bib.

**ANSWER: These Plumbing fixtures are recommended:**

**Mop Sink – FIAT Products TSBC6012 Stockton Terrazzo Neo**

**Mop Basin with 830-AA faucet. Or approved equal.**

**Hose Bib – Mifab Hydrakit HY-9241. Or approved equal.**

**###**

**IMPORTANT MESSAGE**

**PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.**