

**CITY OF NAPLES  
PURCHASING DIVISION  
CITY HALL, 735 8<sup>TH</sup> STREET SOUTH  
NAPLES, FLORIDA 34102  
PH: 239-213-7100    FX: 239-213-7105**

**ADDENDUM NUMBER 2**

NOTIFICATION DATE:	SOLICITATION TITLE:	SOLICITATION NUMBER:	BID OPENING DATE & TIME:
<b>11/14/2023</b>	<b>Lowdermilk Park Facility Improvements - ITB</b>	<b>24-007</b>	<b>12/29/2023 2:00PM</b>

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,  
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**


**The following answers to written, submitted questions:**

1. Keynote 307 on A1.01 states "LOCATION OF NEW CONCRETE RETENTION - REFER TO SITE CIVIL "BY OTHERS"." Please advise if we should include the concrete retention or exclude from our bid based on keynote "BY OTHERS".

**ANSWER: Please include the concrete in your bid. Disregard "by others".**

2. During a site visit we noticed existing underground electrical that is in the footprint of the concrete retention. See attached sketch and photos. This electrical is not on the prints. Please advise what the intention is with this electrical.

**ANSWER: We believe this electrical to be outside the work area. Should it be in the way, the City would have its electrical contractor move it.**



###

**IMPORTANT MESSAGE**

**PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET .**