

**CITY OF NAPLES
PURCHASING DIVISION
735 8TH STREET SOUTH
NAPLES, FL 34102
PH: 239-213-7100 FX: 239-213-7105**

ADDENDUM NUMBER 4

NOTIFICATION DATE:	SOLICITATION TITLE:	SOLICITATION NUMBER:	BID OPENING DATE & TIME:
04/03/2024	Naples Pier Reconstruction - ITB	24-011	5/07/2024 2:00PM

**THE FOLLOWING INFORMATION IS HEREBY INCORPORATED INTO,
AND MADE AN OFFICIAL PART OF THE ABOVE REFERENCED BID.**

The following clarifications are issued as an addendum identifying the following changes for the referenced solicitation.

The following answers to written, submitted questions:

1. Does the city of Naples intend to use any of the existing substructure (piles) for the new superstructure?

Answer: Only the first three pile bents between the existing restrooms are to be re-used.

2. Will the existing substructure require repairs?

Answer: No

3. If the substructure will be retained, does it have sufficient load rating to take the new structure, or will it need to increase capacity?

Answer: The three pile bents to be re-used will be adequate as-is to support the new superstructure.