

City of Naples

Beach Restoration & Water Quality Improvement Project

Presented By:

Erickson Consulting Engineers, Inc.

Karyn Erickson, ME, PE, D CE, Project Director

Christin Perkinson, PhD, PE, D CE, Project Manager

Stantec Inc.

Kelly Blake, PE, Project Manager

Ramon Castella, PE

June 1, 2016



Overview

Naples Beach Restoration & WQ Improvement Project

- Background & Project Need
- Existing Site Conditions
- Project Goals & Objectives
- Analysis
- Design Requirements
- Alternatives
- Cost Estimates
- Evaluation and Alternatives Ranking
- Recommended Alternative (#3)

Background

Naples Beach Restoration & WQ Improvement Project

- Proactive Stormwater Management Program (\$70M)
- Stormwater User Fees & Incentives
- Stormwater & Fertilizer Ordinances (BMPs & PreTreatment)
- Grass Retention Swales Program & Education
- State DEP Requires Outfall Removal
- City Resolution No. 12-13028 Requires Outfall Removal
- AECOM Stormwater Outfall Removal “Alternatives Evaluation” (2013)
- ECE “Technical Analysis & 30% Design Report” (2015/16)


Project Need

- **Existing Outfalls Identified as Source of Beach Erosion and Bacteria**
- **Blocked Discharge from Sand Buildup**
- **Frequent Maintenance to Secure/Unclog Pipes**
- **Gulf Shore Blvd Flooding Due to Back-up of Existing Beach Outfalls**
- **Degrades Aesthetics and Impacts Tourism**
- **Sea Level Rise Will Increase Occurrence of Flooding**



April 2008

Stormwater Outfalls at Naples Beach



Outfalls: #2, #3, #4, #5 and #6, #7, #8, #9, #10 (City-9)

Site Conditions



**Flooding of Gulf Shore Road
(Near 2nd Ave N/Outfall 8, Sept 2015)**



**Blocked Discharge
(Outfall 9)**

Site Conditions



Frequent Maintenance



Beach Erosion & Aesthetics

Outfall 3



Outfall 5



Outfall 6

Site Conditions – Water Quality



Goals & Objectives

- 1. Reduce flooding and improve water quality**
- 2. Reduce adverse impacts to beach & hardbottom resources**
- 3. Eliminate beach erosion from outfall induced scour**
- 4. Improve lateral beach access by removing pipelines/outfalls**
- 5. Meet or exceed existing level of service:**
 - ❖ **5-Yr rain event (City of Naples Comprehensive Plan)**
 - ❖ **25-Yr rain event (SFWMD)**
- 6. Convey stormwater to pump station, treatment & offshore discharge**
- 7. Community education (project objectives and design)**


Analysis & Design Requirements

- **Naples Beach Rainfall Conditions**
- **Level of Service (25 Yr Storm Event Discharge)**
- **S/W Line Consolidation (Peak Discharge) ↑**
- **Siting & Sizing Pump Station(s)**
- **Define & Evaluate Water Quality Conditions & Treatment**
- **Depth of Closure & Nearshore Hardbottom**

Naples Rainfall Days Exceeding 0.5 Inch

Year	Total Days Exceeded					Total # Days
	0.5 in	1 in	2 in	3 in	4 in	
2003	42	20	7	3	1	148
2004	25	12	2	0	0	125
2005	35	18	9	1	1	142
2006	30	20	4	0	0	93
2007	18	9	2	0	0	96
2008	33	15	3	0	0	103
2009	25	6	0	0	0	96
2010	34	11	3	0	0	96
2011	24	13	2	0	0	96
2012	25	12	1	0	0	99
2013	31	14	4	1	0	109
2014	33	9	1	1	1	104
2015	22	6	2	0	0	105
TOTAL	377	165	40	6	3	1,412
AVG	29	13	3	0	0	109
OCCURENCE	26.6%	11.6%	2.8%	0.4%	0.2%	100%

Aug 4, 2014 Rainfall Event




(6 inches in 4 hours)

Beach Erosion Impacts

- **Erosion Fronting Outfalls = 92,200 CY (7 Yrs)**
- **Outfall Induced Impact Estimated at 50+%**
- **Sand Placement Cost (92,200 CY* \$35/CY)**
 - **\$1.6M (2006-2013)**

Design Level(s) of Service

Outfall #	Outfall Location Description	Peak Discharge (cfs)		
		5-Yr/1-Hr Event	5-Yr/1-Day Event	25-Yr/3-Day Event
2	Naples Beach Hotel & Golf Club	36.8 (19.9)	26.2 (14.2)	84.1 (45.5)
3	8th Avenue North	9.6	8.5	2.9
4	7th Avenue North	9.8	8.0	12.4
5	6th Avenue North	5.6	5.1	8.2
6	Alligator Lake Outfall	37.0 (34.2)	37.0 (34.2)	82.3 (76.1)
7	3rd Avenue North	19.4	16.4	24.1
8	1st Avenue North	31.7	28.1	42.6
9	1st Avenue South	8.2	8.0	11.2
10	2nd Avenue South	9.6	8.1	11.8
TOTAL		168 (148)	145 (131)	290 (245)




Values in parenthesis represent the predicted
 Naples Beach Hotel & Golf Club Improvements (Grady Minor, 2015)

WQ Sampling & Testing

Parameters Tested

- Suspended Solids
- Fecal Coliform
- Enterococci
- Nitrogen, Nitrate & Nitrite
- Phosphorous
- Turbidity
- Conductivity & Temperature



Sites for Consolidation & Pump Stations


Largest % of Total Flow:

Outfall 2: 19%


Outfall 6: 31%

Outfall 8: 17%

67%




City's Existing Utility Infrastructure & S/W Line Consolidation Options



Pipeline Consolidation along Gulf Shore Blvd

- Utilities Department prefers consolidation line west ROW to replace the potable watermain
- Consolidation line east side concurrent with creating a bike lane



Conceptual Collection System for Pipeline Consolidation

(Alternative 1)

Conveyance Direction	Outfall Description		Peak Flow for the 5-Yr/1-Day Event	Collection System Flow	Cumulative Collection System Flow
			(cfs)	(Peak cfs)	(Peak cfs)
To Outfall 2	2	Naples Beach Hotel and Golf Club	5.7		
To Pump Station 1	2	Naples Beach Hotel and Golf Club (City)	8.5	28.4	28.4
	3	8th Avenue North	8.5	12.9	41.3
	4	7th Avenue North	8.0	12.4	53.6
	<i>Sub-Total (2-4)</i>		25.1	53.6	
Pump Station 1					61.9
To Pump Station 1	5	6th Avenue North	5.1	8.2	8.2
	<i>Sub-Total (5)</i>		5.1	8.2	
To Pump Station 2	6	Near Alligator Lake	34.2	76.1	76.1
	7	3rd Avenue North	16.4	24.1	100.2
	<i>Sub-Total (6-7)</i>		50.6	100.2	
Pump Station 2					165.7
To Pump Station 2	8	2nd Avenue North	28.1	42.6	65.6
	9	1st Avenue South	8.0	11.2	23.0
	10	2nd Avenue South	8.1	11.8	11.8
	<i>Sub-Total (8-10)</i>		44.2	65.6	
TOTAL CONSOLIDATED			124.9	165.7	227.6
TOTAL PEAK RUNOFF (Outfalls 2-10)			130.5		

Conceptual Discharge Plan for Pipeline Consolidation LOS Requirement (25-yr)

Description	Cumulative Collection System Flow	Pump Station Flow Discharged to Gulf	System Overflow
Pump Station 1	61.9	61.9	0.0
Pump Station 2	165.7	94.8	71.0
TOTAL CONSOLIDATED	227.6	156.6	71.0

All values are peak flow rates (cfs)

Pump Station Siting



3rd Avenue North




6th Avenue North

Alligator Lake
Generator Site



Pump Station Components

- **Below Grade Wet Well & Valve Vault**
- **Elevated Control Panel**
- **Emergency Generator**



Design Requirements Summary

- **Improve Function of Existing S/W System**
 - Pump Station will Significantly Improve Drainage & Increase System Efficiency
 - Eliminate Stormwater “Staging” for Pipe Flow to Gulf
 - Pump Station Below Grade and Adjacent to Beach
 - Low Relief Diffuser System to Minimize Impacts
 - Overflow Capacity for Extreme Rainfall Events
 - Allow for Changes to Components
- **Minimize/Eliminate Impacts to Water Quality**
 - Stage Treatment (Filtration, UV Disinfection as required)
- **Prevent Erosion to Beach - Dune System**
 - Subsurface Pipeline to Offshore Diffuser
 - Eliminate Impacts to Beach-Nearshore System (removing outfalls)

Alternatives

Alternative	Pump Station Location	Total Flow % Consolidated to Pump Station		System Re-Routing	Outfalls to Remain
		5-yr	25-yr		
1	3 rd Avenue N	77%	41%	To Moorings Bay & Naples Bay	Outfall 2 (Private Contribution)
2	6 th Avenue N (“North System”) <u>and</u> 3 rd Avenue N (“South System)	96%	69%	-	Outfall 2 (Private Contribution)
3	Vicinity of Naples Beach Hotel & Golf Club (“North System”) <u>and</u> 3 rd Avenue N (“South System)	100%	77%	-	-

Alternatives: Conceptual Flow Schematics

ALTERNATIVE #1 Single Pump Station @ 3rd Ave N



5-yr	77%
25-yr	41%

ALTERNATIVE #2 Two Pump Stations @ 6th Ave N & 3rd Ave N



5-yr	96%
25-yr	69%

ALTERNATIVE #3 Two Pump Stations @ Near Golf Club & 3rd Ave N




5-yr	100%
25-yr	77%


Alternative 1: Single Pump Station 3rd Ave North

Pipeline Consolidation Schematic

Pipeline Segment	Cumulative Peak Flow (cfs)	Outfall Peak Flow (5yr-1day / 25yr-3day) (cfs)	Segment Length (ft)	RCP Size (in)
1	12.9	Outfall # 3 (8th Ave N) (8.5 / 12.9)	360	24
2	25.3	Outfall # 4 (7th Ave N) (8.0 / 12.4)	780	30
3	33.5	Outfall # 5 (6th Ave N) (5.1 / 8.2)	420	36
4	68	Outfall # 6 (34.2 / 76.1)	800	36 (2) (from Outfall 6)
Sub-Total 4			2,770	
5	42.6	Outfall # 7 (3rd Ave N) (16.4 / 24.1)	810	36
		Outfall # 8 (2nd Ave N) (28.1 / 42.6)		
Total	5		3,580	




Pump Station, Offshore Discharge & Diffuser System (Alternative 1)



**Alt 1 Peak Flow
= 100 cfs**

Consolidated Stormwater System to Offshore Discharge

Profile View





No Dune Impacts

Reduces Environmental Impacts


Diffuser Beyond Depth of Closure

Overflow Line (Modify Outfall #6)




Filtration & Treatment System

- Complete WQ Testing Program
- Determine WQ Treatment Requirements
- Design Suspended Sediment Filtration
- UV Treatment System



Offshore Diffuser System

Gulf of Mexico



Cost Comparison

Item	Description	Alternative 1	Alternative 2		Alternative 3	
			North System (Phase I)	South System (Phase II)	North System (Phase I)	South System (Phase II)
1	Mobilization/Demobilization	\$578,300	\$586,900	\$593,300	\$496,530	\$593,300
2	Pipeline Consolidation	\$4,084,000	\$1,723,800	\$2,507,300	\$1,786,000	\$2,507,300
3	Pump Station System	\$2,403,680	\$2,312,200	\$2,403,680	\$1,809,200	\$2,403,680
4	Water Quality Treatment System	\$1,115,000	\$1,025,000	\$1,387,500	\$1,025,000	\$1,387,500
5	HDD & Diffuser System	\$2,794,000	\$3,038,000	\$1,946,000	\$2,882,000	\$1,946,000
Sub-Total (Items 1-5)		\$10,974,980	\$8,685,900	\$8,837,780	\$7,998,730	\$8,837,780
Contingency (20%)		\$2,195,000	\$1,737,200	\$1,767,600	\$1,599,700	\$1,767,600
Sub-Total by System		\$13,169,980	\$10,423,100	\$10,605,380	\$9,598,430	\$10,605,380
Total		\$13,169,980	\$21,028,480		\$20,203,810	
% of 5-yr / 25-yr Flow Treated		77% / 41%	96% / 69%		100% / 77%	
Effectiveness per Dollar Spent (Construction \$ / % Treated)		\$17.1M / \$32.1M	\$21.9M / \$30.5		\$20.2M / \$26.2M	

Alternatives Evaluation & Ranking

- **Ranking by City Engr & Natural Resource Depts and Engr Team**
- **Meetings with Stakeholders**
 - **Conservancy of SWFL and Waterkeeper Alliance**
 - **Permitting Agencies (SFWMD, FDEP)**
- **Sensitivity Analysis**
- **Ranking Scale**

Ranking	Description
-7 / +7	Significant comparative negative/positive project impact
-4 / +4	Medium comparative negative/positive project impact
0	Neutral impact for project

Alternatives Evaluation & Ranking

Evaluation Criteria	Weight	Alternative 1		Alternative 2		Alternative 3	
		Raw	Weighted	Raw	Weighted	Raw	Weighted
Technical	40%		1.15		1.08		1.63
Meets Project Objectives	15%	4	0.60	4	0.75	6	0.90
Technical Complexity (Pipeline Consolidation)	5%	-6	-0.30	-5	-0.25	-4	-0.20
Operational Integrity and Reliability (Pump Station)	7.5%	6	0.45	4	0.30	4	0.30
Constructability	7.5%	4	0.30	3	0.23	5	0.38
Scalability	5%	2	0.10	4	0.20	5	0.25
Financial	30%		0.30		0.15		0.30
Capital Expenditure (CAPEX)	15%	-1	-0.15	-3	-0.45	-3	-0.45
Effectiveness per Dollar Spent	15%	3	0.45	4	0.60	5	0.75
Non-Technical	30%		1.30		1.23		1.68
Social Considerations	7.5%	4	0.30	2	0.15	5	0.38
Environmental Impact	10%	4	0.40	5	0.50	6	0.60
Regulatory Approvals (Permitting)	5%	6	0.30	4	0.20	5	0.25
Health & Safety (Flood Protection, Public Safety, Recreation, etc)	7.5%	4	0.30	5	0.38	6	0.45
	100%		2.8		2.5		3.6

Preferred Alternative

- **Alternative 3: Two pump stations**
- **Removes All City Outfalls (9)**
- **Routes Outfall 5 to Alligator Lake
(Additional WQ Treatment)**
- **Significantly Improves Nearshore Water Quality**
- **Highest Effectiveness per Dollar Spent
(100% / 77% of flows treated)**
- **Eliminates Adverse Impacts to
Environmental Resources**
- **Scalable**

North Pump Station
on Golf Course
(exact location to be
determined)


System Generator →

South System
Pump Station
& Electrical
System →

Alternative 3 “North System”

Pipeline Consolidation Schematic


Pipeline Segment	Cumulative Peak Flow (cfs)	Outfall Peak Flow (5yr-1day / 25yr-3day) (cfs)	Segment Length (ft)	RCP Size (in)
1	33.5	Outfall # 2 (Naples Beach Hotel and Golf Club) (8.5 / 12.9)	850	42
2	20.6	Outfall # 3 (8th Ave N) (8.5 / 12.9) Outfall # 4 (7th Ave N) (8.0 / 12.4)	360	30
Total	2		1,210	




Offshore Discharge (Peak Flow)

- 100% 25-yr

“North System” Pump Station Design



“North System” Offshore Discharge and Diffuser System



Preferred
Alternative

Pipeline Consolidation Schematic

Alternative 3 “South System”


Offshore Discharge (Peak Flow)

- 100% 5-yr
- 77% 25-yr

Preferred
Alternative


Pipeline Segment	Cumulative Peak Flow (cfs)	Outfall Peak Flow (5yr-1day / 25yr-3day) (cfs)	Segment Length (ft)	RCP Size (in)
1	8.2	Outfall # 5 (6th Ave N) (5.1 / 8.2)	230	18
2	34.2	Overflow Diversion Structure Outfall # 6 (34.2 / 76.1)	800	36 (2)
Sub-Total 2			1,030	
3	65.6	Offshore Pump Station Outfall # 7 (3rd Ave N) (16.4 / 24.1)	800	36 (2)
4	23.0	Beach Dune Outfall # 8 (1st Ave N) (28.1 / 42.6)	850	36
5	11.8	Outfall # 9 (1st Ave S) (8.0 / 11.2)	400	24
		Outfall # 10 (2nd Ave S) (8.1 / 11.8)		
Sub-Total 3			2,050	
Total			3,080	

“South System” Pump Station Design




Typical Underground Pump Stations with Elevated Control Panel

“South System” Generator Site



“South System” Offshore Discharge & Diffuser



Preferred
Alternative

Cost Estimate & Phases

Item	Description	Alternative 3	
		North System (Phase I)	South System (Phase II)
1	Mobilization/Demobilization	\$496,530	\$593,300
2	Outfalls Consolidation	\$1,786,000	\$2,507,300
3	Pump Station System	\$1,809,200	\$2,403,680
4	Water Quality Treatment System	\$1,025,000	\$1,387,500
5	HDD & Diffuser System	\$2,882,000	\$1,946,000
Sub-Total (Items 1-5)		\$7,998,730	\$8,837,780
Contingency (20%)		\$1,599,700	\$1,767,600
Sub-Total by System		\$9,598,430	\$10,605,380
Total		\$20,203,810	

Preferred
Alternative

Consolidation (South System) along back-beach potentially results in \$1.8 cost savings

Recommendations & Next Steps

- **Continue Stakeholder / Community Coordination**
- **Complete Water Quality Testing Program**
- **Additional Data Collection and Modeling**
- **Supplemental Engineering**
- **Return to Council with Update**
- **Detailed Design and Permitting**

November 2016



Questions and Discussion